

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	5	3	5	3	5	0	0	
	Grand Total	1082	6468	4	6	4	6	4	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.11.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Devarkadra	33KV	Narayanapet	14.12	15.20	01.08	EL	No Visible Fault		NO
2		Kalwakurthy	Jaknalapally	33KV	Nagarkurnool	06.15	08.54	02.39	EL/&OL	Insulator Damaged		NO
1	SDPT	Habsipur	Dubbak	33KV	Siddipet	22.20	00.00	01.30		Due to tripped on EL		-
1	RR N	132KV LGM Pet	33KV MN Park	33KV	Medchal	05.28	08.21	02.53	BD	33KV Pin Insulator Failed at Unique Bio Tech Company		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 20.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Chakalpally	11KV	Jadcherla	06.00	09.30	03.30		11 KV wire cut near Chakalpally.	-
1	NLG	Thoragal	Madaram	11KV	Nalgonda	13.00	14.00	01.00	EL	Insulator failed	-
2		Gundepuri	Pasthala	11KV	Suryapet	06.02	09.10	03.08	EL	Disk failed at Pasthala X road	-
3		Choutuppall ipds	Thangedipally	11KV	Bhongiri	10.02	11.39	01.37	EL/OL	11 KV Disc Failed at Govt High school Near Thangedipally village	-
1	SDPT	Thunki Khals	Thunki Khalsa	11KV	Gajwel	13.05	14.15	01.10		11 KV Line cut	-
1	HYD N	H.A.L.	Samrat	11KV	VI	21.07	22.32	01.25	OL-Rph	HT Line snapped at Saibaba Temple, near Nala	-