

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		1		1		1			
3	MDK	107	933		2		2		2			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 24.11.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD				NIL							-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 24.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Bhogaram	11kv	Narayanpet	15.20	16.40	01.20		Jumper cut and touched the cross arm	-
2		Maddur	Maddur	11kv	Narayanpet	10.40	11.54	01.14		11KV Line Phase to Phase	-
3		Salkarpet SS	Jangamreddypally	11kv	Narayanpet	09.20	12.00	02.40		Tree Fallen on 11KV line	-
1	NLG	B.P.Pally	Mukthapur	11kv	Choutuppall	08.05	09.00	00.55	EL	11kv Post off Insulator Failed near Mukthapur Village	-
1	MDK	Sadasivpet	TSM	11kv	Sangareddy	15.30	16.40	01.10		BD due to Tree branches fallen on line	-
2		Inole	Peddakanjarla	11kv	Patancheru	00.10	05.00	04.50		BD due to Insulator failed	-
1	SDPT	RAIPOLE	THIMMAKKAPALLY	11kv	Gajwel	13.50	16.15	02.05		HT/LT	-
2		CHITYAL	CHITYAL	11kv	Husnabad	12.10	13.30	01.20		TREE FALLEN ON CONDUCTOR	-
1	RR N	Shameerpet	Alankrita	11kv	Medchal	06.40	10.05	03.25		11KV Line Touched to Channel at Ring Road Out	-
2		Kistapur	Kistapur	11kv	Medchal	11.45	12.40	00.55		Tree Branches fallen on the 11KV Line at Drums Company	-
1	RR E	IDAUppal	Srikrishna	11kv	Habsiguda	08.13	09.25	01.12		11kv BUNCH Cable earth wire fallen on 11KV line at beside SA printer	-
1	HYD C	S.D.Hospital	Crescent Hospital	11kv	VII	12.03	13.28	01.25	EL,OL-Rph	I/C Cable fault at Crescent Hospital (1No. DTR kept off)	-