

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	3	18	3	18	3	18			
7	RR(E)	168	403		16		16		16			
8	Hyd	194	1044		17		17		17			
	Total	606	3055	3	51	3	51	3	51	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	11	12	11	12	11	12			
2	NLG	144	988		12		12		12			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT			1	8	1	8	1	8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	13	34	13	34	13	34	0	0	
	Grand Total	1082	6468	16	85	16	85	16	85	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurthy	33KV	Narayanapet	09.40	10.10	00.30	EL	No Visible fault Supply OK	Kankurthy	Alternate Supply Arranged from 33KV Mogalmadka Feeder at 10:10Hrs
2		Maddur	Damargidda	33KV	Narayanapet	12.15	13.55	01.40	EL	Disc Insulator Failed & Replacement at Damargidda Said	Damargidda	No
3		Marikal	Koukuntla	33KV	Narayanapet	20.40	21.18	00.38	EL	No Visible fault Supply OK	Koukuntla	No
4		Nagarkurnool	Bijinapally	33KV	Nagarkurnool	1:00	6:47	5:47		No Visible fault Supply OK	Bijinapally	AB Switch Open at Vittem SS
5		Kalwakurthy	Jaknalapally	33KV	Nagarkurnool	7:10	10:55	3:45	EL&OL	2No Insulator Replacement & Tree Fallen on the Line Tree Cutting Work	Jaknalapally	No
6		Kalwakurthy	Vangoor	33KV	Nagarkurnool	19:32	20:05	0:33		R Phase L A Blast	Vangoor	Alternate Supply Arranged from 33KV Polkampally Feeder
7		Kalwakurthy	Rachoor	33KV	Nagarkurnool	21:52	23:20	1:28		B Phase L A Blast	Rachoor	No
8		220/33KV SS Singota	Kudikilla	33KV	Nagarkurnool	13:00	15:30	2:30	EL&OL	No Visible fault Supply OK	Kudikilla	AB Switch open at Narlapur
9		leeza	Gattu	33KV	Gadwal	8:24	10:07	1:43	EL	3no insulators failed	Gattu	Alternate Supply Arranged 33KV Mitta Doddy Feeder at 10:07Hrs
10		Alampur	Alampur	33KV	Gadwal	2:19	3:06	0:47	EL&OL	No Visible fault Supply OK	Alampur	No
11		Alampur	Undavelly	33KV	Gadwal	16.26	18.00	01.34	OL	Due to Rain	Undavelly	Alternate Supply Arranged 33KV Alampur Feeder at 18:00Hrs
1	MDK	Gummadidala	AFA	33KV	Patancheru	6:40	10:40	4:00		Due to Pin Insulator Failure	AFA	No
1	SDPT	Gajwel	Pragnapur	33KV	Gajwel	2:02	3:55	1:53		BD (Due to Rain)	Pragnapur	No
1	RR N	132KV LGM Pet	LGM Pet	33KV	Medchal	3:19	8:50	5:31		No visible fault	LGM Pet	Back feeding arranged from 33KV Ratnalayam Feeder at 05:30 hrs
2		132KV LGM Pet	MN Park	33KV	Medchal	03.44	06.37	02.53		No visible fault	MN Park	No
3		132KV Medchal	Aliabad	33KV	Medchal	05.00	08.40	03.40		33KV Jumper Opened at Ganapur Village	Aliabad	No

TSSPDCL - LMRC / Corporate office

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown
1	MBNR	Jaklair	Jaklair	11KV	Narayanapet	08.00	12.50	04.50		Breakdown due to line fault
2		Bijwar	Bijwar	11KV	Narayanapet	10.00	12.00	02.00		11KV insulator failure at kothapally vlg
3		Maganoor	Wadwat	11KV	Narayanapet	10.11	11.15	01.04		Jumper cut and touched the cross arm
4		Salkarpet	Reddypally	11KV	Narayanapet	11:00	14:00	3:00		Jumper cut and fallen on 11KV cross arm
5		Salkarpet	Jangamreddypally	11KV	Narayanapet	13:00	15:00	2:00		Insulator failure
6		Vennached	Lingaipally	11KV	Narayanapet	11:02	11:57	0:55		Tree branch fallen on 11KV line
7		APPAKPALLY	JAJAPUR	11KV	Narayanapet	14:15	15:50	1:35		BIRD FALLEN ON THE LINE, APPAKPALLY
8		KONDAPUR	HANUMANPALLY	11KV	Narayanapet	10:35	11:00	0:25		HT/LT CROSSING, VENTARAM REDDY DTR, HANUMANPALLY
9		Udithyal	Macharam	11KV	Jadcherla	2:09	14:30	12:21		11KV Disc failed Near Tanmai Company side.
10		Udithyal	Udithyal	11KV	Jadcherla	5:32	8:20	2:48		11Jumper Cut Near Veerannapally (Vi).
11		Kandoor	Komreddy pally	11KV	Jadcherla	6:40	13:50	7:10		11KV Insulator Failure And Top Pinbinding Cut Near Gouripally(vi).
12		Karkonda	Fathepur	11KV	Jadcherla	06.38	10.36	03.58		Tree Fallen on the 11Kv Line Near Fathepur (V)
1	NLG	Penpahad	Potlapahad	11KV	Suryapet	2:30	6:40	4:10	E/L	Jumper cut
2		Kasarabada	Circlepeta	11KV	Suryapet	03.00	06.40	03.40	E/L	Insulator failed
3		Reddygudem	Maddirala	11KV	Suryapet	14.40	16.40	02.00	E/L	Jumper cut
4		Bollepally	Jampally	11KV	Bhongir	07.10	08.15	01.05	EL/OL	11 kv Pole dammage near Meti thanda
5		Kondamadugu	Kondamadugu	11KV	Bhongir	06.00	12.00	06.00	EL/OL	11kv Insulator Failed near Bibinagar Village
6		Chamapur	Singaram	11KV	Bhongir	06.00	10.30	04.30	EL/OL	11kv Disc Failed near Kalvapally Village
7		Choutuppal	Thangedipally	11KV	Choutuppal	04.00	10.10	06.10	EL/OL	11kv Disc Failed near Thangadapally Village
8		Choutuppal IPDS	Thangdapally	11KV	Choutuppal	14.22	15.24	01.02	EL/OL	11kv Disc Failed near Thangadapally Village
9		Juloor	Kapraipally	11KV	Choutuppal	07.22	09.10	01.48	EL/OL	11 KV Insulator failed near Kapraipally village
10		Voligonda	Nagaram	11KV	Choutuppal	03.10	04.20	01.10	EL/OL	11 kv Insulator failed near voligonda gutta

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown
11		Pamangundla	Pittampally	11KV	Nalgonda	05.00	06.30	01.30	EL/OL	Insulator failed
12		T.P.Gouraram	Thungapad	11KV	Devarakonda	3:30	6:30	3:00	EL/OL	11 KV Disc failed
1	MDK	Bollaram - II	Kottam	11KV	Patancheru	3:00	6:00	3:00		Due to Insulator Failure
2		EPIP-I	Newland (New)	11KV	Sangareddy	17.35	18.25	00.50		Due to Conductor Snapped
1	SDPT	MARKOOK	SNEHA INDUSTRIAL	11KV	Gajwel	3:30	7:40	4:10		11 KV LINE CUT
2		PAMULAPARTHY	EPPALAGUDAM	11KV	Gajwel	4:00	10:30	6:30		DISC FAILED
3		GOWRARAM	PAMULAPARTHY	11KV	Gajwel	6:00	14:00	08.00		DISC FAILED
4		MULUGU	BAILAMPUR	11KV	Gajwel	07.55	14.35	06.40		Insulator failed
5		DOULTHABAD	SHERIPALLY BANDARAM	11KV	Gajwel	13.10	15.20	02.10		Insulator failed
6		Jakkapur	Shanigakuntla	11KV	Siddipet	14.12	16.25	02.13		11 KV wire cut & LC.No.16806
7		Nangnoor	Nangnoor	11KV	Siddipet	04.00	09.10	05.10		Jumper cut & LC.No.22855
8		Guruvannapet	Guruvannapet	11KV	Husnabad	7:30	8:50	1:20		Disc failed
1	RR N	Madinaguda	Swaranapuri Colony	11KV	Kukatpally	4:10	5:30	1:20	EL/OL	Tree Fallen On the 11kv Line 11kv Line At AdaiahNagar
2		HMT	Venkanna Hills	11KV	Medchal	03.50	04.45	00.55		No visible fault
3		Petbasheerabad	ST Ann's	11KV	Medchal	17.00	17.55	00.55		Tree fallen on the 11KV Line at Police Station
4		Kompally	Jaibheri	11KV	Medchal	17.20	18.18	00.58		No visible fault
5		UMCC	HAL Colony	11KV	Medchal	19.10	20.45	01.35		11KV Pin Insulator failed and replaced at UMCC Main Gate
6		ICICI	Bharathbio tech	11KV	Medchal	08.05	09.00	00.55		11KV Jumper cut at Bharathbio tech company
7		Aliabad	HBL	11KV	Medchal	09.00	10.40	01.40		Tree Branch fallen on the Line at Hanuman Temple
8		Kandlakoya	KV Reddy Nagar	11KV	Medchal	02.25	07.14	04.49		Tree Branches fallen on the 11KV Line at Big Boss Company
9		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	02.45	08.05	05.20		No visible fault
10		Nuthankal	Nuthankal	11KV	Medchal	09.10	10.40	01.30		Bird fallen on the 11KV Line at Mullegudem
11		Thurkapally	Thurkapally	11KV	Medchal	02.15	03.05	00.50		100KVA T/F Copper Patti Cut at Mellakunta Cheruvukatta
12		GP Pally	APIIC	11KV	Medchal	04.11	08.50	04.39		Tree fallen on the 11KV Line at JK Seeds
13		GP Pally	Neighbourhood	11KV	Medchal	05.55	08.55	03.00		Tree fallen on the 11KV line at Sunitha House T/F Opposite
14		Gowdavelly	Basaragadi	11KV	Medchal	12.10	12.50	00.40		Tree fallen on the 11KV Line at Gyanapur Village
15		Nuthankal	Nuthankal	11KV	Medchal	14.30	15.10	00.40		11KV Jumper Opened at Ankoor Goud Bore Well
16		Devarayamjal	Mandaipally	11KV	Medchal	18.00	19.30	01.30		No visible fault

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown
17		Kandlakoya	Kandlakoya	11KV	Medchal	18.10	19.10	01.00		11KV Line cut and replaced at Cheruvukatta
18		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	18:02	20:10	2:08		No visible fault
1	RR E	Moula-Ali	Mirzalguda	11KV	Sainikpuri	3:10	4:00	0:50		Line petrolling done but no visible fault found
2		Anand Bagh	Chandragiri Colony	11KV	Sainikpuri	07.53	09.28	01.35		Cross aram fallen on 11Kv line at Shiva Gouri Enclave
3		Moula-Ali	Mirzalguda	11KV	Sainikpuri	17.02	18.25	01.23		Line patrolling done but no visible fault found
4		RGK	Barshipet	11KV	Sainikpuri	17.30	20.18	02.48		11Kv Pin Insulator failed at Priya Darshani and Heavy Rain
5		Cherlapally-III	Danmed	11KV	Sainikpuri	19.55	20.58	01.03		Tree fallen on 11Kv line at Vishwajeeth Company
6		Cherlapally-IV	BN Reddy Nagar	11KV	Sainikpuri	20.35	22.05	01.30		Tree branches fallen on 11KV line and Insulator failed at BN Reddy Nagar
7		IICT	CCMB	11KV	Habsiguda	03.30	04.46	01.16		11KV Disc failed at Venkateswara Ice
8		St.No.08	Ravindra Nagar	11KV	Habsiguda	17.07	18.44	01.37		11KV Pin Insulator failed at Ravindra Nagar Colony Church(50% load charged at 17:29)
9		IDA Uppal	Ram Reddy Nagar	11KV	Habsiguda	17.12	18.50	01.38		11KV Disc failed at Road No.13 TV Colony
10		NGRI	Habsiguda	11KV	Habsiguda	16.35	17.35	01.00		11KV Pin Insulator failed at St.No.05 Habsiguda
11		Uppal	Raghavendra Colony	11KV	Habsiguda	15.55	18.37	02.42		11KV HG Fuse Insulator failed at Praveen Mudiraj Home,11KV Line AB Switch jumper cut at Dharmapuri Colony and 11KV UG Cable failed at Beerappagadda Sai Darshini Apartment
12		Chakripuram	S V Nagar	11KV	Keesara	07.20	08.49	01.29		Squarrel fallen on 63KVA DTR at S V Nagar Road No.02
13		Narapally	Prathap Singaram	11KV	Keesara	06.05	06.50	00.45		11KV Pin Insulator failed at Tirumal Nagar
14		P&T Colony	Canara Nagar	11KV	Keesara	07.15	07.55	00.40		11KV Pin Insulator failed at Budda Nagar Road No.07
15		P&T Colony	Medipally	11KV	Keesara	18.50	19.30	00.40		Line Patrolling but no visible fault & Line AB Switch opened at Sri Sai Nagar
16		Nagaram	Gandhi Nagar	11KV	Keesara	17:10	18:15	1:05		11KV Insulator failed at Milaan Garden
1	HYD N	MLA Colony	Lotus Pond	11KV	X	00.10	01.35	01.25	OL	Post type Insulator flash over at Lotus Pond
2		Macha Bollaram	Radha Sath Sang	11KV	C-VI	3:55	5:20	1:25	A/R Opened	Tree branches fallen on lines at Hanuman Temple
3		Gymkhana	Pared Ground	11KV	C-VI	16:36	18:02	1:26	OL-R&Yph	-----
4		Seethaphalmandi	Namal Gundu	11KV	V	16:45	18:05	1:20	OL-Rph	Twisted Lines at Wesley Church
5		Lalaguda	A.P Dairy	11KV	V	17.20	18.50	01.30	EL	Tree branches fallen on lines at Grave Yard

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown
1	HYD S	Chanchalguda	Chowni	11KV	VIII	07.34	08.53	01.19	EL,OL-Rph	Jumper cut at Chowni
2		Asmangadh	Saidabad Colony	11KV	VIII	17:34	18:53	1:19	All Indication	Pin Insulator flash over at Quadri Masjid Line AB Switch
1	HYD C	Fever Hospital	Kachiguda Railway Station	11KV	II	01.58	06.40	04.42	All Indication	No Visible Fault
2		Asif Nagar	Hakimpet	11KV	VII	03.38	05.22	01.44	EL	Tree branches fallen on lines at Hakimpet
3		Golconda	Golconda OH	11KV	VII	03.40	06.25	02.45	EL,OL-Yph	Post type Insulator flash over at Resham Bagh
4		Golconda	Narayanamma College	11KV	VII	3:40	6:50	3:10	EL,OL-Yph	Pin Insulator flash over at Raj Nagar Colony
5		Toli Chowki	Paramount Hills	11KV	VII	5:35	8:12	2:37	EL,OL-Bph	No Visible Fault
6		Asif Nagar	Hakimpet	11KV	VII	5:37	8:50	3:13	All Indication	No Visible Fault
7		Golconda	Mothi Mahal	11KV	VII	5:48	7:30	1:42	EL	Pin Insulator flash over at Lakdika Tall
8		S.D.Hospital	Ahmed Nagar OH	11KV	VII	5:50	8:08	2:18	EL	Pin Insulator flash over at Mahammed Apts
9		Bathkammakunta	Saibaba Temple	11KV	II	16:17	17:30	1:13	EL	Disc Insulator flash over at Orchid Apts
10		S.D.Hospital	Police Mess	11KV	VII	17.30	19.15	01.45	EL,OL-Rph	HT Jumper cut at A.R

Alternate Supply Arranged
No
No
No
No
No
No
No
No
No
No
No
No
No
70% Load B/F supply taken from 11KV Kalyanipuri Feeder & remaining 30% load charged at 22:10
No
No
No
No
No
No
No
Partial feeder arranged B/F on 11KV Balamrai fdr
No
No

Alternate Supply Arranged
Arranged B/F on 11KV Bada Bazar feeder
No
No
No
No
No
No
Arranged B/F on 11KV Brindavan Colony fdr
No
No
No
No