

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		9		9		9			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		6		6		6			
	Total	606	3055	0	18	0	18	0	18	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	11	3	11	3	11			
2	NLG	144	988		10		10		10			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	22	3	22	3	22	0	0	
	Grand Total	1082	6468	3	40	3	40	3	40	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.11.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Machanpally	33KV	Mahabubnagar	11.55	12.35	00.40	EL	Manikonda Isolator Closed & Opening Manikonda Isolator Feeder charged Stood OK	Machanpally	-
2		Balanagar	Thomidirekula	33KV	Jadcherla	11.40	12.35	00.55	EL	Jumper Cut at Hemajipur	Thomidirekula	-
3		Achampet	Amrabad	33KV	Nagarkurnool	02.25	09.45	07.20	EL	Tree Fallen on the Line Near Rangapur	Amrabad	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 28.11.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Krishna	Chegunta	11KV	Narayanapet	06.34	07.43	01.09		Due to 11KV Line Fault	-
2		Maganoor	ADIVISATYARAM	11KV	Narayanapet	02.00	08.40	06.40		11KV ADIVISATYARAM breaker problem	-
3		MANTHANGODE	Katchwar	11KV	Narayanapet	06.00	09.00	03.00		11KV Conductor cut at Katchwar entrance	-
4		MANTHANGODE	Katrevpally	11KV	Narayanapet	05.00	09.00	04.00		11Kv Disc failure at uppari Govindhu chenu	-
5		Gudeballore	CHECKPOST	11KV	Narayanapet	10.30	11.30	01.00		TREE BRANCH FALLEN ON 11kv LINE AT Tie road	
6		KANKURTHY	LOKURTHY	11KV	Narayanapet	11.08	11.50	00.42		DUE TO SQUIRREL CAME IN TOUCH WITH THE LINE	
7		MARIKAL	GUNMUKLA	11KV	Narayanapet	06.30	07.45	01.15		DUE TO DISC FAILURE	
8		Konded	Konded	11KV	Jadcherla	05.30	13.30	08.00		11KV Wire Cut Near Laxmi Nayak tanda Side.	-
9		Mothiganapur	Medigadda Tanda	11KV	Jadcherla	01.30	10.00	08.30		11KV Disc Fail Near Kurva Gadda Tanda Side.	-
10		Pomal	Pomal	11KV	Jadcherla	11.04	13.00	01.56		11KV jumper Cut Near pomal (Vi).	-
11		Bhoothpur	Rural	11KV	Jadcherla	03.30	06.45	03.15		11Kv Phase To Phase Near Goplapur(Vi).	-
1	NLG	Palem	Palem	11KV	Nalgonda	14.00	15.10	01.10	EL	Jumper cut	-
2		Mushampally	Muthyalamma	11KV	Nalgonda	04.00	05.30	01.30	EL	Insulator failed	-
3		Chitriyala	Gajillapur	11KV	Devarakonda	12.20	12.55	00.35	EL	11 KV Disc Failed	-
4		Tekumatla	Tekumatla	11KV	Suryapet	05.30	09.20	03.50	E/L	Disc failed	
5		.Chandupatla	Thimmapuram	11KV	Suryapet	06.10	08.00	01.50	E/L	Insulator failed	
6		NG.Bandal	Gandamalla	11KV	Bhongir	04.00	09.30	05.30	E/L	11 KV Insulator failed near Gandamalla village.	
7		MT.Pally	MT.Pally Agl	11KV	Bhongir	06.10	12.30	06.20	E/L	11kv Disc Failed near MT.Pally Village	-
8		Nemaragommula	Jameelapet	11KV	Bhongir	02.00	08.35	06.35	E/L	11 kv Insulator failed at Sathish reddy well near Jameelapet village	-
9		D.Nagaram	D.Nagaram Agl	11KV	Choutuppal	03.45	11.15	07.30	E/L	11 KV Disc Failed at Baddam. Anji reddy well & HT/LT NEAR Mogaroni kunta , 11 kv Pole damage	-
10		Puligilla	Kerchupally	11KV	Choutuppal	04.00	09.45	05.45	E/L	11 kv insulator failed at Gundu Balreddy well near Kerchupally village.	-
1	MDK	Anrich Bollaram	Sulaxshana-II		Patancheru	01.50	04.20	02.30		B/D Due to Tree branches fallen on the line	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Kandlakoya	Kandlakoya	11KV	Medchal	02.10	05.50	03.40		Tree Fallen on 11KV Line at Surender Reddy Bavi,Kandlakoya	-
2		Kandlakoya	KV Reddy Nagar	11KV	Medchal	03.45	07.05	03.20		11KV Line AB Switch Opened at Kaveri seeds(No Fault)	-
3		Devarayamjal	DMC	11KV	Medchal	03.00	06.00	03.00		No Fault	-
4		Devarayamjal	Mandaipally	11KV	Medchal	02.00	08.25	06.25		No Fault	-
5		ICICI	Bharathbio tech	11KV	Medchal	17.00	19.30	02.30		Line AB Switch opened at Sami labs Company	-
6		Subhash Nagar	Bank Colony	11KV	Medchal	02.40	03.38	00.58		No Fault	-
7		Kompally	Aparna	11KV	Medchal	01.39	02.52	01.13		11KV Disc Failed and replaced at Rajireddy House,Kompally	-
8		Kompally	Jaibheri	11KV	Medchal	01.48	03.19	01.31		11KV Cable touched to Box pole at Cheruvukatta,kompally	-
9		Subhash Nagar	Pragha Tools	11KV	Medchal	12.03	12.28	00.25		11KV Line Cut at Swetha Hari Apartment	-
1	RR E	Anand Bagh	Shivapuri	11KV	Sainikpuri	01.37	13.38	12.01		1Kv line AB Polimer Insulator failed at RUB Bridge near Thalla Basthi Anandbagh	-
2		Kushaiguda	Kamala Nagar	11KV	Sainikpuri	03.30	05.00	01.30		11KV Disk failed at South Kamala Nagar	-
3		Cherlapally-III	IOC	11KV	Sainikpuri	04.11	05.28	01.17		11Kv pin insulator failed at Stanner Drugs	-
1	HYD N	Zamistanpur	Sanjeevapuram	11KV	V	04.20	06.12	01.52	EL	Disc Insulator flash over at S.R Hospital	-----
2		Kalyan Nagar	Vishwa Bharathi	11KV	X	08.45	10.17	01.32	All Indication	Cable fault	Arranged B/F on 11KV Vengal Rao Nagar fdr
1	HYD S	Asmangadh	Saidabad Colony	11KV	VIII	03.52	05.57	02.05	EL-OL-Y&Bph	Jumper cut at Saidabad Colony	
1	HYD C	Vittalwadi	Kamineni Hospital	11KV	I	08.35	10.15	01.40	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Taj Mahal fdr
2		S.D Hospital	Police Mess	11KV	VII	09.55	11.14	01.19	EL,OL-Bph	HT Jumper cut at 2nd Auto Reclosure	-----
3		Mothi Mahal	Saleh Nagar	11KV	VII	11.45	12.53	01.08	EL	Sparking line AB Switch at Mothi Mahal	-----