

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 1 | | 1 | | 1 | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 0 | 3 | 0 | 3 | 0 | 3 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | | | | | | | | |
| 2 | NLG | 144 | 988 | | 3 | | 3 | | 3 | | | |
| 3 | MDK | 107 | 933 | | 1 | | 1 | | 1 | | | |
| 4 | SDPT | | | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 6 | 1 | 6 | 1 | 6 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 1 | 9 | 1 | 9 | 1 | 9 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 02.10.2020

Circle-wise 33KV Breakdowns

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--------------------|-----------------------|---------------------------|
| 1 | SDPT | Husnabad | Dharmaram | 33KV | Siddipet | 05.50 | 07.45 | 01.55 | | Insulator Fail | | - |

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 02.10.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | NLG | Siripuram | Siripuram | 11KV | Huzurnagar | 10.20 | 12.00 | 01.40 | EL | 11 KV LINE SNAPPED | - |
| 2 | | Palakeedu | Nagireddy gudem | 11KV | Huzurnagar | 14.40 | 16.30 | 01.50 | EL | 11 KV LINE SNAPPED | - |
| 3 | | Motakondur | Motakondur Agl | 11KV | Bhongir | 03.00 | 06.05 | 03.05 | EL | 11 kv Post-off Insulator failed | - |
| 1 | MDK | Patancheru Town | MIA-II | 11KV | Patancheru | 12.10 | 14.45 | 02.35 | | BD due to Conductor snapped | - |
| 2 | SDPT | Mustabad X-Road | Hanuman Nagar | 11KV | Siddipet | 15.35 | 16.55 | 01.20 | | B/D Tree Branches Fall in 11 KV line | - |
| 3 | | KOHEDA | KOHEDA TOWN | 11KV | Husnabad | 12.00 | 02.24 | 04.48 | | B.D DUE TO LINE PROBLEM | - |
| 1 | RR N | Laxmapur | MC Pally | 11KV | Medchal | 09.50 | 11.40 | 01.50 | | Bird fallen on the 11KV Line at Forest, MC Pally | - |
| 1 | HYD C | S.D Hospital | Humayun Nagar | 11KV | VII | 14.02 | 17.27 | 03.25 | EL | Cable fault at KFC, Mehdipatnam | - |
| 2 | | S.D Hospital | Ahmed Nagar UG | 11KV | VII | 14.50 | 16.05 | 01.15 | EL | Sparking AB Switch at Osman PT | - |