

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	8	3	8	3	8	0	0	
	Grand Total	1082	6468	4	11	4	11	4	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.10.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Pasupula	33kv	MBNR	18.3	19.40	01.10		Insulator failure	Pasupula	33KV Peddakodumur
2		Srirangapur	Kondurgu	33kv	MBNR	13.5	16.15	02.25		Insulator failure	Kondurgu	-
1	NLG	Madugulapally	Laxmidevigudam	33kv	Miryalaguda	08.05	12.45	04.40	EL	2 Disk Faild	Laxmidevigudam	-
1	RR N	132KV Malkaram	33KV Ratnalayam	33kv	Medchal	00.44	09.44	09.00	BD	No Fault (Alt arrnaged 33kv LGM Pet 132 LGM Pet at 0:50)	33KV Ratnalayam	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 03.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Edulur	Garlabaigudam	11kv	Nalgonda	07.00	08.10	01.10	EL	Insulator Failed	-
2		G.Malkapuram	Chinthalapalem	11kv	Huzurnagar	03.15	07.00	03.45	EL	11 KV LINE SNAPPED	-
3		Bethavolu	Chennarigudem	11kv	Huzurnagar	12.50	15.00	02.10	EL	11 KV LINE SNAPPED	-
4		Yannaram	Suarram	11kv	Choutuppal	08.45	09.05	00.20	EL/OL	11kv Insulator Failed near SS-9	-
1	SDPT	GOURAVELLY	GUDATIPALLY	11kv	Husnabad	12.25	17.53	05.28		CONDUCTOR SNAPPED	-
2		MARKOOK	MARKOOK	11kv	Gajwel	15:20	16:20	01.00		Bloodsucker(Thonda) fell on line	-
3		ERRAVALLY	TOWN	11kv	Gajwel	16:50	17:58	01.08		LT LINE CUT	-
4		BEGUMPET	BEGUMPET	11kv	Gajwel	17:47	19:22	01.35		JUMPER CUT	-
1	RR E	Vasanthapuri	BJR Nagar	11kv	Sainikpuri	17.45	18.59	01.14		11Kv jumper cut & two wires twisting at DM Hospital	-
2	HYD N	Clock Tower	St Marry's	11kv	V	13.40	15.01	01.21	EL,OL-Rph	RMU smokes at Vijaya Dignostic Center	Arranged B/F on 11KV Gurudwara fdr
3	HYD C	Lake View	N.K.M's Hotel	11kv	I	09.26	10.38	01.12	EL,OL-Bph	Breaker problem at SS	Arranged B/F on 11KV Padmavathi Nagar feeder