

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933	1		1		1				
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	11	1	11	1	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.10.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Hadnoor	33KV	Zaheerabad	03.45	05.00	01.15		BD due to Insulator failed	Hadnoor	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 04.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nakrekal	Kadaparthi	11KV	Nalgonda	07.20	11.30	04.10	E/L	Breaker problem	-
2		Ch.Annaram	Thotlavarigudem	11KV	Nalgonda	09.30	10.30	01.00	E/L	11KV Insulator Failed	-
3		Narkatpally	Mandra	11KV	Nalgonda	14.00	15.30	01.30	E/L	11KV Insulator Failed	-
4		Dirsincherla	Yallapuram	11KV	Huzurnagar	07.50	10.00	02.10	E/L	11Kv Line Snapped	-
5		Paladugu	Duppally	11KV	Bhongir	06.55	10.00	03.05	EL/OL	11kv Line snapped near Narasapur (V)	-
1	SDP	Pandilla	Pandilla rural	11KV	Husnabad	13.15	14.15	01.00		HT/LT line	-
2		Dubbak	Chellapur	11KV	Siddipet	13.03	15.40	02.37		B/D-11 Kv insulater Fail	-
1	RR N	Vijayanagar	Venkateshwera Nagar	11KV	Kukatpally	11.35	13.30	01.55	BD	Tree branchesh Fallen the 11kv line at Road:19, Venkateshweranagar	-
2		Vijayanagar	Shanthinagar	11KV	Kukatpally	13.10	14.40	01.30	BD	AB Cable Failed at MLA Gandhi House, Shanthinagar	-
3		Kistapur	IDA Hanuman	11KV	Medchal	13.10	14.30	01.20	BD	Tree Fallen on 11KV Line at Need Company	-
1	HYD N	Lalaguda	Railway Work Shop	11KV	V	12.30	14.00	01.30	EL	RMU fault at Railway Work Shop	-