

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT				10		10		10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	14	0	14	0	14	0	0	
	Grand Total	1082	6468	0	19	0	19	0	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.10.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Date: 05.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kethepally	Cheekatigudem	11KV	Nalgonda	14:05	16:15	2:10	E/L	11KV AB switch burnt at SS-5 Cheekatigudem	No
2		Aitipamula	R.C.Puram	11KV	Nalgonda	04.07	09.05	04.58	E/L	Bird died on 11KV line	No
3		Bollepally	Jampally	11KV	Bhongir	09.50	11.30	01.40	EL/OL	11kv Line Snapped near Jampally Village	No
1	MDK	Sadasivapet	Nandi Kandi	11KV	Sangareddy	10:30	11:25	0:55		Insulator failed	No
1	SDPT	D R PALLY	TOWN FEEDER	11KV	Gajwel	9:10	9:50	0:40		11KV Jumper cut	No
2		MARKOOK	BHAVANANDAPUR AND SNEHA FEEDER	11KV	Gajwel	10:47	11:20	0:37		11KV Disc failed	No
3		WARGAL	TOWN FEEDER	11KV	Gajwel	15:44	16:27	0:43		LT Line cut	No
4		THUNKIKHALSA	SHAKARAM FEEDER	11KV	Gajwel	15:03	15:30	0:27		LT Line cut	No
5		KONDAPAKA	VISHVANATHPALLY FEEDER	11KV	Gajwel	17:25	18:10	0:45		11KV JUMPER CUT	No
6		MD SHAPUR	LINGAIPALLY THANDA FEEDER	11KV	Gajwel	05.00	09.28	04.28		11KV Line cut	No
7		ANAJIPUR	ANAJIPUR FEEDER	11KV	Gajwel	13:30	14:40	1:10		11KV Disc failed	No
8		GURRALASOPA	VADDEPALLY FEEDER	11KV	Gajwel	9:40	11:25	1:45		11KV Disc failed	No
9		Chityala	Chityala	11KV	Husnabad	09.05	11.20	02.15		Jumper cut	No
10		Dharmaram	Dharmaram rural	11KV	Husnabad	15:30	17:15	1:45		Line problem	No
1	RR N	Jeedimetla SS II	NRSA	11KV	Jeedimetla	5:22	7:05	1:43		11KV AB Cable failure Sub station out side	No
2		Medchal	IDA-I	11KV	Kukatpally	11.05	12.03	00.58		Tree Branch fallen on the 11KV line at Check Post Bus Stop	No
3		Devarayamjal	Pothaipally	11KV	Kukatpally	13.35	14.25	00.50		11KV Cable failed at NTR Statue	No
1	HYD N	Lalaguda	Railway Work Shop	11KV	V	12.05	13.44	01.39	EL	RMU problem at Railway Work Shop	Arranged B/F on 11KV Vijaypuri fdr
1	HYD C	Asif Nagar	Toli Chowki	11KV	VII	16.24	17.43	01.19	EL,OL-Rph	Cable End Kit fault at M.F.Garden	No