

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT				8		8		8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	12	3	12	3	12	0	0	
	Grand Total	1082	6468	3	15	3	15	3	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.10.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanpet	19.55	21.40	01.45	E/L	Due to Line Not Standing		Alternate Supply Arranged From 33KV Hanwada at 21:40Hrs.
2		Narayanapet	Narayanpet-2	33KV	Narayanpet	16.55	18.25	01.30	O/L & E/L	Insulator Failed at Appakpally(V)		NO
3		220/33KV SS Singotam	Kudikilla	33KV	Nagarkurnool	11.39	14.11	02.32	E/L	Cable cut Near Chennapraovpally(V)		NO

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 08.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Chitriyala	Chitriyala	11KV	Devarakonda	11.10	12.25	01.15	E/L	11Kv Insulator Failed	-
2		Repala	Kalakova	11KV	Huzurnagar	14.50	16.00	01.10	E/L	11Kv Line Snapped	-
3		Akupamula	Singaram	11KV	Huzurnagar	12.35	14.35	02.00	E/L	11Kv Line Snapped	-
1	MDK	Patancheru Town	High Power	11KV	Patancheru	13.25	15.30	02.05		B/D due to Conductor snapped	-
1	SDPT	Ankshapur	Nagarajupally	11KV	Siddipet	10.35	11.50	01.15		B/D for HT/LT Line phase to Phase LC No23901	-
2		Gurralongondi	Gurralongondi	11KV	Siddipet	09.08	11.20	02.12		B/D Disc fail LC No.16737	-
3		Ramakkapet	Ramakkapet	11KV	Siddipet	07.09	10.10	03.01		B/D for Due to bird LC No.29740	-
4		AHMEDIPUR	PEDICHED LC	11KV	Gajwel	18.30	18.40	00.10		INSULATOR FAIL	-
5		KONDAPAKA	VISHVANATHPALLY FEEDER	11KV	Gajwel	11:30	15:15	03:45		INSULATOR FAIL	-
6		Ramchandrapur	Varikolu	11KV	Husnabad	12.10	17.30	05.20		Insulation failure, same rectified	-
7		Koheda	Kurella	11KV	Husnabad	06.30	09.05	02.35		Tree fallen on line	-
8		Chityal	Dommata	11KV	Husnabad	00.00	11.35	11.35		Line fault	-
1	RR S	Hafeezpet	Vyshali Nagar	11KV	Gachibowli	00.30	01.50	01.20	BD	11kv AB-Cable failed and rejoined at Sai Nagar Cheruvu	-
1	RR E	Moulali	Spectra	11KV	Sainikpuri	21.30	22.38	01.08		11KV Jumper cut at Joythi Masala Company	-
1	HYD S	Malakpet	Farhath Nagar	11KV	Asmangadh	22.10	23.20	01.10	OL-R&Bph	Jumper cut at Dabeerpura PS	-