

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		6		6		6			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	10	0	10	0	10	0	0	
	Grand Total	1082	6468	0	17	0	17	0	17	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 10.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Nerallapally	11KV	Jadcherla	12.25	15.00	02.35		11KV Wire cut near Gunded(v)	-
2		Midjil	Kothur	11KV	Jadcherla	11.05	14.00	02.55		11KV Insulator fail near Mallapur	-
3		Velgomla	Velgomla Agl	11KV	Jadcherla	12.40	15.17	02.37		11KV Wire cut near Velgomla(v)	-
1	NLG	Chamapur	Singaram	11KV	Bhongir	02.10	06.20	04.10	EL	11 kv Disc failed	-
2		Velugupally	Keshavapuram	11KV	Suryapet	04.30	06.55	02.25	EL	Insulator failed	-
3		Velugupally	G.K.Annaram	11KV	Nalgond	08.00	09.35	01.35	EL	Insulator failed	-
1	SDP	Mustabad X road	Gadicherlapally	11KV	Siddipet	15.55	18.45	02.50		B/D Insulator failure	-
2		JAGADEVPUR	JAGADEVPUR	11KV	Gajwel	14.55	16.25	01.30		INSULATOR FAIL	-
3		Guruvannapet	Tapaspally	11KV	Husnabad	13.30	15.50	02.20		DUE TO RAINFALL	-
4		Komuravelly	Kadavergu	11KV	Husnabad	03.09	04.30	01.21		DISC FAILURE	-
1	RR E	Ramanthapur	Ganesh nagar	11KV	Habsiguda	16.53	18.18	01.25		11KV line Snapped at Vishal temple road X cross	-
1	HYD S	Attapur	Puranaphool	11KV	III	02.40	04.10	01.30	EL,OL	Cable fault at Kamal Dall Mill	-
1	HYD C	Public Garden	Parishram Bhavan	11KV	I	00.11	05.05	04.54	All Indication	Cable End Kit failed	Arranged B/F on 11KV AIR feeder
2		Mothi Mahal	Saleh Nagar	11KV	VII	07.40	10.20	02.40	EL,OL-Bph	Big tree fallen on lines & Bird fault on lines at Military Area	Partial fdr arranged B/F on 11KV Fathe Darwaza fdr
3		Toli Chowki	Ameena Masjid	11KV	VII	09.18	10.50	01.32	EL,OL-Y&Bph	AB Cable fault at Paramount Gate No.3 (3No. DTR's Kept Off)	-----
4		Erramanzil	I.C Quarters	11KV	I	18.24	19.45	01.21	EL	faulty loads of 11KV Erramanzil feeder	-----
5		N.I.M.S	Erramanzil	11KV	I	18.24	21.15	02.51	EL	RMU fault at Erramanzil Chaman	Arranged B/F on 11KV I.C. Quarters fdr