

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550		12		12		12			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		5		5		5			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>22</b>	<b>0</b>	<b>22</b>	<b>0</b>	<b>22</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	4	3	4	3	4			
2	NLG	144	988		7		7		7			
3	MDK	107	933	2	4	2	4	2	4			
4	SDPT				14		14		14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>5</b>	<b>29</b>	<b>5</b>	<b>29</b>	<b>5</b>	<b>29</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>5</b>	<b>51</b>	<b>5</b>	<b>51</b>	<b>5</b>	<b>51</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 11.10.2020

## Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Puttapad	Salkarpet	33KV	Narayanapet	02.33	07.45	05.12		Tree Branches remove on the Line at Kaplapur(V)	Salkarpet	-
2		Narayanapet	Chinnajatram	33KV	Narayanapet	04.50	07.10	02.20		Due to Rain	Chinnajatram	-
3		Ghanapur	Lattupally	33KV	Wanaparthi	11.13	12.40	01.27		33KV Line Fault	Lattupally	-
1	MDK	Jogipet	Dakur	33KV	Jogipet	10.45	16.05	05.20		B/D due to Tree branches fallen on the line	Dakur	-
2		Zaheerabad	Mirzapur B	33KV	Zaheerabad	09.20	10.10	00.50		B/D due to Tree branches fallen on the line	Mirzapur B	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 11.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothapally	Kanchanpally	11KV	Jadcherla	09.00	10.34	01.34		11Kv Phase To Phase Near Limbya Naik Tanda	-
2		Bhoothpur	Rural	11KV	Jadcherla	03.35	08.30	04.55		11Kv Jumper Cut Near Goplapur (Vi)	-
3		Pomal	Ammapur	11KV	Jadcherla	05.00	10.00	05.00		11Kv Phase To Phase Near Ammapur (Vi)	-
4		Pomal	Putonipally	11KV	Jadcherla	05.00	10.00	05.00		11Kv Phase To Phase Near Putonipally (Vi)	-
1	NLG	Marror	Maroor	11KV	Nalgonda	01.10	02.30	01.20	EL	Jumper cut	-
2		Chervupally	Dacharam	11KV	Nalgonda	06.30	07.30	01.00	EL	Insulator failed	-
3		Narkatpally	Mandra	11KV	Nalgonda	04.00	05.30	01.30	EL	Jumper cut	-
4		Velishala	Velishala	11KV	Suryapet	06.40	10.05	03.25	EL	Disk failed	-
5		Repala	Repala	11KV	Huzurnagar	05.00	07.00	02.00	EL	11 KV LINE SNAPPED	-
6		Golankonda	Matoor	11KV	Bhongir	07.55	10.45	02.50	EL/OL	11 kv Line snapped near Golankonda Wagu	-
7		Puligilla	Kerchupally	11KV	Choutuppal	00.05	09.00	08.55	EL/OL	11 kv Line snapped near Kerchupally village. 3 Phase supply ok	-
1	MDK	Sangareddy Rural	P.R Pally	11KV	Sangareddy	10.50	12.55	02.05		B/D due to Insulator failulre	-
2		Ismailkanpet	Industrial	11KV	Sangareddy	09.57	11.26	01.29		B/D due to Tree branches fallen on the line	-
3		Fasalwadi	Rythunagar	11KV	Sangareddy	10.35	14.10	03.35		B/D due to Conductor sanpped	-
4		Bollaram-I	Kyathan	11KV	Patancheru	09.55	13.20	03.25		B/D due to Jumper cut	
1	SDPT	JAGADEVPUR	JAGADEVPUR	11KV	Gajwel	13.15	14.15	01.00		DISC FAIL	
2		NACHARAM	ANTAGIRIPALLY	11KV	Gajwel	09.00	10.25	01.25		TREE BRANCH FALL OVER 11KV	
3		MULUGU	NAGIREDDYPALLI	11KV	Gajwel	14.30	16.40	02.10		DISC FAIL	
4		GANDIPALLY	RAMAVARAM EXP	11KV	Husnabad	02.24	00.00	12.00		B.D , DUE TO INSULATOR FAILED	
5		THOTAPALLY	DEVAKKAPALLY	11KV	Husnabad	02.24	09.36	07.12		B.D , DUE TO JUMPER CUT	
6		Guruvannapet	Tapaspally	11KV	Husnabad	03.36	02.24	13.12		B.D, DUE TO HEAVY RAIN	
7		Dhoolmita	Lingapur	11KV	Husnabad	12.00	12.00	00.00		B.D, DUE TO 11 KV LINE CUT INSULATOR FAILED	
8		REGULAPALLY	REGULAPALLY	11KV	Husnabad	00.00	00.00	00.00		B.D DUE TO 11 KV LINE CUT	
9		Tadakapally	Venkatapur	11KV	Siddipet	08.40	11.40	03.00		B/B 11KV Pole fallen down, LC No 10696	
10		Raghavapur	Raorukula	11KV	Siddipet	06.15	08.25	02.10		B/D - 11KV insulator fail, LC No. 11822	
11		Raghavapur	Raorukula	11KV	Siddipet	09.02	14.05	05.03		B/D - Tree Branches fallen on the line, LC No. 11823	
12		Raghavapur	Raghavapur	11KV	Siddipet	08.50	11.45	02.55		B/D - 11KV insulator fail, LC No. 11824	
13		Dharmajipet	Lachapet	11KV	Siddipet	09.25	17.32	08.07		B/D - Jumper cut, LC No. 3446	
14		Peddachepyal	Alwal	11KV	Siddipet	14.50	15.35	00.45		B/D - 11KV wire cut, LC No. 37366	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Kothaguda	Aparna	11KV	Kondapur	09.50	11.38	01.48		11kv Pin insulators failed near Sri kany hotel at Aparna	-
2		Gachibowli	Gouthami Society	11KV	Kondapur	10.05	12.30	02.25		11kv Pin insulators failed near Park at Gouthami society	-
3		Khaitalapur	Janathanagar	11KV	Kondapur	12.45	14.18	01.33		11kv Disc failed Khaitalapur, single road	-
4		KPHB	Road No-5	11KV	Kondapur	11.20	12.30	01.10		11kv Disc failed at MIG-366, Breaker out going jumper cut in SS	-
1	RR N	Jeedimetla-III	Back Let Hylam	11KV	Jeedimetla	10.40	12.50	02.10		11kv Ab Cable Failure At Phase-V	-
2		Jeedimetla-II	Uttam Biscut	11KV	Jeedimetla	10.15	11.35	01.20		LV-I PT Limb Jumper Snapped In Sub station	-
3		Madeena Guda	Pragathi Enclave	11KV	Kukatpally	06.19	07.22	01.03		11kv AB Cable Failure At pragathinagar	
4		Madeena Guda	Bk Enclave	11KV	Kukatpally	10.30	12.10	01.40		11kv Pin Insultor Failure At Sai Ranga theatre	
5		Somashila	RP Colony	11KV	Kukatpally	10.05	12.20	02.15		11kv Endy Kit failure At pragathinagar	
6		Somashila	Madhavaram nagar	11KV	Kukatpally	10.50	11.55	01.05		Due To Heavy Rain	
7		Mayurinagar	Ram NareshaNagar	11KV	Kukatpally	10.35	11.50	01.15		11kv AB Cable Failure At Nizampet	
8		UMCC	Mahadevpuram	11KV	Medchal	10.10	10.55	00.45		11KV Pin Insulator Failed at Sreeram Nagar	-
9		Subhash Nagar	Jairam Nagar	11KV	Medchal	05.45	08.05	02.20		11KV AB Cable end kit Failed at Govt School,Vennalagadda	-
10		Medchal	IDA Kandlakoya	11KV	Medchal	10.35	11.50	01.15		11KV Pin Insulator Failed and replaced at REVL Opp	-
11		Medchal	CMR	11KV	Medchal	13.20	14.20	01.00		11KV Disc failed at CMR College	-
12		Medicity	Munirabad	11KV	Medchal	10.27	11.30	01.03		11KV Lightening Arrester failed and replaced at Reliance Company,Pudur	-
1	RR E	Chengicherla	Chengicherla	11KV	Keesara	15.30	16.10	00.40		HT/LT line twisted at Venkat Sai Nagar	-
1	HYD N	H.M.T	Sri Sai Colony	11KV	VI	03.35	05.30	01.55	EL,OL	No Visible Fault	Arranged B/F on 11KV Indo Swing feeder
2		Chinna Thokatta	Old Bowenpally	11KV	VI	09.46	11.22	01.36	EL,OL-Yph	Breaker problem at SS	Arranged B/F on 11KV Seetharama Puram fdr
3		Marredpally	A.O.C	11KV	C-VI	10.05	12.05	02.00	All Indication	Breaker problem at SS	Arranged B/F on 11KV Officers Colony fdr
4	HYD S	C.R.P.F	Baba Nagar	11KV	III	13.05	14.20	01.15	EL	AB Cable fault at Baba Nagar	Arranged B/F on 11KV C-Block feeder
5	HYD C	Langerhouse	Pensionpura	11KV	VII	13.45	15.50	02.05	EL	Foreign material fallen on lines at Edgah Garden	(At 15:28Hrs partial B/F arranged on 11KV Company Bagh fdr)