

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		9		9		9			
8	Hyd	194	1044		15		15		15			
	Total	606	3055	0	34	0	34	0	34	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		8		8		8			
3	MDK	107	933	2	3	2	3	2	3			
4	SDPT			1	8	1	8	1	8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	22	4	22	4	22	0	0	
	Grand Total	1082	6468	4	56	4	56	4	56	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.10.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijinepally	33KV	Nagarkurnool	14.58	19.25	04.27	EL	Conductor snapped at Nallavagu		No
1	MDK	Zaheerabad	Mannapur	33KV	Zaheerabad	14.25	16.15	01.50		BD due to Tree branches fallen on the line		-
2		Bollaram	Bollaram - III	33KV	Patancheru	17.20	21.30	04.10		BD due to Conductor snapped		-
1	SDPT	Habsipur	Pothareddypet	33KV	Siddipet	17.05	18.10	01.05		Due to spark Hct		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 12.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	KONDAPUR	CHANDAPUR	11KV	Narayanapet	14.10	16.45	02.35		DUE TO HEAVY WIND AND GALE, DISC FAILURE, CHANDAPUR VILLAGE	-
2		Kothamolagara	L & T	11KV	Jadcherla	12.35	13.40	01.05		11 KV insulater Fail near Thirmalaya pally gate.	-
3		Pollepally	Udandapur	11KV	Jadcherla	01.43	06.20	04.37		11KV Jumper Cut	-
1	NLG	Pamanagundla	Pittampally	11KV	Nalgonda	12.10	14.30	02.20	E/L	11KV Insulator failed	-
2		Chitriyala	Chitriyala	11KV	Devarakonda	10.00	13.00	03.00	E/L	11KV Line Cutt	-
3		Nampally	Vadepally	11KV	Devarakonda	07.40	08.45	01.05	E/L	11KV Insulator failed	-
4		D.Nagaram	Wardhamanu kota	11KV	Suryapet	02.40	07.30	04.50	E/L	11kv Insulator failed	-
5		Garidepally	Ponugodu	11KV	Huzurnagar	01.30	03.20	01.50	E/L	11kv Line snapped	-
6		Palakeedu	Janpahad	11KV	Huzurnagar	12.40	14.30	01.50	E/L	11kv Line snapped	-
7		Maryala	Chowderpally	11KV	Bhongir	06.00	07.50	01.50	EL/OL	11 kv Pin Insulator failed at Rangareddy well near Chowderpally (V)	-
8		D.Nagaram	Pipalpahad 24	11KV	Choutuppal	08.55	11.55	03.00	EL/OL	11kv Line snapped near Peepalphad (V)	-
1	MDK	Aroor	Express	11KV	Sangareddy	17.25	19.20	01.55		BD due to Jumper cut	-
2		Patancheru Town	MIA-II	11KV	Patancheru	12.45	13.55	01.10		BD Conductor snapped	-
3		Gundla Machnoor	Industrial	11KV	Jogipet	16.30	18.30	02.00		BD Conductor snapped	-
1	SDPT	Jagadevpur SS	Jagadevpur AGL Feeder LC:6471 (Kumar LM)	11KV	Gajwel	12.20	13.50	01.30		disk Fail	-
2		Karkapatla SS	Jodas Feeder LC:620 (Hanumanthu LM)	11KV	Gajwel	19.25	21.36	02.16		Insulater Fail	-
3		Gowararam Ss	Gowraram Town I	11KV	Gajwel	11.00	05.30	06.30		Tree Branch Fallen	-
4		Mulugu SS	Bailampur feeder LC:27252 (Rajesham LM)	11KV	Gajwel	00.00	09.30	09.30		Insulater Fail	-
5		GURUVANAPET	TAPASPALLY	11KV	Husnabad	00.00	04.35	04.35		TREE FALLEN ON CONDUCTOR	-
6		GURUVANAPET	POSANPALLY	11KV	Husnabad	00.00	04.35	04.35		TREE FALLEN ON CONDUCTOR	-
7		GANDIPALLY	RAMAVARAM XPRESS	11KV	Husnabad	00.00	07.00	07.00		TREEFALLEN ON CONCUTOR	-
8		HUSNABAD	MADATHA	11KV	Husnabad	06.00	07.45	01.45		INSULATOR FAILURE	-
1	RR S	Nallagandla	Jawahar Navodaya	11KV	Gachibowli	16.00	17.20	01.20		11kv Pin-insulator failed and LT cable snapped at Aparna Sarovar Opposite, Nallagandla	-
2		Madinaguda	Hafeezpet	11KV	Gachibowli	15.05	16.15	01.10		Due to heavy rain, 3 No's HG fuses faield at Reliance digital	-
3		Kaithalapur	New 4th Phase	11KV	Kondapur	16.05	17.50	01.45		Tree fallen on 11kv line at New 4th phase church	-
1	RR N	Madinaguda	HMT	11KV	Kukatpally	15.03	17.30	02.27	EL	11kv Pin Insulater failed at Krushinagar	-
2		Madinaguda	FCI Colony	11KV	Kukatpally	15.10	16.50	01.40	EL	11kv AB Cable failed at Takey Town,Miyapur	-
3		Madinaguda	Shanthinagar	11KV	Kukatpally	15.06	17.30	02.24	EL	11kv Pin Insulater failed at Dolphin Apt,DeepthiSrinagar	-
4		Miyapur X Road	ASR Stach	11KV	Kukatpally	15.39	17.11	01.32	EL	11kv Disk Failed at plot:125, Pragathinagar	-
5		Chandanagar	Shankarnagar	11KV	Kukatpally	15.40	17.45	02.05	EL	11kv AB Cable failed at Shankarnagar	-
6		Jeedimetla-II	Apuroopa Colony	11KV	Jeedimetla	18.55	20.20	01.25	EL/OL	Tree branchesh fallen the 11kv line at Durga Apt,Durga Colony	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
7		Medicity	Munirabad	11KV	Medchal	20.20	21.20	01.00	EL	Tree Branch fallen on the 11KV Line at Law Collage Back side	-
1	RR E	Uppal	RTA	11KV	Habsiguda	15.05	16.05	01.00		Tree branches fallen on 11KV line at Survey Colony	-
2		Sainikpuri	Vijayapuri	11KV	Sainikpuri	11.18	12.33	01.15		11Kv Pin Insulator failed at Sainikpuri (LM Anil)	-
3		Moula ali	Spectra	11KV	Sainikpuri	12.02	14.53	02.51		11Kv line AB Switch Disk failed at IDA Moula ali (LM Venkatesh)	-
4		Kushaiguda	Neredmet	11KV	Sainikpuri	14.30	15.45	01.15		Tree branches fallen on 11Kv line near Good Luck café (AE)	-
5		RGK	RGK	11KV	Sainikpuri	19.30	20.30	01.00		11Kv Polymer Disk failed at Bharath Nagar (Artisian Raju)	-
6		Chengicherla	My Villas	11KV	Keesara	12.05	12.45	00.40		Line patrolling but no visible fault due to heavy rain	-
7		Chengicherla	My Villas	11KV	Keesara	14.30	16.10	01.40		11KV HG Fuse Insulator failed at Ramakrishna Nagar	-
8		Narapally	Prathap Singaram	11KV	Keesara	16.10	16.50	00.40		11KV Disc failed at Korremula	-
9		Narapally	AP Meat	11KV	Keesara	17.10	17.50	00.40		11Kv Insulator failed at Divya Nagar	-
1	HYD N	R.P Nilayam	Saraswathi Nagar	11KV	C-VI	11.25	12.27	01.02	EL,OL-R&Bph	Cable fault at Life Line Hospital	-----
2		Addagutta	Ambedkar Nagar	11KV	C-VI	14.30	16.30	02.00	EL	Cable fault	Arranged B/F on 11KV Polytechnic fdr
3		Pragatools	Eshwar Vimal	11KV	VI	14.58	16.00	01.02	EL	HG fuse burntout at Eshwar Vimal	-----
4		Gymkhana	Apollo	11KV	C-VI	15.05	16.20	01.15	EL	Tree branches fallen on lines at Navajeevan Hospital & O/G Jumper cut at SS	-----
5		MLA Colony	V.L.C.C.	11KV	X	15.23	17.40	02.17	All Indication	Tree branches fallen on lines at V6 News Channel, HG fuse B/O at Omega Hospital & Disc Insulator flash over at Opp. D.Srinivasa's House	-----
6		Macha Bollaram	Madhura Enclave	11KV	C-VI	16.00	17.25	01.25	OL	Tree branches fallen on lines at Govt. Hospital, Old Alwal	-----
7		H.A.L.	Indian Rubber	11KV	VI	16.27	17.42	01.15	EL,OL-Yph	O/G Jumper cut at SS, CT PT failed at Plot No.40&42 & CT PT failed at M.C.Building	-----
8		Marredpally	Military Hospital	11KV	C-VI	16.35	18.35	02.00	EL	Big tree fallen on lines at Military Hospital	-----
9		Addagutta	Polytechnic	11KV	C-VI	17.50	20.30	02.40	EL	Faulty loads of 11KV Ambedkar Nagar fdr	-----
10		Nehru Nagar	LIC Colony	11KV	C-VI	19.05	20.26	01.21	EL,OL-R&Bph	Tree branches fallen on lines at Krishna Kuteer Apts & Jumper cut at Post Office	-----
11		New Bowenpally	Raju Colony	11KV	VI	19.05	20.15	01.10	EL	5No. DTR's fault at Durga Matha Temple, due to tree branches fallen on Lines	-----
12		N.I.M.S	Andhra Jyothi	11KV	X	19.50	21.45	01.55	EL	I/C Cable fault at Grave Yard	Arranged B/F on 11KV Nagarjuna Hills feeder
13		Osm. University	Ladies Hostel	11KV	V	21.05	23.30	02.25	All Indication	Tree branches fallen on lines near SS	Arranged B/F on 11KV Ravindra Nagar feeder
1	HYD C	Amberpet	C.P.L.	11KV	II	16.38	18.16	01.38	EL	Tree branches fallen on lines at CPL Ground	-
2		Golconda	Narayanamma College	11KV	VII	20.30	21.35	01.05	EL,OL	UG Cable fault at Sandhya Hotel (3No. DTR's Kept Off)	-