

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550	3	15	3	15	3	15			
7	RR(E)	168	403		13		13		13			
8	Hyd	194	1044		19		19		19			
	Total	606	3055	3	49	3	49	3	49	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		10		10		10			
3	MDK	107	933	4	1	4	1	4	1			
4	SDPT				13		13		13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	26	5	26	5	26	0	0	
	Grand Total	1082	6468	8	75	8	75	8	75	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.10.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Devarkadra	33kv	Narayanpet	06.40	07.30	00.50	E/L	Due to Rain AB Switch Open at Bandrvelly SS	Devarkadra	-
1	Sangareddy	Sadashivapet	Jogipet	33kv	Sangareddy	01.05	03.30	02.25		BD due to Insulator failed	Jogipet	-
2		Sadashivapet	Manjeera	33kv	Sangareddy	00.00	10.15	10.15		Bd due to Tree fallen on line	Manjeera	-
3		Bollaram	Meenakshi	33kv	Patancheru	16.10	18.30	02.20		BD due to Insulator failed	Meenakshi	-
1	Medak	Ramayampet	33KV KONAPUR	33kv	Toopran	02.37	08.05	05.28		BD due to Insulator failed	33KV KONAPUR	-
1	RR N	132KV Medchal	33KV Aliabad	33kv	Medchal	11.20	13.35	02.15	EL/OL	Tree Branches fallen on the 33KV Line at Forest Area	33KV Aliabad	-
2		132KV Malkaram	33KV Ratnalayam	33kv	Medchal	11.28	15.30	04.02	EL/OL	Earthing Wire Cut & Replaced in SS	33KV Ratnalayam	-
3		132KV Malkaram	33KV Shameerpet	33kv	Medchal	11.28	15.30	04.02	EL	Earthing Wire Cut & Replaced in SS	33KV Shameerpet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 15.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bijwar	Pulimamidi	11kv	Narayanpet	14.24	14.45	00.21		Due to 11KV Disc faiere at Pulimamdi	-
2		Udithyal	Macharam	11kv	Jadcherla	01.00	06.10	05.10		Tree Fallen on 11 KV line near suraram	-
1	NLG	Pamanagundla	Yerrasanigudem	11kv	Nalgonda	10.35	13.20	02.45	EL	Tree Fallen on the 11 KV Line	-
2		Velgupally	G.K.Annaram	11kv	Nalgonda	20.40	10.20	13.40	EL	11 KV Jumper Cut	-
3		Madgulapally	Dacharam	11kv	Nalgonda	20.30	11.20	14.50	EL	Tree Fallen on the 11 KV Line	-
4		Pendlipakala	Chinthakuntla	11kv	Devarakonda	14.00	16.30	02.30	EL	11 Kv Jumper Cutt	
5		Yerkaram	Das thanda	11kv	Suryapet	06.00	08.30	02.30	E/L	Insulator failed	
6		Ravulapally	Kukkadam	11kv	Suryapet	08.50	10.20	01.30	E/L	Disc failed	
7		Mellacheruvu	Hemlathanda	11kv	Huzumagar	02.25	07.00	04.35	EL	11 kv inslater failed	
8		Keethavarigudem	Sarvaram	11kv	Huzurnagar	08.00	10.30	02.30	EL	11 KV JUMPER CUT	
9		Bollepally	Jampally	11kv	Bhongir	13.25	15.30	02.05	EL/OL	11kv Line snapped & 11kv Insulator Failed near RN Thanda Buchhubavi	-
10		Arror	Gurnathpally	11kv	Choutuppall	00.00	10.00	10.00	EL/OL	11 kv Insulator failed near Gangapur village. 3 Phase supply ok	-
1	Medak	33/11 KV Pathur SS	11 KV Shamnapur Feeder	11kv	Medak	01.25	06.06	04.41		Due to 11KV insulator failed	
1	SDPT	Ramancha	Ramancha	11kv	Siddipet	02.00	11.00	09.00		B/D Disck failed	
2		BV Pur	BV pur Feeder LC.No.9159	11kv	Gajwel	15.50	16.50	01.00		Tree has fallen	
3		Gajwel	BV pur Feeder LC.No.	11kv	Gajwel	14.30	16.40	02.10		Disk fail	
4		Erravelly SS	Lifterigation and poleice station LC.No.25615	11kv	Gajwel	12.45	13.10	00.25		Disk fail	
5		Gowraram SS	Gowraram AGL Feeder LC.NO.	11kv	Gajwel	00.00	13.00	13.00		Tree has fallen	
6		Gowraram SS	Pathre Feeder LC.No	11kv	Gajwel	00.00	19.50	19.50		Tree has fallen	
7		Gowraram SS	Gowraram Town -I	11kv	Gajwel	03.00	11.20	08.20		11kv line cut	
8		Gowraram SS	Gowraram Town -II	11kv	Gajwel	03.00	09.30	06.30		Janaki feeds company near tree was fallen	
9		Gowraram SS	Pamulaparthi Feeder	11kv	Gajwel	00.00	11.20	11.20		Tree brances has fallen	
10		Raipole SS	Raipole AGL LC.No.6530	11kv	Gajwel	08.45	09.30	00.40		Jumper cut	
11		Anjipur SS	Manthure Feeder LC.No.6621	11kv	Gajwel	08.00	11.40	03.30		Tree has fallen by 11KV Line	
12		Chityal	Chityal Agl	11kv	Husanabad	12.45	14.40	01.55		Line snapped, same rectified	
13		Maddur	Ladnoor Agl	11kv	Husanabad	07.30	09.20	01.50		Insulator failure, same rectified	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Rajendra Nagar	ICAR	Naram	11kv	Rajendra Nagar	15.00	16.15	01.15	EL	11KV Disc failed at Naram	-
2	Saroomnagar	Auto nagar	Mansoorabad	11kv	Saroomnagar	11.57	13.40	01.43	EL/OL	Tree fault at Auto nagar Parking yard	-
1	RR N	Prashanthi Hills	Prashathi Hills	11kv	Kukatpally	00.01	02.30	02.29	EL	11kv Pin insulator Failure At Srila apt	-
2		Jeedimetla-II	Excell	11kv	Jeedimetla	12.01	14.00	01.59	EL	Tree Branches Fallen On The 11kv Line At At andhra polymer Company	-
3		Jeedimetla-II	Uttam Biscut	11kv	Jeedimetla	07.48	11.15	03.27	EL	CT BT Failure & 11kv jumper Cut Touched Channel At Rp techno	-
4		Jeedimetla-III	VinayakaNagar	11kv	Jeedimetla	11.19	14.00	02.41	EL	11kv Jumper Cut At Vinaya Company	-
5		Kompally	Dholari Dhani	11kv	Medchal	15.55	16.48	00.53	EL/OL	11KV Pole damaged at Highway 44	-
6		Yellampet	IDA Yellampet	11kv	Medchal	08.30	11.10	02.40	EL	Tree Branches fallen on the 11KV Line at Sangam Company	-
7		ICICI	ICICI	11kv	Medchal	02.10	08.10	06.00	EL	No Fault	-
8		ICICI	SP-I	11kv	Medchal	10.02	14.10	04.08	EL	CT PT Problem in Iftal Company(Line AB Switch Opened)	-
9		Gowdavelly	IDA Gowdavelly	11kv	Medchal	01.30	03.30	02.00	EL	Tree Fallen on 11KV Line at Ayodhaya	-
10		ICICI	Bharath Bio Tech	11kv	Medchal	09.35	10.35	01.00	EL/OL	11KV Line Phase to Phase at Genotech Company	-
11		Kandlakoya	KV Reddy Nagar	11kv	Medchal	00.35	10.10	09.35	EL	Tree Branch touched on the 11KV Line at Kompally Bridge	-
12		Aliabad	Gubba	11kv	Medchal	02.25	03.50	01.25	EL/OL	Tree fallen on the 11KV Line at Petrol Pump	-
13		Devarayamjal	Kottapet	11kv	Medchal	05.30	06.44	01.14	EL	Bird fallen on the 11KV Line at Radhika Garden	-
14		Gowdavelly	Basaragadi	11kv	Medchal	12.20	15.10	02.50	EL/OL	11KV Pin Insulator failed at Gnanapur Village	-
15		GP Pally	Malla Reddy	11kv	Medchal	14.35	14.50	00.15	EL	Tree Branches fallen on the at Mallareddy Collage	-
1	RR E	Nacharam	Nagarjuna	11kv	Habsiguda	01.00	02.00	01.00		11KV Breaker fault & Smoke came from brekaer & Back feeding supply taken from 11KV Mukthametal Feeder	-
2		Nacharam	Innogent	11kv	Habsiguda	23.06	01.50	02.44		Line Patrolling but no visible fault & 11KV Line AB Switch opened near Sona Traders	
3		Mallapur	Sai Nagar	11kv	Habsiguda	00.00	01.20	01.20		11KV Disc failed at Mithal Company	
4		Uppal	GKSR	11kv	Habsiguda	14.30	15.20	00.50		Cloth fallen on T/F at Bharath nagar	
5		VP Nagar	KK Nagar	11kv	Habsiguda	23.28	01.42	02.14		11Kv Pin Insulator failed at KK Nagar (Artisian Karunkar)	
6		Cherlapally-II	Jannuram	11kv	Habsiguda	23.32	00.38	01.06		Ground Patrolling Done But no fault found Due to Heavy Rain	
7		Cherlapally-III	Gail	11kv	Habsiguda	09.20	11.34	02.14		11Kv line Toched to Kasaram at Gandhi Nagar Colony (L Insp Koteswar Rao)	
8		Singapur	Singapur	11kv	Habsiguda	00.30	06.40	06.10		Tree branches line A 35 block	
9		Narapally	Narapally	11kv	Habsiguda	08.10	10.25	02.15		Tree branchLorry dashed at main road & jumper cut	
10		P&T colony	Chengicherla	11kv	Habsiguda	08.20	09.20	01.00		Insulaotr fail at Sampoorna opp	
11		Mallapur-1	Sai nagar	11kv	HABSIGUDA	00.00	01.20	01.20	EL/OL	Disc failed at Vittal nagar	
12		Nacharam	Nagarjuna	11kv	HABSIGUDA	01.00	02.05	01.05	NO indication	Breaker problem	11KV Muktha metals
13		Cherlapally-3	GAIL	11kv	SAINIKPURI	09.20	11.34	02.14	EL	Cross arm touched to 11KV line at Gandhi nagar colony	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Prashasan Nagar	B.N.R Hills	11kv	X	02.30	03.56	01.26	EL,OL-Rph	Tree branches fallen on lines at DMR Hills	-----
2		Thirumalgiri	Kiran Talkies	11kv	C-VI	05.10	08.00	02.50	EL	Tree branches fallen on lines at Penta Reddy Colony	-----
3		H.A.L	A.O.L	11kv	VI	06.35	08.10	01.35	EL,OL	Bird fault at IDPL	-----
4		Prashanth Nagar	Ganesh Kanta	11kv	VI	12.05	14.30	02.25	EL,OL	CT PT failed at Rajiv Gandhi Nagar	-----
5		Road No.22	M.C.R	11kv	X	13.40	15.05	01.25	All Indication	R.M.U fault at M.C.R Institute	-----
6		Kundanbagh	Methodist Colony	11kv	IV	15.47	17.18	01.31	EL,OL-R&Bph	3No. HT Jumpers cut at K.C Apts, Railway Track & Ashramam	-----
7		Muffakamja College	Venkateshwara Hills	11kv	X	21.40	22.56	01.16	EL	CT PT failed at Bondalagadda	Arranged B/F on 11KV Nagarjuna Hills fdr
1	HYD S	Yakuthpura	Moulaka Chilla	11kv	VIII	06.14	08.18	02.04	EL	No Visible Fault	Arranged B/F on 11KV Bhavani Nagar fdr
2		Asmangadh	Asmangadh	11kv	VIII	10.43	13.58	03.15	EL	Conductor snapped at 1st Line AB Switch	-----
3		Salarjung	Yakuthpura	11kv	VIII	16.10	17.30	01.20	All Indication	HT Line snapped at Prince Hotel	-----
1	HYD C	Gudimalkapur	Sri Ram Nagar	11kv	VII	00.25	02.30	02.05	EL	Pin Insulator flash over at M.P.Garden	-----
2		Fever Hospital	BKP Bus Depot	11kv	II	00.30	05.00	04.30	EL	Tree branches fallen on lines	-----
3		Exhibition	APPSC	11kv	I	02.40	04.05	01.25	EL	Pin Insulator flash over at APPSC	-----
4		A.C.Guards	Bazarghat	11kv	VII	09.41	10.48	01.07	EL	Faulty loads of 11KV Nilofer fdr	-----
5		Gudimalkapur	Sri Ram Nagar	11kv	VII	10.05	11.30	01.25	EL,OL	Disc Insulator flash over at Narayana School	-----
6		Toli Chowki	B.S.N.L	11kv	VII	11.00	12.20	01.20	EL	Cable fault at Yousufin Apts	-----
7		Asif Nagar	Military	11kv	VII	15.54	17.36	01.42	EL,OL-Rph	Tree branches fallen on lines at Military Area	-----
8		Gudimalkapur	Sri Ram Nagar	11kv	VII	15.58	17.01	01.03	EL,OL	Disc Insulator flash over at M.P Garden	-----
9		Fever Hospital	C.C.S.Hospital	11kv	II	21.45	01.35	03.50	EL	Cable fault at RTC Bus Stop (1No. DTR kept off)	(At 23:25Hrs partial fdr charged)