

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		56		56		55		1	1 No. 11KV Still pending
	Total	606	3055	0	56	0	56	0	55	0	1	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114		3		3		3			
7	RR(E)	22	133		14		14		14			
	Total	476	3413	3	31	3	31	3	31	0	0	
	Grand Total	1082	6468	3	87	3	87	3	86	0	1	

TSSPDCL - LMRC / Corporate office

Date: 17.10.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	SLC Mills	33KV	Rajendernagar	08.30	11.45	03.15	E/L	Monkey Fallen on the line	SLC Mills	No
2		Amangal	SLC Mills	33KV	Rajendernagar	21.05	02.10	05.05	E/L	Poles fallen on the SLC Mill Line	SLC Mills	No
1	MDK	Sadasivpet	Manjeera	33KV	Sangareddy	04.30	11.10	06.40		Poles fallen on the SLC Mill Line	Manjeera	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Muffakamza College	Meridian	11KV	X	02.24	03.55	01.31	EL,OL	Pin Insulator flash over at Zahira Nagar	No
2		Macha Bollarum	Father Balaiah Nagar	11KV	C-VI	7:35	8:52	1:17	EL	Line AB Switch Jumper cut at Macha Bollarum	No
3		Clock Tower	Railway Reservation	11KV	V	8:25	9:45	1:20	EL,OL-Rph	HT Jumper cut at Red Cross	No
4		Yellareddyguda	Jaya Prakash Nagar	11KV	V	18:15	19:50	1:35	EL	Pin Insulator flash over at Pasfic Apartment	No
5		Nehru Nagar	L.I.C Colony	11KV	C-VI	18:00	19:32	1:32	EL	No Visible Fault (due to Rain)	Partial fdr charged
6		Borabanda	SRT Colony	11KV	IV	18:45	20:45	2:00	EL	3No Jumpers cut at Bharath Nagar	No
7		Gymkhana	Rani Bagh	11KV	C-VI	20:40	22:10	1:30	EL	No Visible Fault (due to Rain)	No
8		Road No.12	NBT Nagar	11KV	X	20:20	22:10	1:50	EL	Kept off DTR at Lamba Lamba Apts	No
9		Gymkhana	Balamrai	11KV	C-VI	20:45	23:00	2:15	EL,OL-Rph	No Visible Fault (due to Rain)	No
10		Pragatools	Giri Nagar	11KV	VI	21:38	23:07	1:29	EL	Tree branches fallen on lines at H.B.Colony	No
11		Road No.22	Obul Reddy	11KV	X	21:05	23:02	1:57	All Indication	No Visible Fault (due to Rain)	No
12		Tirumalagiri	Mangapuram	11KV	C-VI	21:10	22:40	1:30	EL,OL	No Visible Fault (Due to Rain)	No
13		Gymkhana	Rani Bagh	11KV	C-VI	22:15	23:25	1:10	EL	No Visible Fault (Due to Rain)	No
14		Thirumalgiri	Mangapuram	11KV	C-VI	21:10	22:40	1:30	EL,OL	No Visible Fault (Due to Rain)	No
15		Yousufguda	Hylam Colony	11KV	X	21:10	23:30	2:20	All Indication	No Visible Fault (Due to Rain)	No
16		Macha Bollarum	Ayyappa Nagar	11KV	C-VI	20:58	23:40	2:42	EL	No Visible Fault (Due to Rain)	No
17		I.D.P.L	SIFCO	11KV	VI	22:10	23:50	1:40	EL	Pin Insulator flash over at Sifco Lane	No
18		Nehru Nagar	H.H.K.Bhavan	11KV	V	21:50	23:50	2:00	EL	No Visible Fault (Due to Rain)	No
19		Macha Bollarum	Krishna Nagar	11KV	C-VI	22:40	23:45	1:05	EL,OL	No Visible Fault (Due to Rain)	No
20		Macha Bollarum	Father Balaiah Nagar	11KV	C-VI	21:05	0:14	3:09	EL,OL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Kiran Talkies fdr
21		Begumpet	H.P.S	11KV	IV	20:17	0:20	4:03	EL	Trees fallen on lines at Gree Park Hotel, Divys Shakthi Apts	Arranged B/F on 11KV Green Park Hotel fdr
22		Srinagar Colony	Satya Sai	11KV	X	21:30	1:10	3:40	EL	Disc Insulator flash over HP Gas Godown	No
23		N.I.M.S	Tata Rao	11KV	X	21:50	0:46	2:56	EL,OL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Banjara Hills fdr
24		Bhudevi Nagar	Ram Raj Nagar	11KV	VI	22:50	0:55	2:05	EL,OL	Tree branches fallen on lines at Water Tank	No
25		Clock Tower	Minarva	11KV	V	21:28	2:05	4:37	EL	No Visible Fault (due to Rain)	Arranged B/F on 11KV S.D.Road fdr
26		K.I.M.S	D.V.Colony	11KV	V	21:10	7:59	10:49	EL,OL-Yph	Tree fallen on lines	No
27		K.I.M.S	Bharani Complex	11KV	V	21:11			All Indication	Water logged	No
1	HYD S	C.R.P.F	Omar Colony	11KV	III	07.40	08.47	01.07	EL,OL-Bph	I/C Cable fault	Arranged B/F on 11KV Anwar Mirchi feeder
2		C.R.P.F	Balapur	11KV	III	17:23	19:30	2:07	EL,OL	No Visible Fault (due to Rain)	No
3		C.R.P.F	Salala	11KV	III	17:05	19:05	2:00	EL,OL-Bph	No Visible Fault (due to Rain)	No
4		Kandikalgate	Rakshapuram	11KV	III	17:30	18:50	1:20	EL,OL-R&Bph	No Visible Fault (due to Rain)	No
5		Chanchalguda	Guddi Bowli	11KV	VIII	21:20	23:55	2:35	EL	Removed faulty loads of 11KV Islamiya fdr	No
6		Moosaram Bagh	Moosaram Bagh	11KV	VIII	21:30	23:05	1:35	EL,OL	No Visible Fault (Due to Rain)	No
7		Chanchalguda	Islamiya	11KV	VIII	21.20	00.40	03.20	OL-Rph	No Visible Fault (Due to Rain)	No