

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		10		10		10			
8	Hyd	194	1044		9		9		9			
	Total	606	3055	0	26	0	26	0	26	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	10	0	10	0	10	0	0	
	Grand Total	1082	6468	0	36	0	36	0	36	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 18.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Boothpur	Amistapur	11KV	Jadcherla	00.00	07.10	07.10		11 KV insulater fail near Amistapur (v)	-
2		Balanagar	Neralapally	11KV	Jadcherla	10.20	12.35	02.15		11 KV wire cut near vayal kunta thanda.	-
1	NLG	Pamangundla	Pittampally	11KV	Nalgonda	06.20	07.35	01.15	EL	Insulator failed	-
2		Turkapally	Turkapally	11KV	Nalgonda	08.00	09.00	01.00	EL	Jumper cut	-
3		Thummadam	Narammagudem	11KV	Miryalaguda	06.15	10.00	03.45	EL	Tree branchs failed on line near village	-
4		IDA	Singanagudem	11KV	Bhongir	02.00	07.40	05.40	EL	11kv Insulator Failed near Singannagudem near	-
5		Anantaharam	Anantaharam	11KV	Bhongir	00.00	03.25	03.25	EL	11 KV Disc failed near moodampally village	-
6		Bollepally	Jampally	11KV	Bhongir	09.00	11.15	02.15	EL	11 kv Line snapped near SS	-
7		Mandollagudem	Peddakondur	11KV	Choutuppall	00.00	08.56	08.56	EL	100 kva DTR failed near theriila village	-
8		Malkapur	Malakpur Agl	11KV	Choutuppall	07.30	11.15	03.45	EL	11 kv Disc failed near Booralagudem	-
1	RR S	CBIT	Gandipet	11KV	IBRAHIMBAGH	00.45	02.03	01.18	EL	11KV Insulator Failed at Signature Villa	-
2		IIIT	APHB colony	11KV	GACHIBOWLI	07.30	09.00	01.30	EL/OL	11KV Disc failed at DLF 3rd gate	-
3		Lodha	Belleza	11KV	KONDAPUR	08.30	13.55	05.25	EL/OL	Breaker internal fault	-
1	RR N	Suraram	Sriramnagar	11KV	Jeedimetla	16.35	19.35	03.00	EL	11kv line AB Cable failed at Diksha School, Sriramnagar	-
2		Jeedimetla-III	Vinayaka Nagar	11KV	Jeedimetla	08.05	10.40	02.35	EL	11kv line AB Cable failed at Jappala Basthi, Vinayaka nagar	-
3		Gowdavelly	IDA Gowdavelly	11KV	Medchal	01.00	07.30	06.30	EL/OL	11KV Pin Insulator failed & Tree fallen on the 11KV Line at Gowdavelly X Road	-
4		Laxmapur	Narayanapur	11KV	Medchal	14.50	16.10	01.20	EL	11KV Pin Insulator failed at Laxmaiah Bhavi, Narayanpur Village	-
1	RR E	Polytechnic	Sri nagar	11KV	Habsiguda	04.31	06.30	01.59		Line petroling done cable falt & gien back feeding to Kamakshipuram feeder	-
2		Polytechnic	Srinivasapuram	11KV	Habsiguda	04.42	07.10	02.28		Line petroling done cable falt & gien back feeding to Ram reddy nagar , Ln nagar	-
3		IDAuppall	Metro	11KV	Habsiguda	11.40	13.20	01.40		11KVline Snnaped & Tree fallen on 11kvline RN Fillter	-
4		Aushapur	Aushapur	11KV	Keesara	22.30	09.50	11.20		Disk fail at Aushapur Village	-
5		Aushapur	Chandupatla	11KV	Keesara	08.40	10.30	01.50		Disk fail at Chandupatla Village	-
6		Aushapur	Madharam	11KV	Keesara	10.00	12.30	02.30		11KV line Snapped at Mallapur Village	-
7		Aushapur	Chandupatla	11KV	Keesara	11.00	12.30	01.30		11KV line Snapped at Edulabad road	-
8		Peerzathiguda	Chenna reddy	11KV	Keesara	21.38	12.38	15.02		11KV pole broken at deecancloth back side	-
9		Balaji nagar	Santosh nagar	11KV	Keesara	08.20	09.16	00.56		insulator fail at Santosh nagar	-
10		Singapur	RGK	11KV	Keesara	01.30	04.15	02.45		Tree fallen on 11KV at RGK main road	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Nehru Nagar	Hari Hara Kala Bhavan	11KV	V	00.25	10.00	09.35	EL	I/C Cable fault at Picket X-Road	Arranged B/F on 11KV Picket feeder
2		Gunrock	Subash Nagar	11KV	C-VI	01.30	03.10	01.40	EL	No Visible Fault (Due to Rain)	-----
3		I.D.P.L	SIFCO	11KV	VI	03.00	04.20	01.20	EL,OL-Rph	Conductor snapped at Eko Company	-----
4		MLA Colony	V.L.C.C.	11KV	X	12.50	15.14	02.24	EL,OL-Rph	Tree fallen on Lines at Central Bank Galli	Arranged B/F on 11KV Shopping Complex fdr
1	HYD S	Miralam	Jahanuma	11KV	III	08.30	09.50	01.20	EL,OL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Mustafa Ngr fdr
2		Chanchalguda	Islamiya	11KV	VIII	21.03	22.40	01.37	OL-Rph	DTR fault at Bridge	Arranged B/F on 11KV Guddi Bowli fdr
1	HYD C	Hussain Sagar	A.G Mint	11KV	I	04.50	06.20	01.30	EL	Cable fault	Arranged B/F on 11KV Mint Compound fdr
2		Industrial Area	Azamabad I.E	11KV	II	07.35	10.15	02.40	EL	Pin Insulator flash over V.S.T Bus Stop	-----
3		Golconda	O.U Colony	11KV	VII	08.10	11.05	02.55	EL,OL-Rph	I/C Cable fault	Arranged B/F on 11KV Water Works & 11KV Darga OH feeders