

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	14	2	14	2	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.10.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Damargidda	33KV	Narayanapet	14.55	17.30	02.35	E/L	Disc Failed at 132KV Yard Cut Point	Damargidda	-
1	MDK	Sadasivpet	Jogipet	33KV	Sangareddy	17.50	19.50	02.00		B/D Due to Conductor Snapped	Jogipet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 22.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Annaram	11KV	Suryapet	07.30	09.40	02.10	E/L	Bird fallen on the line	-
2		Janpahad	Janpahad	11KV	Huzurnagar	15.00	16.30	01.30	EL	11 KV LINE SNAPPED	-
3		Chervupally	Chervupally-1	11KV	Nalgonda	06.20	07.40	01.20	EL	11 KV Jumper Cut	-
4		Thurkapally	Thurkapally	11KV	Nalgonda	03.27	08.09	04.42	EL	Tree Fallen on the Line	-
5		NG.Bandal	Verrareddypally	11KV	Bhongir	11.00	12.02	01.02	EL	11kv Line Snapped near Alwalakunta	-
1	MDK	Patancheru Town	MIA-II	11KV	Patancheru	06.45	08.05	01.20		B/D Due to Conductor Snapped	-
1	RR S	Lodha	Belleza(Dedicated)	11KV	KONDAPUR	08.15	15.03	06.48	EL OL	Internal breaker problem	-
2		Chanda nagar	Chanda nagar	11KV	GACHIBOWLI	13.15	14.30	01.15	EL OL	11Kv Insulator failed at Saraswathi Vidya mandhir	-
1	RR N	Nuthankal	Bharathi Agro	11KV	Medchal	07.10	09.48	02.38	BD	Breaker VCB Problem rectified in SS	-
2		Nuthankal	Lingapur	11KV	Medchal	15.50	17.55	02.05	BD	11KV Conductor Snapped at Prasad Seeds Company	-
3		Tattiannaram	Laxmi Ganapathi	11KV	SAROORNAGAR	23.05	00.21	01.16	EL	Cable problem at Shreyas college	-
1	RR E	Cherlapally-IV	Sai Nagar	11KV	Sainikpuri	11.13	12.32	01.19		11Kv Cable Dammage at near KLR Industry (L Insp Kishor Raju) Load Add on Vasavi Shiva Nagar feeder	-
2		Vayupuri	GK Nagar	11KV	Sainikpuri	14.05	15.55	01.50		Tree Branches fall on 11kv line at Gokul Naagr Omega Hotel line (LM Srinivas) Breaker Problem Load Add on Gokul Nagar feeder (LM Srinivas)	-
1	HYD N	Road No.12	Road No.10	11KV	X	14.50	16.35	01.45	EL	Faulty 3Nos. DTRs at Road No.10	Arranged B/F on 11KV Namdhari fdr

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
------	--------	-----------------------	-------------------------	-----	-------------------------	------	----	----------	---------------------	--------------------	------------------------------

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
------	--------	-----------------------	-------------------------	-----	-------------------------	------	----	----------	---------------------	--------------------	------------------------------