

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 26.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamangundla	Yerrasanigudem	11KV	Nalgonda	12.00	13.18	01.18	E/L	11 KV Jumper Cut	-
2		Penpahad	Annaram	11KV	Suryapet	07.30	09.40	02.10	E/L	Bird fallen on the line	-
1	RR S	IIIT	APHB Colony	11KV	Gachibowli	03.12	05.30	02.18		11kv AB Cable failed near DLF 3rd Gate (Backfeeding from 11kv Jayabheri Feeder)	-
1	RR N	Jeedimetla-I	Phase-I	11KV	Jeedimetla	17.25	18.25	01.00		11kv line Jumper Cut at Hyderabad Bus Body, Phase-I	-
2		Jeedimetla-IV	Vasudha	11KV	Jeedimetla	12.30	14.00	01.30		11kv line Endkit failed at opp:Vasudha Company	-
3		Aliabad	LGM Pet	11KV	Medchal	16.20	17.00	00.40		Bird fallen on the 11KV Line at Beerappa Temple	-
1	RR E	Balaji Nagar	Sai Baba	11KV	Keesara	07.10	08.30	01.20		11KV Sai Baba feeder breaker mechanical fault & B/F from 11KV Laxmi Narsimha feeder	-
1	HYD N	Kalyan Nagar	Vengal Rao Nagar	11KV	X	17.15	18.31	01.16	OL-Bph	Internet Cable fallen on Lines at GTS Colony	-
1	HYD S	Jiyaguda	Tappa Chabutra	11KV	IX	18.05	19.40	01.35	EL	Street Light Pole fell on Line at Sabji Mandi	Partial feeder charged at 19:20Hrs & Remaining loads added on 11KV Goshala feeder
2		Malakpet	Municipal Colony	11KV	VIII	19.25	21.13	01.48	EL	Cable fault	Arranged B/F on 11KV Shanker Nagar feeder