

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	5	1	5	1	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	4	1	4	1	4	0	0	
	Grand Total	1082	6468	2	9	2	9	2	9	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 27.10.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Kothakota	33kv	Wanaparthi	20.32	22.45	02.13	E/L	Alternate Supply arranged to 132KV SS Thirmalaipally (33KV Line Problem & 33KV Jumper Cut)	Kothakota	-
1	RR N	132KV LGM Pet	33KV Aliabad	33kv	Medchal	14.30	17.25	02.55		33KV Disc Failed and Replaced at Aliabad Village	33KV Aliabad	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 27.10.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mustipally	Mustipally	11kv	Narayanapet	09.47	11.00	01.13		HT/LT wires snapped & cut	-
2		Jadcherla	Nagasala	11kv	Jadcherla	11.45	13.30	01.45		Phase to Phase near Nasurlabad	-
3		Kothamolgara	Elkicherla	11kv	Jadcherla	13.30	14.30	01.00		11KV Disk fail near Nallakunta side	-
1	NLG	Akaram	Shanthi Nagar	11kv	Nalgonda	09.00	10.10	01.10	EL	11 KV Insulator failed	-
1	RR N	Kandlakoya	Saigeetha Ashramam	11kv	Medchal	12.05	13.25	01.20		No Fault	-
2		Thurkapally	Yadaram	11kv	Medchal	11.48	13.35	01.47		11KV Line Cut & Replaced at Function Hall Backside, Thurkapally	-
1	RR E	Idauppall	Ram reddy nagar	11kv	Habsiguda	14.27	15.15	00.48		Coconut Tree branches fallen on 11 KV line due to that line snnaped at Happy Bar	-
1	HYD N	Nehru Nagar	Contonment	11kv	C-VI	08.00	10.25	02.25	EL,OL-Yph	Auto Reclosure fault at Boosareddyguda	At 09:25Hrs Partial fdr B/F arranged on 11KV West Marredpally fdr & Remaining loads added on 11KV Lalitha Nagar feeder
1	HYD C	Amberpet	Amberpet	11kv	II	15.47	17.10	01.23	EL	Pin Insulator flash over Gandhi Gally	-----