

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 30.10.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
<b>NIL</b>												

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mukundapuram	Mukundapuram	11KV	Huzurnagar	10:54	12:01	1:07	EL	11 KV Line snapped	No
2		Rajupeta	Rajupeta	11KV	Nalgonda	05.00	07.10	02.10	EL	11 KV Jumper Cut	No
3		Kethepally	Kasanagodu	11KV	Nalgonda	13.00	14.00	01.00	EL	11 KV Jumper Cut	No
4		Narsingbatla	Chennugudem	11KV	Nalgonda	14.55	15.35	00.40	EL	11 KV Jumper Cut	No
1	SDPT	Habsipur	Dharmaram	11KV	Siddipet	1:22	8:10	6:48		11 KV line wire Cut	No
2		Bekkal	Kutigal	11KV	Husnabad	00.00	12.20	12.20		DTR FAILURE (3PH BD 1-PH OK)	No
1	RR N	Jeedimetla SS II	Excell	11KV	Jeedimetla	10:40	11:30	0:50	EL	Tree branches fallen on the 11kv line	No
1	HYD N	New Bowenpally	Police Quarters	11KV	VI	17.38	19.46	02.08	EL,OL	2No. HT Lines snapped at Police Quarters	Parial feeder charged & Remaining fdr arranged B/F on 11KV Raju Colony feeder