

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		6		6		6			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	7	2	7	2	7	0	0	
	Grand Total	1082	6468	2	15	2	15	2	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.09.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narva	33KV	Narayanapet	21:30	21:55	00:25	E/L	Due to Heavy Rain	Narva	Alternate Supply Arranged from 33KV Ekaspur from 132KV Marikal 21:30Hrs.
1	MDK	Gummadidala	GPSS-2	33KV	Patancheru	15:30	17:25	1:55		Jumper cut	GPSS-2	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Mukundapuam	11KV	Suryapet	3:30	7:20	3:50	E/L	Conductor snapped	No
2		Palakeedu	Sajjapuram	11KV	Huzurnagar	04.30	07.00	02.30	E/L	11 KV LINE SNAPPED	No
3		Pedaveedu	Lothuvagu	11KV	Huzurnagar	13.20	15.20	02.00	E/L	11 KV JUMPER CUT	No
4		Rajapet	Renikunta Agl	11KV	Bhongir	02.00	07.00	05.00	E/L	11 kv Insulator failed	No
5		Choutuppal ipds	Bangarigadda	11KV	Choutuppal	5:16	6:47	1:31	E/L	11 kv Insulator failed	No
1	MDK	Inole	Peddakanjarla	11KV	Sangareddy	15:30	19:00	3:30		Conductor snapped	No
1	SDPT	Gurrallagondi	Malyala	11KV	Gajwel	11:11	11:52	0:41		AB Switch problem	No
1	RR N	Jeedimetla-1	Balaji	11KV	Jeedimetla	9:30	11:50	2:20		11kv A B Cable End kit failure	No
1	RR E	AnandBagh	P B Colony	11KV	Sainikpuri	21:10	22:28	1:18		AB Cable Problem at Simhadrinagar	No
1	HYD N	Patigadda	Budha Bhavan	11KV	V	14.55	16.35	01.40	EL	Cable fault at Dumping Yard	Arranged B/F on 11KV H.S Pump House feeder
2		Monda Market	Gandhi Nagar P.S	11KV	V	15:24	17:41	2:17	EL,OL-Bph	UG Cable fault at Dharma Kanta (MMK Apts DTR Kept Off)	Partial fdr charged at 16:20 Hrs
3		R.P Nilayam	Naga Devatha Temple	11KV	C-VI	15:50	17:00	1:10	EL	Cable fault at Naga Devatha Temple	No
1	HYD C	Mothi Mahal	Risala Bazar	11KV	VII	16.32	17.54	01.22	EL,OL-Yph	Cable fault at Kataria House	No
2		Fever Hospital	Tourist Hotel	11KV	II	08.15	13.35	05.20	EL,OL-Rph	2No DTR's Kept off at Chitrakut Apts & Public DTR due to 5 Way RMU fault	Arranged B/F on 11KV Moulana Azad Nagar feeder
3		A.S.R Raju Nagar	GHMC Park	11KV	VII	13.42	15.10	01.28	EL,OL	AB Cable fault at Jaya Nagar (1No. DTR Kept Off)	No