

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 3 | | 3 | | 3 | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | | 4 | | 4 | | 4 | | | |
| | Total | 606 | 3055 | 0 | 8 | 0 | 8 | 0 | 8 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 3 | | 3 | | 3 | | | | |
| 2 | NLG | 144 | 988 | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| 3 | MDK | 107 | 933 | 4 | 6 | 4 | 6 | 4 | 6 | | | |
| 4 | SDPT | | | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 9 | 10 | 9 | 10 | 9 | 10 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 9 | 18 | 9 | 18 | 9 | 18 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 09.09.2020

Circle-wise 33KV Breakdowns

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--------------------------------------|-----------------------|---------------------------|
| 1 | MBNR | Mahabubnagar | Hanwada | 33KV | Mahabubnagar | 18.50 | 21.30 | 02.40 | E/L | 33KV Line Fault | Hanwada | - |
| 2 | | Polepally | Gangapur | 33KV | Jadcherla | 16.07 | 18.50 | 02.43 | EL | No Visible Fault | Gangapur | - |
| 3 | | Kothur | Binju Metals | 33KV | Shadnagar | 15.28 | 16.30 | 01.02 | EL | B Phase insulator Failed at 132KV SS | Binju Metals | - |
| 1 | NLG | Madugulapally | Thadakamalla | 33KV | Miryalaguda | 05.15 | 07.30 | 02.15 | EL/OL | Jumper cut | Thadakamalla | - |
| 1 | MDK | Zaheerabad | Old Allana | 33KV | Zaheerabad | 19.00 | 20.15 | 01.15 | | BD due Tree Fallen on line | Old Allana | - |
| 2 | | Medak | Rajpally | 33KV | Medak | 11.12 | 13.12 | 02.00 | E/L | Tripped Y-Phase B/D decleared | Rajpally | |
| 3 | | Yeldurthy | Mangalparthy | 33KV | Toopran | 19.12 | 20.31 | 01.19 | E/L&O/L | Tripped R,B-Phase B/D Decleared | Mangalparthy | |
| 4 | | Manoharabad | Suguna | 33KV | Toopran | 17.05 | 23.55 | 06.50 | LC | AE/OP/Shivampet for B/D | Suguna | |
| 1 | SDPT | Hubshipur | Peddachikode | 33KV | Siddipet | 15.15 | 15.40 | 00.25 | | BD (Tree Falls on 33Kv line) | Peddachikode | - |

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 09.09.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | NLG | Velugupally | Velugupally | 11KV | Nalgonda | 08.00 | 09.55 | 01.55 | EL | Insulator Failed | - |
| 2 | | Velugupally | G.K.Annaram | 11KV | Nalgonda | 06.00 | 07.30 | 01.30 | EL | Jumper Cut | - |
| 1 | MDK | Fasalwadi | MNR | 11KV | SANGAREDDY | 04.05 | 06.55 | 02.50 | | BD Due to Jumpercut & Disk Fail | - |
| 2 | | Fasalwadi | MNR | 11KV | SANGAREDDY | 18.02 | 19.05 | 01.03 | | BD Due to Jumpercut | |
| 3 | | Patancheru Town | MIA-II | 11KV | PATANCHERU | 18.10 | 20.30 | 02.20 | | BD Due to Jumpercut | |
| 4 | | Kistareddypet | Bheeramguda | 11KV | PATANCHERU | 16.48 | 17.55 | 01.07 | | BD due to Insulator Failed | |
| 5 | | Anrich Bollaram | Kythan | 11KV | PATANCHERU | 18.10 | 21.05 | 02.55 | | BD Due to Tree Fallen on line | |
| 6 | | Toopran | Toopran | 11KV | Toopran | 17.04 | 17.40 | 00.36 | | BD(tree branch fallen online) | |
| 1 | SDPT | Narsapur | Narsapur Industrial | 11KV | SDPT | 16.35 | 16.55 | 00.20 | | BD Tree Fall on line | |
| 2 | | Jangapally | Jangapally | 11KV | SDPT | 10.50 | 15.25 | 04.35 | | B/D 11kv jumper cut | |
| 1 | RR N | Nizampet | Rajadhani school | 11KV | Kukatpally | 16.30 | 17.30 | 01.00 | EL | Due to heavy rain | - |
| 2 | | RGK Suraram | Krushi colony | 11KV | Jeedimetla | 16.35 | 17.50 | 01.15 | EL | Tree branch fallin on the 11kv line at Governament School | - |
| 3 | | Medchal | CMR | 11KV | Medchal | 19.10 | 19.55 | 00.45 | EL | 11KV Pin Insulator failed & replacement at Gangakaveri company | - |
| 1 | RR E | RGK | RGK | 11KV | Habsiguda | 18.19 | 19.50 | 01.31 | | 11KV Line cut at Adraspally | - |
| 1 | HYD N | New Bowenpally | Chandana Hospital | 11KV | VI | 16.35 | 17.48 | 01.13 | EL | LT Line snapped at Bhavana Colony | |
| 2 | | I.D.P.L. | Oblum | 11KV | VI | 18.00 | 20.10 | 02.10 | EL,OL | HT Line snapped & AB Switch Jumper cut at SVCIE, Bala Nagar | |
| 1 | HYD S | Falaknuma | Ravindra Naik Nagar | 11KV | III | 06.05 | 07.28 | 01.23 | EL,OL | Faulty loads of 11KV G.M.Chowni feeder | |
| 2 | HYD C | Langer House | Defence Colony | 11KV | VII | 16.45 | 18.50 | 02.05 | EL | Tree branches fallen on lines at Military Hospital Wall & Pin Insulator flash over at Ambedkar Nagar | |