

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044		27		27		27			
	Total	606	3055	0	38	0	38	0	38	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3	1	3	1	3			
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933	4	3	4	3	4	3			
4	SDPT			1	9	1	9	1	9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	21	7	21	7	21	0	0	
	Grand Total	1082	6468	7	59	7	59	7	59	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.09.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alwal	Water Gridd	33KV	Shadnagar	17.50	19.45	01.55	OL	Tree Fallen on the 33KV line		-
1	NLG	Aitipamula	Kethepally	33KV	Nalgonda	11.50	13.35	01.45	E/L	33Kv Jumper cut at Rayanpuram(V)		-
1	MDK	Sadasivpet	Jackwell	33KV	Sangareddy	17.40	18.50	01.10		BD due ro Jumper cut		-
2		Pashamailaram	BPL	33KV	Sangareddy	13.15	14.50	01.35		BD due to Jumper cut		-
3		Narayankhed	Sirgapur	33KV	Jogipet	13.55	15.40	01.45		BD due to Jumper cut		-
4		Narayankhed	Kalher	33KV	Jogipet	16.45	17.45	01.00		BD due to Jumper cut		-
1	SDPT	Thunkibollaram	Ksheelasagar	33KV	Gajwel	13.58	15.10	01.12		BD (Insulator Failure)		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 10.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gundumal	Ameenkuntla	11KV	Narayanapet	20.00	21.10	01.10		Due to Heavy gale and wind 11 KV Insulator Failed	-
2		Maddur	Renivetla	11KV	Narayanapet	17.20	20.50	03.30		Due to Heavy gale and wind, 11 KV Failed	-
3		Kankurthy	Kankurthy	11KV	Narayanapet	19.52	21.00	01.08		Due to 11KV Insulator Failed	-
1	NLG	Palem	Ogodu	11KV	Nalgonda	04.40	08.40	04.00	E/L	Tree fallen on 11Kv line	-
2		Nakrekal	Nomula	11KV	Nalgonda	03.05	08.40	05.35	O/L	11Kv Jumper cut	-
3		Phanigiri	Phanigiri Agl	11KV	Suryapet	07.00	08.40	01.40	E/L	11Kv Jumper cut	-
4		Maryala	Chowderpally	11KV	Bhongir	07.35	10.05	02.30	EL/OL	11kv line snapped near Chowderpally (V)	-
5		Yennaram	Suraram	11KV	Choutuppal	09.30	11.05	01.35	EL/OL	11kv Disc failed near Suraram (V)	-
6		Juloor	Kapraipally	11KV	Choutuppal	04.00	08.15	04.15	EL/OL	11kv Pin Insulator failed near Kapraipally (V)	-
1	MDK	Cheryal	Turbovent	11KV	Sangareddy	18.00	19.10	01.10		BD due to Disk failed	-
2		Cheryal	DVR	11KV	Sangareddy	07.40	09.40	02.00		BD due to Conductor snapped	-
3		EPIP-I	Gensinth	11KV	Sangareddy	16.35	17.10	00.35		BD due to Jumper cut	-
1	SDPT	Komaticheruvu	Ensanpally	11KV	Siddipet	15.35	19.00	03.25		B/D	
2		Chandhlapur	Gangapur	11KV	Siddipet	16.46	17.33	00.47		B/D	
3		GURRALASOPA	RAMARAM AGL	11KV	Gajwel	13.05	14.20	01.15		CONDUCTOR SNAPED	
4		MOBHARASPUR	MOBHARASPUR	11KV	Gajwel	10.50	12.43	01.53		CONDUCTOR SNAPED	
5		THIMMAPUR	THIMMAPUR	11KV	Gajwel	07.45	11.49	04.04		INSULATOR FAIL	
6		WARGAL	WARGAL TOWN	11KV	Gajwel	08.10	08.50	00.40		INSULATAR FAIL	
7		Akkannapet	Pakirnayak Thanda	11KV	Husnabad	15.15	18.00	02.45		Tree branch fallen on line, same rectified	
8		Ramchandrapur	Potlapally	11KV	Husnabad	14.15	15.15	01.00		Jumper cut	
9		Komuravelly	Kadavergu	11KV	Husnabad	18.10	20.10	02.00		Disc failure, same rectified	
1	RR S	Kothaguda	Universal	11KV	Gachibowli	16.05	18.40	02.35	BD	11kv End kit failure near Harsha Toyota Showroom.	-
1	RR N	HMT	Manikya Nagar	11KV	Medchal	17.30	18.40	01.10	BD	11KV PinInsulator failed at Kakathiya nagar	-
2		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	15.30	16.30	01.00	BD	11kv AB Cable failed at Near Artimes Company, Phase-V	-
3		ICICI	SP-I	11KV	Medchal	10.56	11.56	01.00	BD	Tree Branch fallen on the 11KV Line at 900 Building	-
1	RR E	Moula-Ali	Jawahar Nagar	11KV	Sainikpuri	17.20	18.23	01.03		Ground Petrolling done no Visible fount found to 75%Load Add on Moulali feeder	-
2		Vayupuri	GK Nagar	11KV	Sainikpuri	17.24	18.24	01.00		Tree branches fallen on 11Kv line at HIGA Park (LM Srinivas)	-
3		VP Nagar	Madhura Nagar	11KV	Sainikpuri	17.40	18.40	01.00		Tree branches fall on 11Kv line at BIG-C Show Roo Back side Sri Colony (Artisan/Balreddy)	-
4		Sainikpuri	Kalyan Garden	11KV	Sainikpuri	21.20	23.40	02.20		11Kv line cut at Saipuri Colony (AE/Yapral)	-
5		Kushaiguda	Kushaiguda	11KV	Sainikpuri	22.00	23.45	01.45		11Kv line Pin Insuletor fail at Kushaiguda Industry (AE/OP)	-
6		Kushaiguda	Kapra	11KV	Sainikpuri	22.00	23.00	01.00		11Kv line Disk fail at Varun Enclave (AE/OP)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
7		Ramanthapur Polytechnic	Srinivasapuram	11KV	Habsiguda	21.41	23.12	01.31		11KV Disc Failed at Yadaiah Hotel	-
1	HYD N	Clock Tower	Natraj	11KV	V	13.55	14.58	01.03	EL,OL-Bph	No Visible Fault	Arranged B/F on 11KV S.P Road fdr
2		Road No.22	UCO Bank	11KV	X	14.20	18.00	03.40	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Jubilee Hills & 11KV I.O.A fdrs
3		Film Nagar	Rama Naidu Studio	11KV	X	15.08	17.28	02.20	EL,OL	Tree branches fallen on lines & Jumper cut at Road No.16	-
4		Bowenpally	I.A.F	11KV	VI	15.10	17.00	01.50	EL,OL	Tree branches fallen on lines at IAF Quarters	-
5		Jubilee Hills	H.P Gas	11KV	X	15.12	16.50	01.38	EL,OL-Rph	Tree branches fallen on lines at H.P Gas	-
6		Jubilee Hills	Amar Co.Operative Society	11KV	X	15.12	16.20	01.08	EL,OL-Rph	No Visible Fault	-
7		Toli Chowki	Road No.86	11KV	X	15.20	16.42	01.22	EL	No Visible Fault	-
8		Jubilee Hills	I.O.A	11KV	X	15.26	16.35	01.09	EL,OL-Bph	No Visible Fault	-
9		Gunrock	Surya Enclave	11KV	C-VI	23.25	01.15	01.50	EL,OL-Bph	No Visible Fault	-
1		HYD S	Santosh Nagar	Chandra Huts	11KV	VIII	14.55	16.40	01.45	EL	2No. HT Jumpers cut at IS Sadan
2	Hyderguda		A.G Colony	11KV	III	15.05	16.58	01.53	EL	2No. Disc Insulators flash over at Hyderguda	-
3	Malakpet		M.M.H	11KV	VIII	15.07	16.30	01.23	EL	O/G AB Switch Jumper cut at SS	-
4	Hyderguda		Hyderguda	11KV	III	15.12	18.15	03.03	EL	Big tree fallen on lines at Nalanda Nagar	-
5	Kanchanbagh		Riyasath Nagar	11KV	III	17.17	19.20	02.03	EL,OL	DF Point UG Cable fault at Ali Bai PT	-
1	HYD C	Industrial Area	Mother Dairy	11KV	II	14.58	16.00	01.02	EL,OL-R&Yph	No Visible Fault	-
2		Langer House	Pensionpura	11KV	VII	15.03	16.30	01.27	EL	No Visible Fault	-
3		Bathkammakunta	Ahobilmutt	11KV	II	15.11	16.43	01.32	EL	Tree branches fallen on lines at Hotel Management	-
4		A.S.R Raju Nagar	A.S.R Raju Nagar	11KV	VII	15.13	19.34	04.21	EL	No Visible Fault	Arranged B/F on 11KV Market Yard fdr
5		Langer House	Defence Colony	11KV	VII	15.16	19.28	04.12	EL,OL-Y&Bph	Tree branches fallen on lines at Fire Station	-
6		Langer House	Prashanth Nagar	11KV	VII	15.16	16.48	01.32	EL,OL-Bph	No Visible Fault	-
7		Mothi Mahal	Saleh Nagar	11KV	VII	15.17	18.30	03.13	EL,OL-Y&Bph	Tree fallen on lines at Military Area	-
8		Chilkaiguda	Parsigutta	11KV	II	15.20	16.45	01.25	EL	Faulty loads of 11KV 44 Bus Stop feeder	-
9		Asif Nagar	Avalon	11KV	VII	15.22	17.00	01.38	EL	Tree branches fallen on lines & Jumper cut at Premier Hospital	-
10		Jawahar Nagar	Ashok Nagar	11KV	I	15.24	17.00	01.36	OL-Yph	Tree fallen on lines at Navatha Transport	-
11		Mothi Mahal	M.D Lines	11KV	VII	15.25	19.31	04.06	EL,OL-R&Bph	Tree branches fallen on lines at Military Area	-
12		Golnaka	Brahman Hostel	11KV	II	15.32	16.58	01.26	EL,OL	No Visible Fault	-
13		Golconda	Q.Q Toombs	11KV	VII	15.56	18.05	02.09	EL	Tree branches fallen on lines at Alzapur	-