

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		5		5		5			
6	RR(N)	54	550	1	6	1	6	1	6			
7	RR(E)	168	403		11		11		11			
8	Hyd	194	1044	1	11	1	11	1	11			
	Total	606	3055	2	33	2	33	2	33	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		9		9		9			
3	MDK	107	933	1		1		1				
4	SDPT				18		18		18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	27	2	27	2	27	0	0	
	Grand Total	1082	6468	4	60	4	60	4	60	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.09.2020

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	Talakondapally	33KV	Shadnagar	19.40	22.05	02.25	EL	4 Nos Poles Damaged	Talakondapally	Alternate Supply Arranged from 132KV Alwal 33KV Padkal feeder
1	MDK	Sadasivpet	Koheer	33KV	Sadasivpet	9:25	11:35	2:10		Bird fallen on the line	Koheer	No
1	RR N	132KV Medchal	Medchal-I	33KV	Medchal	14:10	17:30	3:20		33KV Line cut and replaced at near by SS	Medchal-I	No
1	HYD C	132KV Asifnagar	Mothimahal	33KV	Asifnagar	18.28	18.38	00.10	EL	Due to End kit failed on Line AB Switch at MD Lines, Mothimahal.	Taraka Rama	Alternate supply arranged.

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bondugula	Bondugula Town	11KV	Bhongir	2:15	8:10	5:55	EL/OL	R Pahse Limb Failed Town Feeder Tag on Bondugula Agl Feeder	No
2		Bondugula	Bondugula Agl	11KV	Bhongir	06.00	08.10	02.10	EL/OL	11kv Insulator Failed near Bondugula Village 3Phase B/d	No
3		Choutuppal IPDS	Dhamera Agl	11KV	Choutuppal	13.31	16.30	02.59	EL/OL	11kv Line Snapped near Dhamera Agl Due to Rain	No
4		Snagem	Dhubbala	11KV	Choutuppal	13.53	16.30	02.37	EL/OL	11kv Line Snapped near Dubbala vaillge Due to Rain	No
5		Jalalpuram	Gottiparthi	11KV	Suryapet	02.30	06.50	04.20	E/L	Conductor Snapped	No
6		Katangur	Mallaram	11KV	Nalgonda	00.15	06.40	06.25	E/L	Tree branches fallen on line	No
7		Nakrekal	Chandampally	11KV	Nalgonda	04.15	10.20	06.05	E/L	Jumper cut	No
8		Kethepally	Inupamula	11KV	Nalgonda	08.35	13.44	05.09	E/L	11KV insulator failed	No
9		Nakrekal	Palem	11KV	Nalgonda	8:55	10:15	1:20	E/L	Jumper cut	No
1	SDPT	Chinnagundavelly	Rampur	11KV	Siddipet	9:20	19:45	10:25		Disc failed & LC.No.10049	No
2		Peddachekode	Achimaipally	11KV	Siddipet	17.00	19.50	02.50		Insulater failed & LC.No.0651	No
3		DR pally SS	DR pally	11KV	Gajwel	09:00	10:28	1:28		Jumper Cut	No
4		DR pally SS	Giripally	11KV	Gajwel	10:53	11:54	1:01		11 KV line cut	No
5		DR pally SS	Giripally	11KV	Gajwel	15:54	16:59	1:05		DTR Rectified	No
6		Bejgama SS	Jaligama	11KV	Gajwel	15:45	16:44	1:59		Conductor cut	No
7		Singatam SS	Singatam	11KV	Gajwel	17.50	18.15	00.25		Disc failed	No
8		Pregnapur SS	Pregnapur Town	11KV	Gajwel	19.17	19.54	00.37		Copper patti cut	No
9		Pamulaparty SS	Pamulaparthi	11KV	Gajwel	07:38	11:12	03.36		11KV pamulaparthi touched Express feeder line was broken	No
10		Pamulaparty SS	Express	11KV	Gajwel	16:10	17:35	01.35		Tree fallen on the line	No
11		Karkapatla	Globin	11KV	Gajwel	14:30	15:50	01.20		Tree fallen on the line	No
12		Mulugu SS	Mulugu MHQ	11KV	Gajwel	12:45	13:20	0:35		Tree branches fallen on the line	No
13		Kondapaka SS	Vishvanthpally	11KV	Gajwel	04.00	12.00	08.00		Insulator failed and 11 KV Jumper cut	No
14		Husnabad	Madatha	11KV	Husnabad	15.20	16.00	00.40		Heavy Rain	No
15		Gandipally	Ramavaram	11KV	Husnabad	18.15	21.15	03.00		Heavy Rain	No
16		Guruvannapeta	Thapasally	11KV	Husnabad	00.00	06.25	06.25		Tree branches fallen on the line	No
17		Komuravelli	Kadaverugu	11KV	Husnabad	16.55	17.44	00.49		Disc failed	No
18		Maddur	Maddur Agl	11KV	Husnabad	16:00	6:00	14:00		Heavy Rain & Wind	No
1	RR S	Manikonda	Panchavathi	11KV	Ibrahimbagh	18:02	19:20	1:18		11KV Disc failed at Panchavathi Colony	No
2		Manikonda	Friends Colony	11KV	Ibrahimbagh	18.46	19.45	00.59		Tree branches fallen on the 11 KV line at Friends Colony Bus stop	No
3		Puppalaguda	Lanco	11KV	Ibrahimbagh	18.50	19.45	00.55		11 KV Pin insulator failed at Road 4	No
4		IIIT	GPRA	11KV	Gachibowli	04.08	07.26	03.18		11kv AB-Cable failed at UCO bank	Backfeeding from 11kv Kindriya Vihar feeder
5		ESCI	ESCI	11KV	Gachibowli	18:07	19:47	1:40		11kv Line AB-Swith Opened at ESCI College gate.	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Dulapally	Steelcity	11KV	Medchal	1:13	3:00	1:47		63KVA T/F Disc failed at Indus Tower(Jumer Opened)	No
2		Laxmapur	MC Pally	11KV	Medchal	07.55	08.56	01.01		Bird fallen on the 11KV Line at SS Back side	No
3		Kandlakoya	Godrej	11KV	Medchal	09.10	09.50	00.40		11KV Disc failed at NCL Company	No
4		Laxmapur	Laxmapur	11KV	Medchal	14.45	15.40	00.55		11KV Pin Insulator failed at Cheruvukatta	No
5		Aliabad	HBL	11KV	Medchal	14.05	15.40	01.35		Tree fallen on 11KV Line at at LGM Pet	No
6		RGK Suraram	Krushu colony	11KV	Jeedimetla	16:35	17:50	1:15		Tree branch fallin on the 11kv line at Government School	No
1	RR E	NGRI	Scientist Colony	11KV	Habsiguda	13:20	14:18	0:58		Tree fallen on 11KV line near Kalanjali Apartment at Nagendra Nagar Colony & 11KV Jumper cut near 78 degrees Restuarent	No
2		NGRI	Scientist Colony	11KV	Habsiguda	15.34	16.35	01.01		11KV Disc failed near St.No.02 Habsiguda	No
3		Mallapur	Sai Nagar	11KV	Habsiguda	12.05	13.05	01.00		Due to Heavy rain & 11KV 2Nos HG Fuse failed near Pinokini Company	No
4		Nacharam	Innogent	11KV	Habsiguda	12.43	14.05	01.22		11KV Disc failed near AP food & Tree fallen near Bandla Print Company	No
5		Nacharam	Times Of India	11KV	Habsiguda	19.00	20.28	01.28		11KV Disc failed near Sifco Company	No
6		Mallapur-2	AP Colony	11KV	Habsiguda	19.16	21.00	01.44		11KV Harmoor Cable failed near AR Enclave	No
7		Polytechnic	Srinivasapuram	11KV	Habsiguda	19.25	21.40	02.15		11KV 2Nos Disc failed at Kamakshipuram Ravi Photo Studio	No
8		Moula ali	HCL	11KV	Sainikpuri	12.53	15.05	02.12		Insulator failed near Indian Bank (ADE)	No
9		Chengicherla	My Villas	11KV	Keesara	13.55	14.55	01.00		11KV Insulator failed near Bharath Gas Opposite	No
10		Balaji Nagar	Sai Baba Temple	11KV	Keesara	14.16	14.56	00.40		Tree fallen on 11KV line at Shivalayam Temple Road Backside	No
11		Aushapur	Madharam	11KV	Keesara	17:10	18:30	1:20		11KV pin Insulator failed near Narayana Reddy Poultry Form	No
1	HYD N	Vasanthapuri	Sheshapahad	11KV	V	12.48	14.57	02.09	EL	Disc Insulator flash over at Sheshapahad	No
2		Lalaguda	Vijayapuri	11KV	V	13:10	14:38	1:28	EL,OL-R&Bph	Tree branches fallen on lines at Scared Heart High School	No
3		Pragatools	Giri Nagar	11KV	VI	16:39	17:57	1:18	EL,OL-Rph	Standby UG Cable failed at Gandhi Nagar	No
4		K.I.M.D	D.V.Colony	11KV	V	19:43	21:30	1:47	EL,OL-Rph	Pin Insulator flash over at Ramalayam, D.V.Colony	No
1	HYD S	Sultan Bazar	Taraka Rama	11KV	IX	18.54	20.15	01.21	EL	Cable End Kit failed at Music College	No
1	HYD C	S.D Hospital	Ahmed Nagar UG	11KV	VII	18.15	19.38	01.23	EL,OL-Bph	Bamboo Stick fallen on lines at Syed Nagar	No
2		A.S.R Raju Nagar	Sai Garden	11KV	VII	18.20	20.54	02.34	EL,OL	Pin Insulator flash over at Venkata Sai Apts	No
3		ITI Mallepally	Anjuman	11KV	VII	19.40	21.07	01.27	OL	Pin Insulator flash over at Old P.S	No
4		Golconda	Golconda OH	11KV	VII	19.45	20.58	01.13	EL,OL-Bph	AB Cable fault at Ali Masjid	No
5		Chilkaiguda	Parsi Gutta	11KV	II	23:05	0:25	1:20	EL	Tree branches fallen on lines at Timber Depot	No
6		Amberpet	Amberpet	11KV	II	23.25	01.00	01.35	EL	Disc Insulator flash over at Manikeswar Nagar	No