

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	11	1	11	1	11			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		24		24		24			
	Total	606	3055	1	39	1	39	1	39	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	1	22	1	22	1	22			
3	MDK	107	933	2	3	2	3	2	3			
4	SDPT				18		18		18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	43	5	43	5	43	0	0	
	Grand Total	1082	6468	6	82	6	82	6	82	0	0	

## TSSPDCL - LMRC / Corporate office

Date: 13.09.2020

## Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Salasar Balaji	33kv	Jadcherla	03.00	10.30	07.30	E/L&O/L	Due to Isulator Failed at Company & LA Failure	Salasar Balaji	-
2		Gadwal	Maldakal	33kv	Gadwal	10.50	11.40	00.50	E/L	Jumper Cut at Maldakal SS	Maldakal	-
1	NLG	Suryapet	Nuthankal	33kv	Suryapet	03.30	07.10	03.40	E/L	Insulator failed	Nuthankal	-
1	MDK	Zaheerabad	Hadnoor	33kv	Zaheerabad	02.45	09.00	06.15		B/D Due to Jumper Cut	Hadnoor	-
2		Narayankhed	Kalher	33kv	Jogipet	02.20	05.40	03.20		B/D Due to Conductor Snapped	Kalher	-
1	RR N	132KV Chintal	33KV Dulapally	33kv	Medchal	03.16	07.50	04.34		33KV Jumper and Disc failed at IDA Jeedimetla	33KV Dulapally	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 13.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kattangur	Mallaram	11kv	Nalgonda	01.55	06.10	04.15	E/L	Tree Branch Fallen on the Line	-
2		Kattangur	Kalimera	11kv	Nalgonda	03.38	09.05	05.27	E/L	Jumper Cut	-
3		Narkekal	Marrur	11kv	Nalgonda	01.20	06.35	05.15	E/L	Jumper Cut	
4		Narketpally	Mandra	11kv	Nalgonda	02.45	07.15	04.30	E/L	Jumper Cut	
5		Eduloor	Munukuntla	11kv	Nalgonda	03.00	07.00	04.00	E/L	SS-3 Jumper Cut	
6		Pajjur	Pajjur	11kv	Nalgonda	01.00	06.00	05.00	E/L	SS-15 Insulator Failed	
7		Narsingbatla	Chennugudem	11kv	Nalgonda	00.45	07.45	07.00	E/L	Tree Branch Fallen on the Line	
8		Pulicherla	Pulicherla	11kv	Miryalaguda	15.32	16.50	01.18	E/L	Conductor failed	
9		Pendlipakala	Pendlipakala	11kv	Devarakonda	05.00	08.30	03.30	E/L	11 KV Disc Failed	
10		Angadipeta	P.A.pally Rural	11kv	Devarakonda	14.30	15.00	00.30	E/L	Tree Flowen	
11		Angadipeta	Chilkamarri	11kv	Devarakonda	15.30	16.30	01.00	E/L	Tree Flowen	
12		Marriguda	Thamadapally	11kv	Devarakonda	14.20	14.45	00.25	E/L	Tree Flowen	
13		Shivannagudem	R.R.Pally	11kv	Devarakonda	14.30	16.45	02.15	E/L	11 KV Insulator Failed	
14		Durajpally	Town feeder	11kv	Suryapet	03.30	05.50	02.20	E/L	Bird fallen on the line	
15		Yerkaram	Das thanda	11kv	Suryapet	03.40	07.30	03.50	E/L	Insulator flashover	
16		Dirsincherla	Narsaigudem	11kv	Huzurnagar	05.30	07.30	02.00	EL	11 KV LINE SNAPPED	
17		Karvirala	Keshavapuram	11kv	Huzurnagar	06.00	08.45	02.45	EL	11 KV LINE SNAPPED	
18		Bibinagar	Guraladandi	11kv	Bhongiri	09.06	11.40	02.34	EL/OL	11 kv Insulator failed near Chinnaravulapally village	
19		Rajapeta	Nemila	11kv	Bhongiri	03.30	08.20	04.50	EL/OL	11 KV Insulator failed at Kalluri .Narsimha reddy well nemila village	
20		Bondugula	Bondugula Agl	11kv	Bhongiri	06.00	09.30	03.30	EL/OL	11 kv Disc failed at Rice mill Bondugula village	
21		Yellanki	Siripuram	11kv	Choutuppal	00.05	08.55	08.50	EL/OL	11 KV Insulator failed near Siripuram village	
22		Laxmapuram	Nidanpally	11kv	Choutuppal	05.30	10.20	04.50	EL/OL	11 kv Insulator failed near Nidanaply village	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Cheryal	MYK Laticrete	11kv	Sangareddy	01.00	02.00	01.00		B/D Due to Pin Insulator Failure	-
2		Cheryal	Turbovent	11kv	Sangareddy	01.30	03.20	01.50		B/D Due to Conductor Snapped	-
3		Patancheru Town	Town	11kv	Patancheru	03.50	07.00	03.10		B/D Due to Jumper Cut	-
1	SDPT	Gajwel SS	BVPUR Feeder	11kv	Gajwel	07:00	11:30	4:30		11KV Disk fail	
2		Pregnapur SS	Gundanapally Feeder	11kv	Gajwel	10.40	12.18	01.38		Tree has fallen	
3		Wargal SS	Chowderpally Feeder	11kv	Gajwel	7:50	10:18	02.22		11KV Line cut	
4		Gowraram SS	pamulaparthi feeder	11kv	Gajwel	08:00	11:00	03.00		11KV Disk fail	
5		Markook SS	Sheha feeder	11kv	Gajwel	08:30	10:10	01.40		Insulator fail	
6		Karkapatla SS	Globin Feeder	11kv	Gajwel	08:58	12:13	03.15		Insulator fail	
7		Damarakunta SS	Kasireddypally Feeder	11kv	Gajwel	7:23	10:15	3:08		11KV Line cut	
8		Damarakunta SS	Industrial Feeder	11kv	Gajwel	11:10	12:15	01.05		Jumper cut	
9		Damarakunta SS	Damarakunta Feeder	11kv	Gajwel	12:15	14:40	02.25		AB switch Repair	
10		Mulugu SS	Mulugu MHQ Feeder	11kv	Gajwel	02:15	08:35	6:20		Tree has fallen	
11		Mulugu SS	Mulugu AGL Feeder	11kv	Gajwel	10:15	19:00	8:45		Tree Branches has fallen	
12		Thunkibollaram bollaram	Achaipally Feeder	11kv	Gajwel	9:50	11:00	1:10		Bird has fallen	
13		Akkannapet	Gollakunta	11kv	Husnabad	06.00	09.12	03.12		11 KV Line cutting	
14		Thotapally	Devakkapally	11kv	Husnabad	04.10	08.30	04.20		Tree fallen in line	
15		Thotapally	Thotapally (T)	11kv	Husnabad	04.15	09.15	05.00		Tree fallen in line	
16		Mustyal	Veereannzpet	11kv	Husnabad	13.05	14.10	01.05		Insulator Fail	
17		Guruvannapet	Guruvannapet	11kv	Husnabad	04.45	08.02	03.17		Insulator Burst (3-ph B/D )	
18		Komuravelly	Kadavergu	11kv	Husnabad	02.30	09.20	06.50		Insulator Fail	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	HMT	Gandhi Nagar	11kv	Medchal	06.55	07.30	00.35		Tree Fallen on the 11KV Line at HMT Wall	-
2		Subhash Nagar	Gayathri Nagar	11kv	Medchal	00.05	03.15	03.10		Tree Fallen on the 11KV Line at TNR Garden	-
3		Subhash Nagar	Meenakshi	11kv	Medchal	01.00	04.00	03.00		Breaker Mechanical problem in SS	-
4		Subhash Nagar	Pragha Tools	11kv	Medchal	05.00	06.55	01.55		11KV Pin Insulator failed at BHEL Vista Apartment	-
5		Petbasheerabad	Vaishnavi Enclave	11kv	Medchal	01.00	02.20	01.20		No Fault	
6		Chintal	Dwaraka Nagar	11kv	Medchal	03.25	04.30	01.05		11KV Jumper cut and replaced at Prasoon Nagar	
7		GP Pally	GP Pally	11kv	Medchal	03.30	05.55	02.25		Tree Fallen on 11KV Line at Ayodhya X Road	
8		GP Pally	APIIC	11kv	Medchal	07.50	11.50	04.00		Internal Problem at Racharla Infrastructure company (AB Switch opened)	-
9		Aliabad	Jaganguda	11kv	Medchal	09.15	10.00	00.45		Bird fallen on the 11KV Line at Nikmar College	-
10		Jeedimetla-IV	Bhagya Laxmi Colony	11kv	Jeedimetla	02.40	03.40	01.00		AB Cable Failed at Wines Shope, BhagyaLaxmi Colony {B/F Virchow}	-
11		RGK Suraram	Suraram Village	11kv	Jeedimetla	03.20	05.20	02.00		11kv line Pin Insulater failed at Mallareddy Hospital	-
1	RR E	NGRI	Scientist Colony	11kv	Habsiguda	00.15	01.40	01.25		11KV Line snapped & 11KV Pin Insulator failed near Hanuman Temple Habsiguda Main Road & B/F supply taken from 11KV Snehapuri Colony feeder	-
2		Sai nagar	maruthi nagar	11kv	Habsiguda	13.45	14.45	01.00		Insulator fail at NIN colony	-
3		Cherlapally-IV	BN Reddy Nagar	11kv	Sainikpuri	03.45	05.00	01.15		2 Polymer Disk Insuletor fail at BN Reddy Nagar (AE)	-
4		Keesara	Keesara	11kv	Keesara	06.20	07.55	01.35		Insulaotr fail at keesara road	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	New Bowenpally	Reliance Villa	11kv	VI	00.02	01.24	01.22	EL,OL	HG fuse burntout at Last PT	----
2		Gymkhana	Pared Ground	11kv	C-VI	00.20	01.40	01.20	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Ranibagh fdr
3		Jubilee Hills	A.O.U	11kv	X	03.40	05.00	01.20	EL,OL-Bph	Cable fault at Road No.45	----
4		Macha Bollaram	Sai Reddy Nagar	11kv	C-VI	03.48	05.20	01.32	OL-R&Bph	Tree branches fallen on lines at Sai Reddy Nagar	----
5		Jubilee Hills	Film Nagar	11kv	X	03.55	05.15	01.20	EL	No Visible Fault	----
6		Gymkhana	Vasavi Nagar	11kv	C-VI	04.12	06.13	02.01	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Gymkhana fdr
7		Bowenpally	Akshaya Enclave	11kv	VI	04.48	06.26	01.38	EL,OL-Yph	HT Jumper cut & Sparking AB Switch at Airport Road	----
8		Kalyan Nagar	Jawahar Nagar	11kv	X	05.16	06.30	01.14	All Indication	O/G AB Switch Jumper cut & UG Cable fault	Arranged B/F on 11KV Savera fdr
9		Kalyan Nagar	Madhura Nagar	11kv	X	05.16	08.08	02.52	All Indication	HT Jumpers cut on AR near SS	Arranged B/F on 11KV State Home feeder
10		Kalyan Nagar	Laxmi Nagar	11kv	X	05.16	06.48	01.32	All Indication	No Visible Fault	----
11		New Bowenpally	Reliance Villa	11kv	VI	05.53	07.00	01.07	EL,OL	No Visible Fault	----
12		I.D.P.L	SIFCO	11kv	VI	06.20	07.25	01.05	EL	Tree branches fallen on lines at ELCO Company	----
13		Gunrock	Anjaiah Nagar	11kv	VI	10.22	11.26	01.04	EL,OL-Rph	Line AB Switch Jumper cut at Bowenpally Market	----
14		Gymkhana	Balamrai	11kv	C-VI	11.31	12.50	01.19	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Ranibagh fdr
15		Chinna Thokatta	Mahatma Nagar	11kv	VI	14.37	16.45	02.08	EL	Line AB Switch Jumper cut at Progressive Colony & Faulty DTR at Sowjanya Colony	At 15:54hrs Partial fdr charged & remaining loads added on 11KV Saibaba Temple fdr
1	HYD S	C.R.P.F.	Barkas	11kv	III	15.30	16.45	01.15	EL	Bird fault on lines at CRPF Gate No.3	
1	HYD C	S.D Hospital	Police Mess	11kv	VII	00.20	01.33	01.13	EL	Pin Insulator flash over at Masha Allah Apparments	----
2		Indira Park	Talla Basti	11kv	I	04.58	06.02	01.04	EL	HT Jumper cut at Nala AR	----
3		Nampally	FAPCCI	11kv	VII	05.58	07.40	01.42	EL	No Visible Fault	----
4		Golconda	Narayanamma College	11kv	VII	08.32	09.43	01.11	EL,OL-Rph	UG Cable fault at Vaternary Colony (2No. DTR's Kept Off)	----
5		Chilalguda	Bholakpur	11kv	I	09.30	11.16	01.46	EL,OL-Rph	HT Jumper cut at Musheerabad X-Rds	----
6		Nampally	FAPCCI	11kv	VII	13.45	15.08	01.23	EL	Bird fault on lines at Red Hills	----
7		ITI Mallepally	Anwar Ul-Uloom	11kv	VII	14.23	15.31	01.08	EL,OL	Cable fault	Arranged B/F on 11KV Afzal Sagar fdr
8		Fever Hospital	Fever Hospital	11kv	II	21.00	01.05	04.05	EL	Disc Insulator flash over at Barkathpura Chaman	Arranged B/F on 11KV Shankarmutt feeder