

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	8	1	8	1	8			
7	RR(E)	168	403		9		9		9			
8	Hyd	194	1044		13		13		13			
	Total	606	3055	1	30	1	30	1	30	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	12	3	12	3	12			
2	NLG	144	988	8	24	8	24	8	24			
3	MDK	107	933	0	12	0	12	0	12			
4	SDPT			0	18	0	18	0	18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	11	66	11	66	11	66	0	0	
	Grand Total	1082	6468	12	96	12	96	12	96	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.09.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narva	33KV	Narayanapet	04.05	04.35	00.30	E/L	Due to Heavy Rain		Alternate Supply Given to 33KV Ekilaspur Feeder at 4:35Hrs
2		Nagarkurnool	Nagarkurnool	33KV	Nagarkurnool	03.46	03.55	00.09	E/L	Tree Fallen on the 33KV Line		Alternate Supply Given to 33KV Ithole Feeder at 3:55Hrs
3		Nagarkurnool	Peddakothapally	33KV	Nagarkurnool	02.16	07.30	05.14	E/L	Due to Pin Insulator Failed		AB Switch Open at Peddakothapally
1	NLG	Mattampally	Pedaveedu	33KV	Huzurnagar	09.00	13.20	04.20	E/L/O/L	33Kv Insulator failure 2 No's Heavy rain		-
2		Mattampally	Raghunathpalem	33KV	Huzurnagar	09.30	14.15	04.45	E/L/O/L	33Kv Insulator failure 2 No's Heavy rain		-
3		Suryapet	Penpahad	33KV	Suryapet	00.40	14.00	13.20	E/L/O/L	33Kv Disk failure and Jumper cut Due to Heavy rain		-
4		Suryapet	Sudhakar PVC	33KV	Suryapet	00.55	16.20	15.25	E/L/O/L	33Kv Jumper cut in Yard 33/11KC SS Heavy Rain		-
5		Suryapet	Kethepally	33KV	Suryapet	05.05	12.15	07.10	E/L/O/L	Lighting Arrester Blast in 132KV SRPT Due to Heavy rain		-
6		B.B.Nagar	Bollepally	33KV	Bhongiri	04.26	07.06	02.40	E/L/O/L	33KV Insulator failed and replaced near Gokulthanad (V)		-
7		Mothkur	Paladugu	33KV	Bhongiri	02.46	10.26	08.20	E/L/O/L	33Kv Moment fault Heavy rain		-
8		Aitipamula	Annaram	33KV	Nalgonda	01.59	09.10	07.11	E/L/O/L	Breaker problem In Annaram SS Heavy rain		-
1	RR N	132KV LGM Pet	33KV Aliabad	33KV	Medchal	03.15	06.55	03.40		33KV Pin Insulator failed at Ricemill,Keshavaram		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Chennavelly	11KV	Jadcherla	03.00	09.00	06.00		11KV Wire cut near Kucharkal	-
2		Rajapur	Mudireddypally	11KV	Jadcherla	13.25	14.45	01.20		11KV Jumper cut near Mudireddypally	-
3		Balanagar	Amith Cotton Mill	11KV	Jadcherla	03.05	14.00	10.55		11KV Jumper cut near Chinthagudem	-
4		Jadcherla Rural	Mallaboinpally	11KV	Jadcherla	02.00	11.27	09.27		11KV Wire cut near Chittaboinpally	-
5		Boothpur	L & T	11KV	Jadcherla	05.20	08.20	03.00		11KV Insulator fail near Kothamolgara	-
6		Jadcherla Town	Gangapur X-Press	11KV	Jadcherla	01.50	06.40	04.50		11KV Jumper cut near Aloor	-
7		Kotakonda	Thirumapur	11KV	Narayanapet	03.55	08.00	04.05		Due to Heavy Gale & Wind	
8		Marikal	Madwar	11KV	Narayanapet	10.40	12.35	01.55		Due to 11KV Disc Failed	
9		Marikal	Eliganla	11KV	Narayanapet	10.37	12.25	01.48		Due to Heavy Gale & Wind	
10		Perapalla	Perapalla AGL	11KV	Narayanapet	04.00	11.06	07.06		Due to 11KV Disc Failed	-
11		Narayanpet	Yadgir	11KV	Narayanapet	22.30	23.25	00.55		Due to 11KV Disc Failed	-
12		Kosgi	Bhogaram	11KV	Narayanapet	14.25	15.16	00.51		Due to Peacock Fallen Down on 11KV line	-
1	NLG	Nakrekal	Marrur	11KV	Nalgonda	03.00	06.00	03.00	E/L	Tree Branch Fallen 11Kv on the Line	-
2		S.Gouraram	Gurajala	11KV	Nalgonda	02.05	08.30	06.25	E/L	11Kv Jumper Cut	-
3		Eduloor	Naragudem	11KV	Nalgonda	02.30	08.45	06.15	E/L	11Kv Jumper Cut	
4		Pamanagundla	Yerasanigudem	11KV	Nalgonda	04.15	09.05	04.50	E/L	11Kv Jumper Cut	
5		Thoragal	GR Gudem	11KV	Nalgonda	05.00	09.20	04.20	E/L	SS-3 11Kv Jumper Cut	
6		Palem	Palem	11KV	Nalgonda	02.50	09.25	06.35	E/L	SS-15 11Kv Insulator Failed	
7		Nakrekal	Chandampally	11KV	Nalgonda	02.30	10.05	07.35	E/L	Tree Branch Fallen 11Kv on the Line	
8		Kattangur	Powerloom	11KV	Nalgonda	05.00	14.20	09.20	E/L	11KV jumper cut	
9		Palem	Ogodu	11KV	Nalgonda	03.15	13.25	10.10	E/L	11KV jumper cut	
10		Palem	Bopparam	11KV	Nalgonda	06.00	14.05	08.05	E/L	11KV jumper cut	
11		Thoragal	Madaram	11KV	Nalgonda	05.00	15.40	10.40	E/L	11KV jumper cut	
12		Thoragal	TG Gudem	11KV	Nalgonda	05.00	15.25	10.25	E/L	11KV jumper cut	
13		Athmakur	Naseempeta	11KV	Suryapet	09.30	14.00	04.30	E/L	Bird fallen on the line	
14		Reddygudem	Reddygudem	11KV	Suryapet	03.10	07.00	03.50	E/L	Insulator flashover	
15		Palakeedu	Bothalapalem	11KV	Huzurnagar	02.35	07.00	04.35	E/L	11Kv Line Snapped	
16		Munagala	Singaram	11KV	Huzurnagar	04.00	07.30	03.30	E/L	11Kv Line Snapped	
17		Kondamadugu	Kondamadugu	11KV	Bhongir	07.00	11.50	04.50	EL/OL	11kv line snapped near Bibinagar sbi Bank	-
18		Solipet	Peraram	11KV	Bhongir	06.40	07.15	00.35	EL/OL	11kv Insulator Failed near Munirabad (V)	-
19		Paladugu	Panakabanda	11KV	Bhongir	12.55	15.25	02.30	EL/OL	11kv Line snapped near Ragibavi (V)	-
20		Jai.Kesaram	Assonigudem	11KV	Choutuppal	03.22	08.42	05.20	EL/OL	11kv Disc Failed near Vivan Phorma Company	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
21		Choutuppal IPDS	Dhamera Agl	11KV	Choutuppal	13.09	17.30	04.21	EL/OL	11kv Disc Failed near Dhamera (V)	-
22		Jublakpally	Vankamamidi	11KV	Choutuppal	02.22	11.08	08.46	EL/OL	11kv Line Snapped near Vankamamidi Due to Rain	
23		Puligilla	Kanchnapally	11KV	Choutuppal	04.00	11.00	07.00	EL/OL	11kv Insulator Failed near Kanchnapally (V) Due to Rain	-
24		Arror	Town	11KV	Choutuppal	04.20	09.50	05.30	EL/OL	11kv Insulator Failed near Arror Town	-
1	MDK	EPIP-I 1	Chitrakoot	11KV	Sangareddy	05.30	06.50	01.20		BD due to Tree branches fallen on line	-
2		EPIP-I 1	Chaitanya	11KV	Sangareddy	05.35	07.05	01.30		BD due to Insulator failed	-
3		EPIP-I 1	Chaitanya	11KV	Sangareddy	08.50	11.25	02.35		BD due to Jumper cut	-
4		Inole	Sathyasai WW	11KV	Patancheru	05.55	08.27	02.32		BD due to conductor snapped	-
5		SOL	Markwell	11KV	Patancheru	12.05	14.05	02.00		BD due to Tree fallen on line	-
6		Pati	Shalimar	11KV	Patancheru	12.30	14.30	02.00		BD due to Tree branches fallen on line	-
7		Patancheru Town	MIA-II	11KV	Patancheru	15.50	17.20	01.30		BD due to Tree fallen on line	
8		Patancheru Town	Allwyn	11KV	Patancheru	20.30	21.10	00.40		BD due to T/F damaged	
9		Kistareddypet	Bheeramguda	11KV	Patancheru	12.15	12.56	00.41		BD due to Insulator failed	
10		Kondapur	Marepally	11KV	Sangareddy	07.40	11.40	04.00		BD due to AB switch Burst	-
11		Kondapur	Gangaram	11KV	Sangareddy	13.55	15.58	02.03		BD due to Conductor snapped	-
12		Sadashivapet	Town II	11KV	Sangareddy	04.00	07.47	03.47		BD due to AB switch Burst	-
1	SDPT	Chinnagundavelly	Rampur	11KV	Siddipet	09.20	19.45	10.25		B/D Disk fail & LC.No.10049	
2		Peddachekode	Achimaipally	11KV	Siddipet	17.00	19.50	02.50		B/D Insulater fail & LC.No.0651	
3		DR pally SS	DR pally Feeder LC.No.8937	11KV	Gajwel	09:00	10:28	1:28		Jumper Cut	
4		DR pally SS	Giripally Feeder LC.No.8938	11KV	Gajwel	10:53	11:54	1:01		11 KV line cut	
5		DR pally SS	Giripally Feeder LC.No.8940	11KV	Gajwel	15:54	16:59	1:05		DTR Rectified	
6		Bejgama SS	Jaligama Feeder LC.No.5932	11KV	Gajwel	15:45	16:44	1:59		Conductor cut	
7		Singatam SS	Singatam Feeder LC.No.9741 Yadaiah CL	11KV	Gajwel	17.50	18.15	00.25		Disk fail	
8		Pregnapur SS	Pregnapur Town LC.No.9834 Narender Reddy LM	11KV	Gajwel	19.17	19.54	00.37		Copper patti cut	
9		Pamulaparty SS	Pamulaparthly and Express Feeders LC.No.216 Chandram CL	11KV	Gajwel	07:38	11:12	03.36		11KV pamulaparthly touched Express feeder line was broken	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
10		Pamulaparty SS	Express feeder LC.No.217 Chandram	11KV	Gajwel	16:10	17:35	01.35		Tree has fallen	
11		Karkapatla	Globin Feeder	11KV	Gajwel	14:30	15:50	01.20		Tree has fallen	
12		Mulugu SS	Mulugu MHQ Feeder LC.No.14095	11KV	Gajwel	12:45	13:20	0:35		Tree branches has fallen	
13		Kondapaka SS	Vishvanthpally feeder LC.No.24340 Mahender LM	11KV	Gajwel	04.00	12.00	08.00		Insulator fail and 11 KV Jumper cut	
14		Husnabad	Madatha	11KV	Husnabad	15.20	16.00	00.40		Heavy Rain	
15		Gandipally	Ramavaram	11KV	Husnabad	18.15	21.15	03.00		Heavy Rain	
16		Guruvannapeta	Thaspally	11KV	Husnabad	00.00	06.25	06.25		Tree branches fallen on the line	
17		Komuravelli	Kadaverugu	11KV	Husnabad	16.55	17.44	00.49		Disc fail	
18		Maddur	Maddur Agl	11KV	Husnabad	16.00	06.00	14.00		Heavy Rain & Wind	
1	RR N	Prashanthi hills	Srinivasa colony	11KV	Medchal	04.55	06.20	01.25		Due to rain & Insulator failure at 190 road	-
2		Petbasheerabad	Balaji Hospital	11KV	Medchal	05.27	06.50	01.23		11KV Pin Insulator failed at Hitension Road Gate-4	-
3		UMCC	Mahadevpuram	11KV	Medchal	03.45	04.45	01.00		11KV Pin Insulator Failed at Kailasahills	-
4		Subhash Nagar	Pragha Tools	11KV	Medchal	08.16	09.11	00.55		11KV Disc failed at Pipe Line Road, Jeedimetla Village	-
5		Gowdavelly	IDA Gowdavelly	11KV	Medchal	04.10	09.40	05.30		11KV Pin Insulator failed at Ram Reddy Godam, Gowdavelly	-
6		Kandlakoya	KV Reddy Nagar	11KV	Medchal	05.35	08.15	02.40		Tree Fallen on 11KV Line at Bommala Bavi,KV Reddy Nagar	-
7		Medchal	IDA-I	11KV	Medchal	02.45	04.45	02.00		11KV Line Cut at BSNL Office & Masjid	-
8		Medchal	Navadurga	11KV	Medchal	03.05	06.00	02.55		11KV Pin Insulators failed at Gangeed & Bunphaly Compnies	-
1	RR E	Cherlapally-IV	BN Reddy Nagar	11KV	Sainikpuri	03.10	04.40	01.30		11Kv Pin Insuletor fail at BN Reddy Nagar Phase-I (AE)	-
2		Uppal	Boduppal	11KV	Habsiguda	05.20	06.30	01.10		Tree branches fallen on 11kv line at Uppal Maszid Main Road Uppal	-
3		Balaji Nagar	Dental College	11KV	Keesara	05.20	08.00	02.40		11KV Insulator failed at Rajeev Gandhi Nagar	-
4		Cherlapally	Rampally	11KV	Keesara	04.35	06.05	01.30		Line Patrolling but no visible fault	-
5		Yadgarpally	Thimmaipally	11KV	Keesara	07.20	09.30	02.10		Tree branches fallen on 11KV Line at Thimmaipally Harish Wall Venture	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
6		Chakripuram	Shilpa Nagar	11KV	Keesara	02.20	04.40	02.20		11KV disc failed at SC Colony	-
7		Aushapur	Aushapur	11KV	Keesara	06.40	07.45	01.05		Line Patrolling but no visible fault & 11KV line AB Switch opened at SPR College	-
8		Aushapur	Aushapur	11KV	Keesara	14.30	16.30	02.00		11KV Disc failed at Golden Park	-
9		Singapur	RGK	11KV	Keesara	13.45	15.35	01.50		Tree branches fallen on 11KV line near NTPC Beside	-
1	HYD N	R.P Nilayam	Venkatapuram	11KV	C-VI	03.15	04.34	01.19	EL,OL-Yph	DTR fault at Reddy Enclave	-
2		I.D.P.L	Sakshi	11KV	VI	03.55	05.40	01.45	EL,OL-R&Bph	No Visible Fault	-
3		Prashanth Nagar	Andhra Jyothi	11KV	VI	05.15	10.00	04.45	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Ganesh Kanta feeder
4		I.D.P.L	Sakshi	11KV	VI	05.55	07.40	01.45	OL-R&Bph	HT Service HG fuse fault at Plot No.110	-
5		Marredpally	R.K.Puram	11KV	C-VI	06.30	08.40	02.10	EL,OL-Bph	Tree branches fallen on lines at Military Area	-
6		Bowenpally	Plassy Line	11KV	VI	06.40	08.40	02.00	All Indication	DTR fault at Namdari Nagar	-
1	HYD S	Salarjung	Purani Haveli	11KV	III	04.10	05.40	01.30	EL,OL	No Visible Fault	-
2		Salarjung	Darulshifa	11KV	III	04.10	06.20	02.10	EL,OL	RMU Cable fault at Iqbal Hall	-
3		Devibagh	Zoo Quarters	11KV	III	06.38	07.50	01.12	OL-Rph	I/C Cable fault at SS	Arranged B/F on 11KV Kishanbagh AB Cable fdr
1	HYD C	Nampally	Vijay Nagar Colony	11KV	VII	04.14	06.46	02.32	EL	Tree branches fallen on lines at Meera Garden	04:57 Hrs partial feeder charged OK
2		Karwan	Langer House OH	11KV	VII	04.50	07.52	03.02	EL,OL	CT O/G Jumper cut at SS	Arranged B/F on 11KV Prashanth Nagar feeder
3		Langer House	Defence Colony	11KV	VII	05.53	07.38	01.45	EL,OL-Yph	RMU Insulator flash over & Faulty loads of 11KV Langer House Cable fdr	-
4		Gudimalkapur	Amba Garden	11KV	VII	08.32	10.04	01.32	EL,OL	Tree branches fallen on lines & Conductor snapped at Kanaka Durga Temple	-