

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		10		10		10			
6	RR(N)	54	550		9		9		9			
7	RR(E)	168	403		11		11		11			
8	Hyd	194	1044		25		25		25			
	Total	606	3055	0	55	0	55	0	55	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	11	1	11	1	11			
2	NLG	144	988		3		3		3			
3	MDK	107	933	5	3	5	3	5	3			
4	SDPT			1	18	1	18	1	18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	7	35	7	35	7	35	0	0	
	Grand Total	1082	6468	7	90	7	90	7	90	0	0	

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Thirumalaipally	Kothakota	33KV	Wanaparthy	03.40	04.45	01.05	E/L	Due to Heavy Rain	Kothakota	Alternate supply arranged from 132 KV SS Wanaparthy to 33KV Kothakota
1	SDP	Habsipur	Dubbak	33KV	Siddipet	07.10	07.30	00.20		B/D - Insulator fail	Dubbak	-
1	MDK	Zaheerabad	Zaheerabad	33KV	Zaheerabad	19.30	21.00	01.30		B/D Due tree Branch Fallen on the line	Zaheerabad	-
2		Narayankhed	wasar	33KV	Jogipet	13.25	15.40	02.15		B/D Due to Insulator Failure	wasar	-
3		Gummadidala	AFA	33KV	Patancheru	00.10	08.00	07.50		B/D Due to Insulator Failure	AFA	-
4		Singoor	Mudmanik	33KV	Jogipet	21.10	05.15	08.05		B/D Due to Jumper damaged	Mudmanik	-
5		Sadasivpet	Koheer	33KV	Sangareddy	21.40	05.45	08.05		B/D Due to Insulator Failure	Koheer	-

Circle-wise 11KV Breakdowns

Date: 16.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Boothpur	Town	11KV	Jadcherla	08.15	11.06	02.51		11Kv Disc Failure Near Adiya Mines Side.	-
2		Kodgal	Kodgal Agl	11KV	Jadcherla	06.15	12.35	06.20		11Kv Line Cut Near Kurvapally (Vi).	-
3		Mothiganapur	Gangadharpally	11KV	Jadcherla	08.15	12.00	03.45		11Kv disc Failure Near Rudrasri Venchor Side.	-
4		Kothamolgara	Maddigatla	11KV	Jadcherla	07.20	13.30	06.10		Tree Follen On The11Kv Line Near Nallaguttaside.	-
5		Gundumal	Amlikuntla	11KV	Narayanapet	00.00	07.00	07.00		Due to heavy rain	-
6		Pallerla	Nandipad	11KV	Narayanapet	02.00	12.40	10.40		Due to heavy rain	-
7		Mohammadabad	Shaikpally	11KV	Narayanapet	18.16	18.46	00.30		Due to 11 KV Disc faile	-
8		KYATHANPALLY	WATHUGUDLA	11KV	Narayanapet	10.30	11.54	01.24		TO DISC DAMAGE	-
9		KYATHANPALLY	AYYAWARIPALLY	11KV	Narayanapet	06.40	08.20	01.40		DUE TO HG FUSE WIRE FALLEN ON DTR BODY , DISC DAMAGED	-
10		NARAYANPET	SATYA SAI	11KV	Narayanapet	14.10	14.30	00.20		DUE TO DISC FAILURE	-
11		MARIKAL	PC KUNTA	11KV	Narayanapet	08.11	08.30	00.19		TO DISC FAILURE	-
1	NLG	Arlagaddagudem	Chinna Suraram	11KV	Nalgonda	12.00	13.10	01.10	EL	Tree fallen on the line	-
2		Sirikonda	Lal thanda	11KV	Huzurnagar	14.30	16.00	01.30	EL	11 KV LINE SNAPPED	-
3		Anantharam	Hanmapuram	11KV	Bhongir	09.40	11.30	01.50	EL	11KV Disc Failed	-
1	SDP	Mustabad X-Road	Gadicherlapally	11KV	Siddipet	00.00	01.30	01.30		B/D - due to rain	-
2		Nangnoor	Akkanapally	11KV	Siddipet	15.45	17.52	02.07		B/D - 11KV Jumpet cut	-
3		Chinthamadaka	Machapur	11KV	Siddipet	14.55	17.05	02.10		B/D - Insulator fail, LC No. 10338	-
4		Kammarlapally	Kammarlapally	11KV	Siddipet	06.10	09.30	03.20		B/D - 11KV pole bend, Jumper out	-
5		GAJWEL SS	TOWN2 FEEDER	11KV	Gajwel	14.11	15.10	00.59		DISK FAILED	-
6		GAJWEL SS	TOWN1 FEEDER	11KV	Gajwel	16.05	17.05	01.00		DISK FAILED	-
7		KODAKANDLA SS	KODAKANDLA AGL FEEDER (LC.NO.4125)NAGARAJU CL	11KV	Gajwel	08.52	09.35	00.45		JUMPER CUT	-
8		DAMARAKUNTA SS	INDUSTARIAL FEEDER(LC.NO.30886) HANMANTHU LM	11KV	Gajwel	15.02	17.37	02.35		DISK FAILED	-
9		PAMULAPARTHY SS	11KV VASUNDARA EXPRESS FEEDER(LC.NO.224)CHANDRAM CL	11KV	Gajwel	01.00	07.45	06.45		INSULATOR FAILED	-
10		ERRAVALLY SS	ERRAVALLY AGL FEEDER(LC.NO.26388)LAXMAN LM	11KV	Gajwel	00.00	13.00	13.00		DISK FAILED	-
11		WARGAL SS	WARGAL TOWN FEEDER	11KV	Gajwel	16.20	19.20	03.00		TREE BRANCH FALL OVER 11 KV	-
12		DUDEEDA SS	INDUSTARIAL FEEDER(LC.NO.21354) ILAIAH CL	11KV	Gajwel	12.00	14.00	02.00		DISK FAILED	-
13		MARPADAGA SS	SIRISINAGANDLA TOWN FEEDER (LC.NO37236)RAHEEM JLM	11KV	Gajwel	08.10	11.45	03.35		DISK FAILED	-
14		MD SAPUR	LINGAIPALLYTHANDA FEEDER(LC.NO.3510)NARSIMLU CL	11KV	Gajwel	07.00	11.00	04.00		DISK FAILED	-
15		ANAJIPUR SS	ANAJIPUR FEEDER(LC.NO.6203)NARSIMLU LM	11KV	Gajwel	13.22	14.34	01.10		DISK FAILED	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
16		Cheriyal	Sundaneninagar	11KV	Husnabad	01.40	09.35	07.55		Insulator Failed	-
17		Pandilla	Potlapally	11KV	Husnabad	00.30	01.50	01.20		Jumper Cut	-
18		Gouravelly	Gudatipally	11KV	Husnabad	03.00	09.00	06.00		Jumper cut	-
1	MDK	Bollaram - II	Rupa	11KV	Patancheru	10.25	11.35	01.10		B/D Due to Conductor Snapped	-
2		Pati	My Home	11KV	Patancheru	10.30	12.40	02.10		B/D Due to Insulator Failure	-
3		EPIP-I	Chaitanya	11KV	Sangareddy	08.55	10.50	01.55		B/D Due to Conductor Snapped	-
1	RR-S	Manikonda	Friends colony	11KV	IBRAHIMBAGH	17.15	21.55	04.40	EL/OL	11kv Disk Insulator Failed & 2no pin Insulator Failed at tulip garden	
2		Manikonda	Hanuman nagar	11KV	IBRAHIMBAGH	17.20	18.45	01.25	EL	Due to Rain	
3		Nanakaramguda	Manjeera	11KV	GACHIBOWLI	18.02	19.28	01.26	OL	Due to Rain, Pin Insulator flashover at Muppa	
4		Kokapet	Akshaya Patra	11KV	IBRAHIMBAGH	17.30	18.45	01.15	EL/OL	Due to Heavy Rain	
5		APPA	Himayath Sagar	11KV	RAJENDRA NAGAR	17.55	21.48	03.53	EL/OL	Tree branch fallen on line at NFC Colony	11KV Bank colony
6		Kismathpur	LV Prasad	11KV	RAJENDRA NAGAR	18.10	19.40	01.30	EL	Due to Heavy Rain	
7		Kismathpur	Vidya peetam	11KV	RAJENDRA NAGAR	17.55	20.20	02.25	EL	Due to Heavy Rain	
8		APPA	Darga	11KV	RAJENDRA NAGAR	18.50	21.20	02.30	EL/OL	Pole Damage at Sun Fuction hall	
9		Gaganpahad	Satamrai Industrial	11KV	RAJENDRA NAGAR	18.28	20.33	02.05	ELOL	Pin Insulator Failed at Satamrai Village	
10		Gaganpahad	Satamrai Industrial	11KV	RAJENDRA NAGAR	21.17	23.58	02.41	EL	Pin Insulator Failed at Satamrai Village	
1	RR-N	Subhash nagar	Saibaba nagar	11KV	MEDCHAL	09.22	11.38	02.16	EL/OL	Cable fault at Saibaba nagar	11KV Bank colony
2		Subhash nagar	Jairam nagar	11KV	MEDCHAL	20.13	21.29	01.16	EL	Due to Heavy Rain	
3		Kompally	Aparna	11KV	MEDCHAL	20.52	22.11	01.19	EL	Due to Heavy Rain	
4		Kompally	Dholari Dhani	11KV	MEDCHAL	20.53	23.04	02.11	ELOL	11kv Pin Insulaor Failed opposite Maha laxmi Enclave	
5		Kothapet	Kamala nagar	11KV	SAROORNAGAR	14.48	15.50	01.02	EL/OL	Disc Insulator failed at Samskruthi school	
6		Rajeev Swagruha	Jaipuri colony	11KV	SAROORNAGAR	16.57	18.29	01.32	EL	Due to Rain, Pin Insulator flashover at Bandlaguda	
7		Byramalguda	Durga nagar	11KV	CHAMPAPET	18.00	19.10	01.10	OL	11KV Line snaped at Ayyappa temple	
8		Saheb nagar	Sachivalaya nagar	11KV	CHAMPAPET	17.15	18.40	01.25	EL	Due to Rain, Disc Insulator failed near Red water tank	
9		Mother dairy	Swathi residency	11KV	SAROORNAGAR	17.20	18.45	01.25	EL	Due to Rain, Insulator failed at CSR colony Modi builders & Post off Insulator failed at Double bedroom house	
1		Kowkur	Barshipet	11KV	SAINIKPURI	00.20	02.00	01.40	EL	Insulator replaced & AB Switch direct at Darga	
2		CRPF	Chennapur	11KV	KEESARA	00.05	02.05	02.00	EL	Insulator flashover at Mallegowda	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
3	RR E	Balaji nagar	Laxmi Narsimha	11KV	KEESARA	07.46	08.46	01.00	EL	Pin Insulator failed at Laxmi Narsimha gutta		
4		Balaji nagar	Dental College	11KV	KEESARA	20.35	21.54	01.19	EL	Due to Heavy Rain		
5		Balaji nagar	Santhosh Nagar	11KV	KEESARA	20.40	22.00	01.20	EL	Due to Heavy Rain		
6		Cherlapally-5	Rampally	11KV	KEESARA	20.20	22.40	02.20	EL	Due to Heavy Rain		
7		Moulali	Kailasagiri	11KV	SAINIKPURI	20.30	22.00	01.30	ELOL	Conductor Snapped at Sagar Apartment		
8		Cherlapally-2	ICCOM	11KV	SAINIKPURI	20.30	21.45	01.15	EL	Due to Heavy Rain		
9		Moulali	Moulali	11KV	SAINIKPURI	20.40	23.55	03.15	EL	3no Post of Insulator failed & Repair at Rao Nagar		
10		Sainikpuri	Ramalayam	11KV	SAINIKPURI	21.48	22.55	01.07	EL	Tree branch fallen on line at JJ Colony		
11		Sainikpuri	Saipuri	11KV	SAINIKPURI	22.48	02.07	03.19	EL	11kv Pin Insulaor Failed at Laxmipuram Colony		
1		HYD N	Kalyan Nagar	Vengalrao Nagar	11KV	X	17.48	18.54	01.06	EL	Tree branches fallen on lines at Post office	-----
2			Jubilee Hills	P.E.I. OH	11KV	X	17.42	19.06	01.24	EL,OL	No Visible Fault due to heavy Rain	-----
3	Ravindra Society		C.O.D.	11KV	X	17.55	19.34	01.39	EL	No Visible Fault due to heavy Rain	-----	
4	I.D.P.L.		Bala Nagar	11KV	VI	17.40	19.35	01.55	OL-Bph	No Visible Fault due to heavy Rain	-----	
5	Sanjeevaiah Park		Police Lines	11KV	C-VI	15.33	18.01	02.28	All Indication	No Visible Fault due to heavy Rain	Arranged B/F on 11KV Pared Ground feeder	
6	New Bowenpally		Reliance Villa	11KV	VI	17.57	20.01	02.04	EL,OL	Pin Insulator flash over at Sancharpuri Colony	-----	
7	Ravindra Society		Daspalla	11KV	X	17.45	20.22	02.37	EL,OL	No Visible Fault due to heavy Rain	Arranged B/F on 11KV IOA feeder	
8	Ravindra Society		Benz Show Room	11KV	X	18.50	20.30	01.40	EL,OL	No Visible Fault due to heavy Rain	Arranged B/F on 11KV Art Gallery fdr	
9	Kalyan Nagar		Yousufguda	11KV	X	19.45	21.42	01.57	All Indication	Sectionlizer jumper cut at Moon Rock Hotel	-----	
10	Prasasan Nagar		B.N.R Hills	11KV	X	18.05	22.10	04.05	EL,OL	Pin Insulator flash over at Rahul Reddy, Plot No.14	-----	
11	Macha Bollarum		Ayyappa Nagar	11KV	C-VI	20.42	23.20	02.38	Auto Reclouser	Pin Insulator flash over at Elukala Basti	(22:32 Hrs) partial loads added on 11KV Mangapuram fdr & remaining loads added on 11KV Father Balaiah Nagar fdr	
12	Tirumalagiri		Srinagar Colony	11KV	C-VI	22.10	00.35	02.25	EL	Pin Insulator flash over at Srinagar Colony	Arranged B/F on 11KV Chinna Kamela fdr	
13	Macha Bollarum		Radhasath Sang	11KV	C-VI	23.50	02.55	03.05	Auto Reclouser	No Visible Fault	-----	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Karwan	Tallagada Cable	11KV	IX	17.35	19.15	01.40	EL,OL	Pin Insulator flash over at Annapurna Temple	-----
2		Osm. Hospital	Osmangunj	11KV	IX	23.00	00.30	01.30	EL	500KV DTR HG fuse fault at Kishan Gunj	(23:40 Hrs) partial loads added on 11KV M J Market fdr & remaining loads added on 11KV Feelkhana fdr
1	HYD C	Golconda	Aditya Nagar OH	11KV	VII	17.24	18.55	01.31	EL	No Visible Fault due to heavy Rain	-----
2		Indira Park	Talla Basthi	11KV	I	17.19	18.40	01.21	EL	No Visible Fault due to heavy Rain	Arranged B/F on 11KV Goshala fdr
3		Narayanguda	Preventive Medicine	11KV	II	17.30	19.00	01.30	EL	No Visible Fault due to heavy Rain	-----
4		Golconda	Shaikpet W.W.	11KV	VII	17.40	18.51	01.11	EL	No Visible Fault due to heavy Rain	-----
5		Chilkaiguda	Parsigutta	11KV	II	17.45	19.20	01.35	EL	Faulty Loads of 11KV 44 Bus Stop feeder	-----
6		Golconda	Narayanamma College	11KV	VII	18.06	20.00	01.54	EL,OL	No Visible Fault due to heavy Rain	-----
7		S.D.Hospital	Khadi Bandar	11KV	VII	17.15	18.46	01.31	EL	No Visible Fault due to heavy Rain	-----
8		Toli Chowki	B.S.N.L.	11KV	VII	17.30	20.05	02.35	EL	Faulty Loads of 11KV Hakimpet feeder	-----
9		Golconda	Aditya Nagar OH	11KV	VII	18.57	22.00	03.03	EL	Tree fallen on lines at SBI, Samatha Colony	-----
10		Bathakammakunta	D.D Colony	11KV	II	23.03	02.18	03.15	OL-Rph	Big tree fallen on lines near O.U Gate	-----