

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550	1	7	1	7	1	7			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		7		7		7			
	Total	606	3055	1	21	1	21	1	21	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	13	1	13	1	13			
2	NLG	144	988		9		9		9			
3	MDK	107	933	5	1	5	1	5	1			
4	SDPT			2	13	2	13	2	13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	8	36	8	36	8	36	0	0	
	Grand Total	1082	6468	9	57	9	57	9	57	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.09.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Thirumalaipally	Kothakota	33KV	Wanaparthi	03.40	04.45	01.05	E/L	Due to Heavy Rain	Kothakota	-
1	MDK	Kandi	BDL	33KV	Sangareddy	01.30	11.20	09.50		B/D Due to Insulator Failure	BDL	-
2		Kandi	HFC-II	33KV	Sangareddy	11.05	14.45	03.40		BD due to Pole damage	HFC-II	-
3		Kandi	Isnapur	33KV	Sangareddy	03.30	10.25	06.55		B/D Due to Insulator Failure	Isnapur	-
4		Narayankhed	Sirgapur	33KV	Jogipet	00.00	06.50	06.50		B/D Due to Insulator Failure	Sirgapur	-
5		Narayankhed	Sirgapur	33KV	Jogipet	15.45	18.15	02.30		B/D Due to Insulator Failure	Sirgapur	-
1	SDPT	Gajwel	Express	33KV	Gajwel	20.40	00.00	03.20		Due to Heavy Rain	Express	Medhinipur SS
2		Thunki Bollaram	Thunki Bollaram	33KV	Gajwel	00.12	05.15	05.03		B/D Due to Insulator Failure	Thunki Bollaram	-
1	RR N	132KV Malkaram	33KV Ratnalayam	33KV	Medchal	17.10	20.58	03.48	BD	33KV Line AB Switch Opened at BITS	33KV Ratnalayam	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 17.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gundumal	Ameenkuntla	11KV	Narayanapet	19.30	21.30	02.00		Break Down Due to 11KV Disc fail	-
2		Maddur	Maddur	11KV	Narayanapet	21.30	22.20	00.50		Break Down Due to 11KV Disc fail	-
3		Vennached	Vennached	11KV	Narayanapet	14.36	15.26	00.50		Break Down Due to tree fallen down on 11KV line	-
4		Jaklair	Bondalkunta	11KV	Narayanapet	09.00	11.00	02.00		Break Down due to 11KV Disc failure	
5		Uttoor	Pagdimarry	11KV	Narayanapet	04.35	09.50	05.15		Break Down due to heavy rain 3 poles 11 KV damaged	
6		Uttoor	Pagdimarry	11KV	Narayanapet	10.10	11.20	01.10		Break down due to heavy rain and wind DTR disconnection near bridge	
7		CHINNAJATRAM	ANTHWAR	11KV	Narayanapet	05.38	12.01	06.23		BREAKDOWN DUE TO DISC FAILURE, HEAVY RAIN OCCURRED CLEAR THE BREAKDOWN IN THE FIELD	
8		DHANWADA	DHANWADA TOWN	11KV	Narayanapet	04.40	06.10	01.30		BREAKDOWN DUE TO DISC FAILURE	
9		NARAYANPET	CIVIL1	11KV	Narayanapet	07.15	09.25	02.10		BREAKDOWN DUE TO WIND AND GALE	-
10		NARAYANPET	CIVIL1	11KV	Narayanapet	10.30	12.39	02.09		BREAKDOWN DUE TO DISC FAILURE	-
11		KONDAPUR	KISTAPUR	11KV	Narayanapet	11.00	12.00	01.00		BREAKDOWN DUE TO DISC FAILURE	-
12		EKLASPUR	CHITTANOOR	11KV	Narayanapet	07.30	10.30	03.00		BREAKDOWN DUE TO POLES DAMAGE	-
13		APPAKPALLY	SATYA SAI	11KV	Narayanapet	05.45	09.30	03.45		BREAKDOWN DUE TO DISC FAILURE	-
1	NLG	G.Yedavally	Kurampally	11KV	Nalgonda	07.00	08.25	01.25	EL	Insulator failed	-
2		Arlagaddagudem	Chinna Suraram	11KV	Nalgonda	09.35	11.20	01.45	EL	Jumper cut	-
3		Velugupally	Iethavarigudem	11KV	Nalgonda	11.00	12.15	01.15	EL	Insulator failed	-
4		Gundepuri	Bandlapally	11KV	Suryapet	02.30	06.40	04.10	E/L	Insulator Failed	-
5		Bopparam	M.Kothagudem	11KV	Suryapet	01.30	06.10	04.40	E/L	Insulator Failed & Tree branch fallen on the line	-
6		Palakeedu	Nagireddy gudem	11KV	Huzurnagar	03.00	07.30	04.30	EL	Jumper cut	-
7		Venkiryala	Padamatisomaram	11KV	Bhongir	08.34	13.34	05.00	EL/OL	Car Damedged 11 KV Pole dammage at Raghavapuram village(new Pole Erction)	-
8		Anajipur	Anajipur	11KV	Bhongir	04.41	07.50	03.09	EL/OL	100 kva DTR Failed near Bujipuram village.	-
9		S.Lingotam	S.Lingotam	11KV	Choutuppal	10.15	14.30	04.15	EL/OL	11kv Line snpeed near S.Lingotam Village	-
1	MDK	Dundigal	DRF	11KV	Patancheru	08.45	12.10	03.25		B/D Due to Insulator Failure	-
1	SDPT	Guruvannapet	Posanpally	11KV	Husnabad	18.30	19.06	00.36		HT/LT Line	-
2		BANGLA VENKATAPUR	BANGLA VENKATAPUR	11KV	Gajwel	18.01	20.05	02.04		INSULATOR FAILED	
3		GUJWAL&PREGNAPUR	MUTRAJPALLY	11KV	Gajwel	13.28	15.59	02.39		DISC FAILED	
4		PAMULAPARTHI	PAMULAPARTHI	11KV	Gajwel	12.00	12.35	00.35		DISC FAILED	
5		PAMULAPARTHI	PAMULAPARTHI	11KV	Gajwel	15.25	15.50	00.25		DISC FAILED	
6		GOWRARAM	PATHUR	11KV	Gajwel	13.20	13.40	00.20		INSULATOR FAILED	
7		VANTIMAMIDI	SHUT DOWN	11KV	Gajwel	15.25	16.20	00.55		11 KV CLAMPS CHANGED	
8		DOULTHABAD	LINGARAJPALLY	11KV	Gajwel	07.35	09.49	02.14		DISC FAILED	
9		RAYAPOLE	THIMMAKKAPALLY	11KV	Gajwel	23:15	7:15	08.00		DISC FAILED	
10		Pullur	Pullur	11KV	Siddipet	09.04	12.13	03.09		B/D (DISC FAILED)	
11		Narayanraopet	Veerapagudi	11KV	Siddipet	09.21	11.30	02.09		B/D (DISC FAILED)	
12		Mirdoddy	Veerareddy pally	11KV	Siddipet	00.00	08.55	08.55		B/D (DISC FAILED)	
13		Mirdoddy	Jangapally	11KV	Siddipet	21.20	00.00	03.40		Still Continue Break Down	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Nanakramguda	Karway	11KV	Gachibowli	01.22	02.52	01.30		11KV Breaker outgoing AB Switch female post of insulator failed in SS	-
2		Aziznagar	Srinidhi	11KV	Ibrahimbagh	10.20	13.20	03.00		11KV Pin insulator failed at Meesalaraju Thota	-
3		Ibrahim Bagh	Osman sagar	11KV	Ibrahimbagh	17.55	20.30	02.35		11KV line cut at Royal functionhall	-
1	RR N	Jeedimetla-I	Nitco	11KV	Jeedimetla	12.10	13.30	01.20	BD	11kv line Jumper Cut at Indian Gas ,(Due to Rain)	-
2		Jeedimetla-I	Raghava	11KV	Jeedimetla	12.10	13.30	01.20	BD	11kv line Jumper Cut at Indian Gas ,(Due to Rain) {Saftypurpose}	-
3		Gagillpur	Sundhara Chaithanya Ashramam	11KV	Jeedimetla	16.10	18.00	01.50	BD	PTR-II, Limbu Failed at SS ,B/F Thandda Feeder	-
4		Subhash Nagar	Jairam Nagar	11KV	Medchal	14.05	14.47	00.42	BD	11KV AB Cable failed at HP Petrol bunk	-
5		Aliabad	Bommarajpet	11KV	Medchal	17.48	19.00	01.12	BD	Tripped on EL Indication(Due to rain)No Fault	-
6		Bandamadaram	Barmajiguda	11KV	Medchal	19.25	21.40	02.15	BD	11KV Disc Failed at Balaji Poultry farm,Nuthankal	-
7		Medchal	IDA-I	11KV	Medchal	20.10	21.05	00.55	BD	Tree fallen on the 11KV Line near BSNL Office	-
1	RR E	Sainikpuri	Vijayapuri	11KV	Sainikpuri	00.37	03.30	02.53		11Kv Disk failed at Sainikpuri (Artisian Raju)	-
2		Cherlapally-IV	BN Reddy Nagar	11KV	Sainikpuri	08.34	09.50	01.16		Maruthi Plastic Insuletor fail BN Reddy Nagar (AE)	-
3		VP Nagar	Brundhavan Colony	11KV	Sainikpuri	17.29	18.37	01.08		Tree branches fallen on 11Kv line at Brundhavan Colony (LM Chandra Shekar)	-
4		Chakripuram	Ayyappa	11KV	Keesara	00.40	03.15	02.35		11KV Disc failed at Tharapuri Colony	-
1	HYD N	H.A.L	Lokesh Mechines	11KV	VI	03.33	04.53	01.20	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Indian Rubber feeder
2		I.D.P.L	Bala Nagar	11KV	VI	14.20	16.15	01.55	EL,OL	Line AB Switch Jumper cut at Narsapur X-Roads	-----
3		Kalyan Nagar	Vengalrao Nagar	11KV	X	18.25	20.30	02.05	EL,OL-Rph	Tree branches fallen on lines at Kalyan Nagar Singal (2No. DTR's Kept Off)	-----
4		Road No.22	Obul Reddy	11KV	X	19.45	22.15	02.30	EL	Cable fault at Road No.22	Arranged B/F on 11KV Road No.5 fdr
1	HYD C	Zamistanpur	Laxmi Narayan Nagar	11KV	II	09.52	11.00	01.08	All Indication	AB Switch sparking at L.N.Nagar Nala	-----
2		Indira Park	Vivek Nagar	11KV	I	16.35	17.55	01.20	EL	Pin Insulator flash over at Ashok Nagar Cheman	-----
3		Gudimalkapur	Murad Nagar	11KV	VII	16.45	17.55	01.10	EL	-----	Arranged B/F on 11KV Jeevan Kalyan Ngr fdr