

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550		13		13		13			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044		10		10		10			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>33</b>	<b>0</b>	<b>33</b>	<b>0</b>	<b>33</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	2	6	2	6	2	6			
3	MDK	107	933	2	1	2	1	2	1			
4	SDPT			1	14	1	14	1	14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>5</b>	<b>21</b>	<b>5</b>	<b>21</b>	<b>5</b>	<b>21</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>5</b>	<b>54</b>	<b>5</b>	<b>54</b>	<b>5</b>	<b>54</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 20.09.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Miryalguda	Tripuraram	33KV	Miryalguda	17.37	20.40	03.03	E/L	Conductor snapped at PD Pally	Tripuraram	-
2		Thungathurthy	Ravulapally	33KV	Suryapet	00.00	07.40	07.40	E/L	Insulators Flashover	Ravulapally	-
1	MDK	Gummadidala	AFA	33KV	Patancheru	15.30	16.40	01.10		BD due to Insulator failed	AFA	-
2		Narayankhed	Poosalpad	33KV	Jogipet	18.47	22.14	03.27		BD due to Jumper cut	Poosalpad	-
1	SDP	Mustyala	Komuravelly	33KV	Husnabad	02.30	08.55	06.25		Tree Fallen on line	Komuravelly	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 20.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cherkupally	Thungathurthy	11KV	Nalgonda	12.10	13.15	01.05	E/L	11 KV Jumper cut	-
2		Thurkapally	M.Gouraram	11KV	Nalgonda	07.56	09.56	02.00	E/L	Tree branches fallen on line	-
3		Kannekal	GK Palem	11KV	Miryalaguda	10.15	12.30	02.15	E/L	Tree branch fallen and cleared in Kannekal	-
4		Agamothkur	Agamothkur	11KV	Miryalaguda	06.00	10.00	04.00	E/L	Jumper touch Cross arm rectified	-
5		AD Pally	Veerlapalem	11KV	Miryalaguda	15.40	16.45	01.05	E/L	Jumper cut and rectified at Mekalagutta	-
6		Thungathurthy	Vempaty	11KV	Suryapet	02.40	07.30	04.50	E/L	Jumper cut	-
1	MDK	Fasalwadi	Rythunagar	11KV	Sangareddy	10.00	12.02	02.02		BD due to Disk failed	-
1	SDP	Husnabad	Madatha	11KV	Husnabad	00.00	10.10	10.10		EL Heavy due to rain	-
2		Komuravelly	Inapur AGL	11KV	Husnabad	18.55	19.45	00.50		Heavy due to rain	-
3		Komuravelly	Kistampet	11KV	Husnabad	20.10	23.59	03.49		Disk Fail	-
4		Bekkal	Kutigal	11KV	Husnabad	09.36	07.00	08.20		Disk Fail	-
5		Arjunpatla	Simply Fresh	11KV	Husnabad	11.10	12.20	01.10		Lighting Arrester Blast	-
6		Gajwel SS	BV pur feeder	11KV	Gajwel	9:30	16:00	06.30		2 Times Post Off Insulater/Battery Charger Fail	-
7		Markook Ss	Markook Town LC;22007	11KV	Gajwel	05.24	06.44	01.20		Pole Broken	-
8			Markook Twon LC:22008	11KV	Gajwel	11.48	12.35	00.47		Pole Broken	-
9		Pamulaparthy SS	Ippalagudem Feeder	11KV	Gajwel	18.25	19.35	01.10		Insulator Fail	-
10		Gowraram SS	Gowraram Town I LC:40377 (Kistaiah LM)	11KV	Gajwel	16.30	17.30	01.00		Tree Branch Fallen	-
11		Mulugu SS	Mandal HQ feeder LC:27219 (dhanpal Reddy LM)	11KV	Gajwel	07.30	10.20	02.50		HT By LT	-
12		Gurralla Sofa ss	Ramaram Feeder LC:10654 (Bhoopal CL)	11KV	Gajwel	16:00	17:30	01.30		Leened Pole Work	-
13		Begumpet SS	Begumpet Feeder LC:12774 (Venugopl LM)	11KV	Gajwel	17:40	18:34	00.54		Disk Fail	-
14		Ramsagar SS	Ramsagar Feeder LC:6702 (Sathaiah CL)	11KV	Gajwel	9:15	10:15	01.00		Disk Fail	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Kokapet	Babukhan	11KV	IBRAHIMBAGH	21.35	22.50	01.15	EL	Due to heavy rain	-
2		Gaganpahad	REC	11KV	RAJENDRA NAGAR	07.47	09.55	02.08	EL/OL	LAB Switch Open at BK Garden (11KV Pole Damaged Due to Lorry Dashed at BK Garden)	-
3		Mallapur	Osman nagar	11KV	KANDUKUR	15.05	18.10	03.05	EL	Tree branches touching line at Osman nagar	-
1	RR N	Jagathgirigutta	IDA	11KV	Medchal	03.50	05.10	01.20		11KV Cable Endkit failed at Sanjaypuri Colony	-
2		Subhash Nagar	Padma Nagar	11KV	Medchal	23.45	00.52	01.07		11KV Disc failed and replaced at Bavitha Apartment	-
3		Bommarajpet	Bommarajpet	11KV	Medchal	01.30	03.20	01.50		11KV Pin Insulator failed at Bommarajpet Village	-
4		GP Pally	Maisammaguda	11KV	Medchal	00.00	01.20	01.20		Tree Fallen on 11KV Line at Satyam Computers	-
5		GP Pally	GP Pally	11KV	Medchal	23.15	00.30	01.15		Tree fallen on 11KV Line at Ayodhaya X Road	-
6		GP Pally	Maisammaguda	11KV	Medchal	09.00	10.00	01.00		Tree Fallen on 11KV Line at Mallareddy Womens College	-
7		Laxmapur	MC Pally	11KV	Medchal	18.40	19.35	00.55		11KV Disc failed at MC Pally	-
8		Bowrampet	Bowrampet(V)	11KV	JEEDIMETLA	21.32	22.32	01.00	OL	ABS open at Obileshu school(Tree fallen on 11Kv line & Disc failed)	-
9		Maruthi Nagar	Yadav nagar	11KV	SAROORNAGAR	17.04	18.14	01.10	EL/OL	No visible fault	-
10		Auto nagar	AIR	11KV	SAROORNAGAR	14.42	18.20	03.38	EL/OL	Tree branches fallen on line at AIR Station gate	-
11		Saheb nagar	Vaidehi Nagar	11KV	CHAMPAPET	15.36	17.10	01.34	EL/OL	Tree branches fallen on line at Hariharapuram cherukuri building	-
12		Auto nagar	Siris	11KV	SAROORNAGAR	16.13	20.00	03.47	EL	11KV Pin insulator failed at Saraswathi nagar,Rainbow hospital	-
13		Hayath nagar	Mother dairy	11KV	SAROORNAGAR	16.40	19.20	02.40	EL	11KV Pin insulator failed at Lecturers colony	-
1	RR E	Moula-Ali	Malkajgiri	11KV	Sainikpuri	00.35	01.35	01.00		11Kv Polimer Disk failure at SS out side (AE/OP)	-
2		Kushaiguda	Rukminipuri	11KV	Sainikpuri	13.05	14.24	01.19		11Kv line cut at APISC Colony (L.Insp Venkateshwarulu)	-
3		VP Naagr	Brundhavan Colony	11KV	Sainikpuri	20.10	21.18	01.08		11KV Disk failed at Sapthagiri Colony (Artisian Anil)	-
4		Moula ali	Spectra	11KV	Sainikpuri	20.00	23.18	03.18		11KV Pin insulator Failed Near IDA Moula ali Due to Heavy Rain	-
5		Pocharam	Jodimetal	11KV	Keesara	08.30	09.40	01.10		Insulator fail at Jodimetal	-
6		Kowkur	Barshipet	11KV	SAINIKPURI	00.35	01.35	01.00	EL	Polymer disk Failed at SS Outside	-
7		Moulali	Venkateshwara Nagar	11KV	SAINIKPURI	13.03	14.24	01.21	EL/OL	Two 11Kv Lines Snapped at APIIC Colony	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Chinna Thokatta	Park View Enclave	NT	VI	02.30	03.31	01.01	OL-R&Yph	No Visible Fault	-----
2		Road No.13	Gowri Shanker Nagar	NT	X	08.05	09.17	01.12	EL	AB Cable fault at Gowri Shanker Nagar	Arranged B/F on 11KV Babu Khan Chambers fdr
1	HYD C	Golnaka	Moulana Azad Nagar	11KV	II	00.47	02.24	01.37	EL,OL	No Visible Fault	Arranged B/F on 11KV Tourist Hotel fdr
2		Nizam College	Big Bazaar	11KV	I	03.35	05.10	01.35	EL,OL	Bus failed at R.M.U	Arranged B/F on 11KV Puthlibowli fdr
3		Golconda	Darga Cable	11KV	VII	05.05	06.08	01.03	EL,OL-Bph	No Visible Fault	Arranged B/F on 11KV O.U Colony & 11KV Aditya Nagar UG Cable fdrs
4		Fever Hospital	BKP Bus Depot	11KV	II	16.15	17.35	01.20	EL	Faulty DTR at Dhanthapallay Apts	-----
5		Indira Park	Kuchipudi	11KV	I	16.05	17.28	01.23	EL	No Visible Fault	Arranged B/F on 11KV R.K.Mutt fdr
6		Golconda	Mothimahal	11KV	VII	20.05	21.52	01.47	OL	Insulator flash over at Masjid	-----
7		Indira Park	Datta Nagar	11KV	I	22.45	23.55	01.10	EL	RMU fault at Street No.13	-----
8		Bathukamma Kunta	Shivam	11KV	II	22.55	00.10	01.15	EL	Pole fell down at Ratna Deep Super Market	5No DTR's Kept off