

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		18		18		18			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	34	1	34	1	34	0	0	
	Grand Total	1082	6468	1	39	1	39	1	39	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.09.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Pashamailaram	INOXAIR	33kv	Sangareddy	08.00	09.00	01.00		B/D Due to Jumper Cut	INOXAIR	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 21.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Midjil	Venco	11KV	Jadcherla	00.00	05.00	05.00		11 KV Insulator Failed Near Midjil	-
2		Midjil	Veljal	11KV	Jadcherla	00.00	08.00	08.00		11 KV Disc Failed Near Marla Bai Thanda	-
3		Balanagar	CBR	11KV	Jadcherla	09.05	10.30	01.25		11 KV Disc Failed near Nerallapally (V)	-
4		Maddur	Renivatla	11KV	Narayanapet	07.30	12.30	05.00		Due to 11 KV Insulator Failed	-
1	NLG	Narketpally	Mandra	11KV	Nalgonda	04.00	07.00	03.00	EL	11 KV Jumper Cut	-
2		Thurkapally	Hydalapoor	11KV	Nalgonda	13.14	13.45	00.31	EL	11 KV Jumper Cut	-
3		Palem	Ogodu	11KV	Nalgonda	13.00	15.00	02.00	EL	Tree Branches fallen on the line	
4		DAMARCHERLA	Watchya GP	11KV	Miryalaguda	12.30	13.20	00.50	EL/OL	Line Snapped due to Gale/wind	
5		KAMAREDDYGUDEM	KAMAREDDYGUDEM	11KV	Miryalaguda	06.00	11.40	05.40	EL/OL	Jumper Cut rectified	
6		Ghanapuram	G.B.Pally	11KV	Devarakonda	06.00	11.50	05.50	EL	11 KV Insulator failed	
7		Mellavai	Fakeerapuram	11KV	Devarakonda	06.30	11.40	05.10	EL	11 KV Insulator failed & 11 Kv Line Cutt	
8		Velugupally	Velugupally	11KV	Suryapet	09.30	12.50	03.20	EL	Insulator flashover	
9		Gaddipally	Kuthubshapuram	11KV	Huzurnagar	03.20	08.15	04.55	EL	Line Snapped	
10		Janphad	Sunyaphad	11KV	Huzurnagar	06.00	13.04	07.04	EL	Line Snapped	
11		Mattapally	Sulthanpuram Thand	11KV	Huzurnagar	13.50	14.55	01.05	EL	Line Snapped	
12		Munagala	Nellamari	11KV	Huzurnagar	11.40	13.50	02.10	EL	DTR defect	
13		Ch.Laxmapuram	Malkapur Agl	11KV	Bhongir	04.00	10.00	06.00	EL/OL	11kv Disc Failed near Mlakpur Village	
14		Venkatapuram	Dathaipally	11KV	Bhongir	03.30	11.00	07.30	EL/OL	11kv Disc Failed near Dathaipally	
15		Rajapeta	Pamukunta Agl	11KV	Bhongir	03.20	07.55	04.35	EL/OL	11 kv Line snapped near Pamukunta village	
16		Choutuppal	Town 2	11KV	Choutuppal	11.10	12.45	01.35	EL/OL	11kv Line Snapped near vegetable market Choutuppal Town	
17		Juloor	Kapraipally	11KV	Choutuppal	03.00	08.20	05.20	EL/OL	11 kv Insulator failed near Kapraipally village	
18		Jublakpally	Vankamamidi	11KV	Choutuppal	05.00	07.20	02.20	EL/OL	2 no's 11 kv Insulators failed near Darmareddypally village.	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Anrich Bollaram	Town-II	11KV	Sangareddy	17.00	17.40	00.40		B/D Due to tree branch fallen the line	-
2		Patancheru Town	Shanthinagar	11KV	Sangareddy	14.50	15.30	00.40		B/D Due to tree branch fallen the line	-
3		EPIP-II	Marigold	11KV	Sangareddy	07.45	08.55	01.10		B/D Due to tree branch fallen the line	-
1	SDPT	Gandipally	Ramavaram X-press	11KV	Husnabad	05.05	08.05	03.00		Tree Branches fallen on the Line	
2		Dharmaram	Potharam	11KV	Husnabad	09.40	11.15	01.35		Line fault	
3		Guruvannapeta	Thapasally	11KV	Husnabad	01.00	06.10	05.10		Heavy rain	
4		Gambeerpur	Gambeerpur	11KV	Siddipet	05.20	07.40	02.20		B/D 11KV Disk Fail Lc no. 28764	
5		SINGATAM	SINGATAM	11KV	Gajwel	08.00	11.00	03.00		11 KAVA LINE CUT	
6		KODAKANDLA	KODAKANDLA AGL	11KV	Gajwel	14:30	16:40	1:10		BREAK DOWN (94920 81482)	
7		THUNIKI BOLLARAM	Narsapur, Achaipally, Dasarlapally feeders	11KV	Gajwel	01.35	08.05	06.30		LV CT FAILED (94920 80966)	
8		GURRALA SOFA	WADDEPALLY	11KV	Gajwel	16.03	17.25	01.22		11KVA JUMPER CUT	
9		BEGUMPET	BEGUMPET	11KV	Gajwel	09.00	10.45	01.45		11KVA DISK FAILED	
1	RR N	Rajabollaram	Rajabollaram	11KV	Medchal	07.15	10.20	03.05	BD	Tree Branch fallen on the 11KV Line at Monark Godam Backside	-
1	HYD N	Gunrock	Medchal	11KV	C-VI	13.32	15.46	02.14	EL,OL	2No. DTR's I/C Cable fault at Manasa Sarovar Hills - II	(2No. DTR's Kept Off)
2		Pragatools	Asbestos Hills	11KV	VI	15.38	16.54	01.16	EL,OL	AB Cable End Kit failed at Sanjeevaiah Nagar	(1No. DTR Kept Off)
3		Pragatools	Rasool Pharma	11KV	VI	21.02	23.05	02.03	EL	DTR fault at Plot No.B-11	-----
4		Bowenpally	Jaya Nagar	11KV	VI	22.40	23.45	01.05	EL,OL-Bph	DTR fault at Vittal Nagar	-----