

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 1 | | 1 | | 1 | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 0 | 4 | 0 | 4 | 0 | 4 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 1 | 4 | 1 | 4 | 1 | 4 | | | |
| 2 | NLG | 144 | 988 | | 5 | | 5 | | 5 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | 2 | | 2 | | 2 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 11 | 1 | 11 | 1 | 11 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 1 | 15 | 1 | 15 | 1 | 15 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 22.09.2020

Circle-wise 33KV Breakdowns

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MBNR | Kothur | Thimmapur | 33KV | Shadnagar | 16.05 | 18.20 | 02.15 | | Tripped Coil Replaced & Breaker Closing problem | | NO |

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 22.09.2020

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|-----------------------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Gundumal | Gundumal Agl | 11KV | Narayanpet | 02.00 | 05.00 | 03.00 | | 11KV Line cut Near Venkateshwara Temple Gundumal Town | - |
| 2 | | Gundumal | Appaipally | 11KV | Narayanpet | 09.00 | 09.30 | 00.30 | | 11KV Line cut Near Dorepally Anjappa filed | - |
| 3 | | Kosgi | Bhogaram | 11KV | Narayanpet | 15.20 | 17.10 | 01.50 | | Due to Heavy gail and wind, 11KV Disc Fail | - |
| 4 | | Utkoor | Pagidimarry | 11KV | Narayanpet | 10.35 | 11.40 | 01.05 | | Due to Heavy Gail and wind, 11KV Disc Fail | - |
| 1 | NLG | GT Giri | GT Giri | 11KV | Suryapet | 09.02 | 10.50 | 01.48 | E/L | 11Kv Jumper cut | - |
| 2 | | T Giri | Thonda | 11KV | Suryapet | 11.50 | 14.27 | 02.37 | E/L | 11Kv Insulator flashover | - |
| 3 | | Gaddipally | Kutubshapuram | 11KV | Huzurnagar | 01.35 | 07.10 | 05.35 | E/L | 11Kv Line Snapped | - |
| 4 | | Mattampally | Errajelu | 11KV | Huzurnagar | 10.35 | 11.35 | 01.00 | E/L | 11Kv Jumper cut | - |
| 5 | | Vemulkonda | Chitthapuram | 11KV | Choutuppal | 11.50 | 16.10 | 04.20 | EL/OL | 11kv Insulator Failed near Chitthapuaram | - |
| 1 | SDPT | Peddachepyala | Alwal | 11KV | Siddipet | 12.46 | 13.51 | 01.05 | | B/D Disk fail | - |
| 2 | | MD SHAPUR | INDUPRIYAL (Mahipalreddy LM/3523) | 11KV | Gajwel | 07.20 | 12.36 | 05.16 | | INSULATOR FAILED | - |
| 1 | RR N | Aliabad | Majeedpur | 11KV | Medchal | 02.54 | 04.10 | 01.16 | EL | 11KV Pin Insulator failed & Replaced at HBL Pipes Company, Nadigadda | - |
| 1 | RR E | Narapally | Industrial | 11KV | Keesara | 04.34 | 05.14 | 00.40 | | Bird fallen on 11KV line at Narapally main road | - |
| 1 | HYD N | Addagutta | Addagutta | 11KV | C-VI | 15.48 | 17.08 | 01.20 | AR Tripped | AB Swith fault at Opp:Chicken Shop | - |
| 1 | HYD C | Langer House | Langer House Cable | 11KV | VII | 11.15 | 13.35 | 02.20 | EL,OL-Rph | Tree branches fallen on lines at Kedi Colony & Cable fault at R.M.U | - |