

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	4	1	4	1	4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	1	8	1	8	1	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	2	11	2	11	2	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.09.2020

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDP	Gajwel	Ahmedipur	33KV	Gajwel	03.45	07.55	04.10		BD (Jumper cut)	Ahmedipur	-
1	RR N	132KV Medchal	33KV Aliabad	33KV	Medchal	03.42	09.25	05.43	BD	No Visible Fault	33KV Aliabad	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 24.09.2020

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Ghanapuram	G.B.Pally	11KV	Devarakonda	06.30	10.20	03.50	E/L	11 KV Jumper Cutt	-
2		Marriguda	Marriguda	11KV	Devarakonda	04.00	07.06	03.06	E/L	HT/LT	-
3		Kodur	Kommala	11KV	Suryapet	06.00	09.20	03.20	E/L	Insulator flashover	-
1	RR N	Petbasheerabad	Vaishnavi Enclave	11KV	Medchal	16.10	16.35	00.25	BD	11KV Line AB Switch Opened at Deccan Kanta (11KV Line touched to LT Line at Surya Apartment)	-
2		Laxmapur	Laxmapur	11KV	Medchal	05.40	06.35	00.55	BD	11KV Line Cut & replaced at Laxmapur Cheruvu	-
3		Kistapur	Kistapur	11KV	Medchal	14.30	15.40	01.10	BD	11KV Line Cut & Paragon Company	-
4		RR Court	Shivaganga	11KV	SAROORNAGAR	13.43	14.53	01.10	EL	11KV Pin Insulator Failed at M.V.N School & Cloth Fallen on Line at Shiva Ganga Colony	-
1	RR E	NN Colony	Yellareddyguda	11KV	SAINIKPURI	08.28	09.42	01.14	EL/OL	Tree fallen on line at Vinayak nagar	-
1	HYD N	Osm.University	RTC Hospital	11KV	V	01.45	03.48	02.03	EL	Tree branches fallen on lines at N.I.N	-
2		LV Prasad Marg	Road No.14 (Partial fdr)	11KV	X	21.13	23.19	02.06	EL	RMU fault at B.N.R.Hills	-
1	HYD S	Devibagh	Rama Talkies	11KV	III	15.21	16.45	01.24	OL	Pin Insulator flash over & Conductor snapped at Rama Talkies	-