

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No. of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 2 | | 2 | | 2 | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | | 6 | | 6 | | 6 | | | |
| | Total | 606 | 3055 | 0 | 9 | 0 | 9 | 0 | 9 | 0 | 0 | |

Rural

| S.No | Circle | No. of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 1 | | 1 | | 1 | | | |
| 2 | NLG | 144 | 988 | | 6 | | 6 | | 6 | | | |
| 3 | MDK | 107 | 933 | 2 | 2 | 2 | 2 | 2 | 2 | | | |
| 4 | SDPT | | | | 7 | | 7 | | 7 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 2 | 16 | 2 | 16 | 2 | 16 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 2 | 25 | 2 | 25 | 2 | 25 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 27.09.2020

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MDK | Kandi | Alkabeer | 33KV | Sangareddy | 14:00 | 16:00 | 2:00 | | B/D due to Internal fault in Thoshiba Company | Alkabeer | No |
| 2 | | Jogipet | Dakur | 33KV | Jogipet | 08.05 | 13.45 | 05.40 | | B/D due to tree branches fallen on the line | Dakur | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---|
| 1 | MBNR | Malleboinpally | Bureddypally | 11KV | Jadcherla | 08.15 | 11.58 | 03.43 | | 11 Jumper phase to phase near Bureddypally (V) | No |
| 1 | NLG | Jalalpuram | Siddisamudram | 11KV | Suryapet | 11:52 | 15:00 | 3:08 | E/L | Insulator failed | No |
| 2 | | Urlugonda | Thummagudem | 11KV | Huzurnagar | 06.00 | 08.45 | 02.45 | EL | 11 KV Line snapped | No |
| 3 | | Ponugodu | Kotahgudem | 11KV | Huzurnagar | 04.00 | 07.15 | 03.15 | EL | 11 KV Jumper cut | No |
| 4 | | Aitipamula | Industrial | 11KV | Nalgonda | 11.43 | 15.20 | 03.37 | EL | Bird died on 11K line | No |
| 5 | | Narkatpally | M.Yedavally AGL | 11KV | Nalgonda | 13.50 | 16.30 | 02.40 | EL | 11KV wire cut | No |
| 6 | | Mothakondur | Vattor | 11KV | Bhongir | 13:45 | 15:30 | 1:45 | EL/OL | 11KV Insulator failed near Raikunta Pally Village | No |
| 1 | MDK | Dundigal | DRF | 11KV | Patancheru | 8:50 | 10:50 | 2:00 | | BD Due to Disk failed | No |
| 2 | | Gundla Machnoor | Industrial | 11KV | Patancheru | 12.50 | 13.20 | 00.30 | | B/D due to Conductor snapped | No |
| 1 | SDPT | SINGATAM | SINGATAM FEEDER | 11KV | Gajwel | 09:37 | 10:30 | 0:53 | | 11 KV Jumper cut | No |
| 2 | | PREGNAPUR | GUNDANNAPALLY AGL | 11KV | Gajwel | 11:10 | 14:09 | 2:59 | | 11KV Disc failed | No |
| 3 | | PAMULAPARTHY | INFRANAGAR | 11KV | Gajwel | 11.45 | 16.52 | 06.07 | | 11 KV Insulator failed | No |
| 4 | | ERRAVALLY | LIFT ERRIGATION | 11KV | Gajwel | 06.46 | 10.50 | 04.04 | | 11KV Disc failed | No |
| 5 | | DOULTHABAD | MANDAPUR | 11KV | Gajwel | 09.32 | 11.50 | 02.18 | | 11 KV Insulator failed | No |
| 6 | | Gouravelly | Gudatipally | 11KV | Husnabad | 04.00 | 11.00 | 07.00 | | Line snapped | No |
| 7 | | Dharmajipet | Lachapet | 11KV | Siddipet | 11:40 | 18:00 | 6:20 | | B/D for wire cut | No |
| 1 | RR N | Gowdavelly | IDA Gowdavelly | 11KV | Medchal | 13:05 | 14:25 | 1:20 | | 11KV Pole damaged by Lorry at Gnanapur Village | No |
| 2 | | Gowdavelly | Basaragadi | 11KV | Medchal | 13.05 | 14.25 | 01.20 | | 11KV Pole damaged by Lorry at Gnanapur Village | No |
| 1 | RR E | CRPF | Chennapur | 11KV | Keesara | 9:50 | 11:10 | 1:20 | | Tree fallen on on 11kv line at CRPF Boundary | No |
| 1 | HYD N | R.P Nilayam | Naga Devatha Temple | 11KV | C-VI | 03.25 | 06.00 | 02.35 | EL | R.M.U Cable fault at Naga Devatha Temple | No |
| 2 | | Prashanth Nagar | Time Tech | 11KV | VI | 21:20 | 23:10 | 1:50 | EL | DTR fault at Plot.No.10, near Amma Mess | No |
| 3 | | I.D.P.L | Bala Nagar | 11KV | VI | 22:15 | 0:30 | 2:15 | EL,OL-Rph | Bat fallen on lines at TC Bala Nagar & Breaker coil fault at SS | Arranged B/F on 11KV Shobana Colony for |
| 4 | | Clock Tower | Railway Reservation | 11KV | V | 23:20 | 0:25 | 1:05 | All Indication | RMU Fault at Pariki Basti | No |
| 1 | HYD C | Erramanzil | Red Rose | 11KV | I | 00.52 | 02.04 | 01.12 | EL,OL | DTR fault at Red Rose | No |
| 2 | | Bathkamma Kunta | Saibaba Temple | 11KV | II | 12.50 | 14.55 | 02.05 | OL-Rph | Suspected Cable fault | Arranged B/F on 11KV C.E.Colony for & 11KV Ahobilmutt for |