

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		6		6		6			
3	MDK	107	933	3	1	3	1	3	1			
4	SDPT			2	4	2	4	2	4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>5</b>	<b>15</b>	<b>5</b>	<b>15</b>	<b>5</b>	<b>15</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>5</b>	<b>19</b>	<b>5</b>	<b>19</b>	<b>5</b>	<b>19</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 01.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Meenakshi	33KV	Patancheru	07.05	13.30	06.25		B/D due to Conductor snapped	Meenakshi	-
2		Pashamailaram	BPL	33KV	Sangareddy	10.35	12.15	01.40		B/D due to Jumper cut	BPL	-
3		Zaheerabad	Zaheerabad	33KV	Jharasangam	17.22	18.50	01.28		B/D due to Jumper cut	Zaheerabad	-
1	SDPT	Siddipet	Narsapur	33KV	Siddipet	22.35	12.15	01.40		Due to line problem	Narsapur	Alternate Feeder 132/33 KV SS Siddipet in 33 KV Peddakodur Feeder Time 00:15
2		Thukkapur	Mirdoddy	33KV	Gajwel	19.40	21.40	02.00		Erection of 33 kv line	Mirdoddy	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 01.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Salkarpet	Reddypally	11KV	Narayanpet	10.00	11.10	01.10		Tree Branch Fallen on 11KV line Ganded Agl	-
2		Nancherla	Juvulapally	11KV	Narayanpet	12.00	14.00	02.00		11KV line Fallen at Desaipally(V)	-
3		Paspula	Satyaram	11KV	Narayanpet	12.40	15.50	03.10		Tree Branch Fallen on 11KV line at Satyaram(V)	-
4		Mogalmadka	Annasagar	11KV	Narayanpet	03.00	06.30	03.30		Tree Fallen on 11KV line at Annasagar(V)	-
1	NLG	Eduloor	Eduloor	11KV	Nalgonda	13.40	14.40	01.00	EL	11KV Jumper cut Under SS-13	-
2		Mellavai	Revally	11KV	Devarakonda	13.31	15.03	01.32	EL	11 KV HG Fuse Set Failed	-
3		Alair	Alair town	11KV	Bhongir	09.45	10.40	00.55	EL/OL	11 kv Insulator failed near BC.Colony Alair town	-
4		Paladugu	Dattappagudem	11KV	Bhongir	10.20	10.50	00.30	EL/OL	Single phase dtr Failed near Dattappagudem village	-
5		Athmakur	Koratikal	11KV	Bhongir	01.00	09.15	08.15	EL/OL	11 KV Disc failed near Koratikal village.	-
6		Choutuppal	Prathista Indl	11KV	Choutuppal	10.20	12.00	01.40	EL/OL	11kv Line Snapped near Choutuppal Town	-
1	MDK	Patancheru Town	High Power	11KV	Patancheru	11.20	11.50	00.30		B/D due to Jumper cut	-
1	SDPT	Husnabad	Pandilla Express Feeder	11KV	Husnabad	04.48	12.00	07.12		B.D DUE TO 11KV POLE DAMAGED	-
2		Guruvannapet	Posanpally	11KV	Husnabad	00.00	09.36	09.36		B.D DUE TO 11 KV LINE CUT	-
3		Chityal	Thadoor	11KV	Husnabad	00.00	00.00	00.00		B.D DUE TO LT LINE FALLEN ON DTR	-
4		Gagillapur	Gagillapur Town	11KV	Husnabad	11.16	00.28	03.36		B.D DUE TO TREE FALLEN ON 11KV LINE	-
1	RR N	Athiwelly	SPIC	11KV	Medchal	16.35	16.58	00.23	BD	11KV Pole Damaged by Lorry (11KV Jumper Opened at Reliance Godam)	-
1	RR E	AS Rao Nagar	BSNL	11KV	Sainikpuri	20.05	21.16	01.11		11KV line snapped at Vishal Apt opp Kanala Nagar (Artisian Upendhar)	-
2		Chengicherla	Chengicherla	11KV	Keesara	12.40	13.30	00.50		11KV Copper patti cut at MLR Colony	-
3		Aushapur	Bokkenguda AGL	11KV	Keesara	15.00	19.45	04.45		11KV Brass patti cut at Sanjeeva Reddy Bavi T/F	-