

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		5		5		5			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>1</b>	<b>8</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 07.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Chinnamaroor	Pedda Dagada	33KV	Wanaparthi	08.20	13.04	04.44		33KV Jumper cut 132KV SS	Pedda Dagada	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 07.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Reddygudem	Maddiral	11KV	Suryapet	13.20	14.20	01.00	EI	Insulator failed	-
2		Eduloor	Eduloor	11KV	Nalgonda	13.40	14.40	01.00	EI	11KV Jumper cut Under SS-13	-
3		Ghanapuram	Ghan Bheemanapally	11KV	Devarakonda	03.55	06.55	03.00	EI	11 KV Jumper Cutt	-
4		Peddathanda	Peddathanda	11KV	Bhongir	04.50	08.20	03.30	EL/OL	11 kv Line snapped near Dadla Nayak thanda	-
5		Alair 2	Alair town	11KV	Bhongir	06.05	07.12	01.07	EL/OL	Lorry accident ,11 kv Line snapped at Pochamma temple near Alair town	-
1	SDPT	Akkannapet	Fakkirnayak thanda	11KV	Husnabad	08.15	08.40	00.25		B/D due tp Copper patty cut.	-
1	RR N	Town Medchal	Country Club	11KV	Medchal	02.50	03.10	00.20	EL	11KV Line AB Switch Opened at Saibaba Temple (Tree fallen on the 11KV Line at Boys High School)	-
1	HYD S	Osm. Hospital	Begum Bazar	11kv	11KV	03.40	05.10	01.30	EL	Cable fault	At 04:40 Hrs partial fdr charged & remaining loads added on 11KV Gosha Mahal fdr