

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	2	7	2	7	2	7			
3	MDK	107	933	11	14	11	14	11	14			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	13	25	13	25	13	25	0	0	
	Grand Total	1082	6468	13	28	13	28	13	28	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 09.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Madugulapally	Visaka	33KV	Miryalaguda	08.07	10.20	02.13	EL	Cabul Falt		-
2		220KV Miryalaguda	Reddys Lab	33KV	Miryalaguda	05.30	10.30	05.00	EL	Conductor Snaped		-
1	MDK	Sadasivpet	Kondapur	33KV	Sangareddy	16.50	19.20	02.30		B/D due to Disk failure near 33/11kv Kondapur ss		-
2		Singoor	Muddaipet	33KV	Jogipet	17.40	18.10	00.30		B/D due to Conductor snapped		-
3		Borapatla	Chandapur	33KV	Jogipet	18.30	20.55	02.25		B/D due to Tree branches fallen on the line		-
4		Sadasivpet	Manjeera	33KV	Sangareddy	18.15	18.55	00.40		B/D due to Lightning arrester failure		-
5		Pashamailarm	Manjeera	33KV	Sangareddy	19.25	20.40	01.15		B/D due to Jumper cut		-
6		Pashamailarm	SOL	33KV	Sangareddy	17.45	19.40	01.55		B/D due to Jumper cut		-
7		Bollaram	Shathavahana	33KV	Patancheru	17.10	22.50	05.40		B/D due to Jumper cut		-
8		Bollaram	Meenakshi	33KV	Patancheru	17.10	19.55	02.45		B/D due to Tree branches fallen on the line		-
9		Bollaram	ITC	33KV	Patancheru	17.20	19.40	02.20		B/D due to Tree branches fallen on the line		-
10		Bollaram	Anrich	33KV	Patancheru	17.20	19.40	02.20		B/D due to Tree branches fallen on the line		-
11		Borapatla	Covalent	33KV	Jogipet	18.30	22.25	03.55		B/D due to Tree branches fallen on the line		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 09.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gudeballe	Check Post	11KV	Narayanpet	10.50	11.40	00.50		Due to conductor cut at T Road	-
1	NLG	Eduloor	Naregudem	11KV	Nalgonda	08.40	10.30	01.50	EL	11KV Jumper cut Under SS-12	-
2		K.M.Pally	K.M.Pally	11KV	Devarakonda	14.40	15.40	01.00	EL	11 KV Insulator Failed	-
3		Devarakonda	K.B.Pally	11KV	Devarakonda	08.20	09.15	00.55	EL	Movement Fult	-
4		Angadipeta	Chilkamarri	11KV	Devarakonda	16.10	17.55	01.45	EL	Jumper Cutt	-
5		Raghunadapalem	Nakkagudem	11KV	Huzurnagar	03.45	07.00	03.15	EL	11 KV LINE SNAPPED	-
6		Anantharam	Anantharam	11KV	Bhongiri	10.20	13.45	03.25	EL	11 kv Line snapped at Sharada college back side near Anantharam village.	-
7		Addagudur	Ch.Ramaram	11KV	Bhongiri	12.20	14.05	01.45	EL	10 KVA DTR failed at SS-16 near Ch.Ramaram village	-
1	MDK	EPIP-II	Marigold	11KV	Sangareddy	17.26	19.20	01.54		B/D due to Insulator failed	-
2		Sangareddy Rural	Balaji	11KV	Sangareddy	17.28	18.35	01.07		B/D due to Tree branches fallen on the line	-
3		Bonthapally	Veerabadra	11KV	Patancheru	18.00	18.30	00.30		B/D due to Jumper cut	-
4		Bollaram-II	Kottam	11KV	Patancheru	17.00	20.30	03.30		B/D due to Conductor snapped	-
5		Inole	Sathyasai	11KV	Patancheru	16.35	18.40	02.05		B/D due to Conductor snapped	-
6		Inole	Pedda Kanjarla	11KV	Patancheru	14.02	15.20	01.18		B/D due to Tree branches fallen on the line	-
7		Patancheru Town	Santhi Nagar	11KV	Patancheru	17.50	19.50	02.00		B/D due to Tree branches fallen on the line	-
8		Patancheru Town	Kanjarla	11KV	Patancheru	17.50	22.50	05.00		B/D due to Tree branches fallen on the line	-
9		Patancheru Town	Town	11KV	Patancheru	17.50	20.10	02.20		B/D due to Tree branches fallen on the line	-
10		Patancheru Town	Allwyn	11KV	Patancheru	17.50	20.15	02.25		B/D due to Tree branches fallen on the line	-
11		Patancheru Town	MIA-I	11KV	Patancheru	17.50	21.30	03.40		B/D due to Tree branches fallen on the line	-
12		Patancheru Town	MIA-II	11KV	Patancheru	17.50	20.20	02.30		B/D due to Tree branches fallen on the line	-
13		Patancheru Town	Town Industrial	11KV	Patancheru	17.50	21.50	04.00		B/D due to Tree branches fallen on the line	-
14		Patancheru Town	High Power	11KV	Patancheru	17.50	22.10	04.20		B/D due to Tree branches fallen on the line	-
1	SDPT	Kondapaka SS	Vishwanathpally Feeder LC.No.	11KV	Gajwel	02.55	07.40	04.45		1-Ph jumper cut Near SS out said	-
2		HUSNABAD	POTLAPALLY	11KV	Husnabad	03.36	01.55	12.43		B D , DUE TO LINE CUT	-
3		Komuravelly	Posanpally	11KV	Husnabad	04.48	07.12	02.24		B.D, DUE TO LINE CUT	-
1	RR N	Dppallt-II	Cable MLR	11KV	Jeedimetla	17.52	20.00	02.08		11kv line Cut at Medchal Road	-
2		Vikas	Volvo	11KV	Kukatpally	16.52	18.22	01.30		11kv line PinInsulater failed at Sai Anuragh Colony	-
3		Miyapur X Road	E seva	11KV	Kukatpally	16.53	18.06	01.13		Tree branchesh Fallen the 11kv line at SMR Metro,	-