

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>10</b>	<b>3</b>	<b>10</b>	<b>3</b>	<b>10</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 11.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kothapally	33KV	Narayanpet	06.40	08.15	01.35		33KV Jumper cut	Kothapally	-
2		Wanaparthy	Narsaipally	33KV	Wanaparthy	10.45	14.25	03.40		R & Y Phase female contact replacement	Narsaipally	-
1	RR N	132KV Medchal	33KV Medchal-I	33KV	Medchal	17.31	18.18	00.47	BD	33KV Line AB Switch opened at 220KV Medchal SS (33KV Line cut at IDA Medchal SS)	33KV Medchal-I	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 11.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Rajupeta	Silarmiyagudem	11KV	Nalgonda	06.45	11.15	04.30	E/L	Tree branch fallen on line at SS-12	-
2		Akaram	Shanthinagar	11KV	Nalgonda	13.30	14.30	01.00	E/L	11KV jumper cut	-
3		Anantharam	Anantharam	11KV	Bhongir	11.35	13.37	02.02	EL/OL	11KV Line Snapped near Anantharam Village	-
4		Voligonda	Voligonda Twon	11KV	Choutuppal	12.40	13.30	00.50	EL/OL	11KV Line Snapped near Voligonda Twon	-
1	MDK	Gowraram SS	Maialaram	11KV	Gajwel	00.00	05.00	05.00		Problem Not found But Feeder OK	-
2		Chittapur	Ragothamapally	11KV	Siddipet	10.19	10.49	00.30	B/D	B/D	-
1	RR N	Shemshiguda	Thulasivanam	11KV	Kukatpally	01.30	03.10	01.40	EL/OL	AB Cable failed at NTR Kaman, B/F Yellamma banda	-
1	RR E	AS Rao Nagar	BSNL	11KV	Sainikpuri	06.24	07.20	00.56		Tree branches touched on 11Kv line Phase to Phase at Kamala Nagar	-
1	HYD S	Asmangadh	GA Bank Colony	11KV	VIII	07.39	08.46	01.07	EL	HT Line snapped at GA Bank Colony	
1	HYD C	Asif Nagar	N.S.F Colony	11KV	VII	12.03	13.19	01.16	EL,OL-Bph	Cable fault at N.S.F Colony	