

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		6		6		6			
3	MDK	107	933	1		1		1				
4	SDPT				6		6		6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	13	1	13	1	13	0	0	
	Grand Total	1082	6468	1	17	1	17	1	17	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 13.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Pashamailaram	SOL	33KV	Sangareddy	06.05	07.50	01.45		B/D Due to Jumper cut		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 13.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	P.C Kunta	11KV	Narayanapet	05.52	06.50	00.58		Due to Phase to Phase	-
1	NLG	Dirsenapally	Machinapally	11KV	Suryapet	15.30	17.10	01.40	E/L	Insulator failed	-
2		Paladugu	Paladugu	11KV	Bhongir	03.00	08.15	05.15	E/L	11 kv Line snapped near Raghavapuram village	-
3		Choutuppal IPDS	Damera Agl	11KV	Choutuppal	04.00	10.23	06.23	E/L	11 KV Insulator failed , HT/LT & Tree branchess fallen at line at Reddicherla near Thangedipally village	-
4		Juloor	Peddagudem	11KV	Choutuppal	11.28	13.52	02.14	E/L	11 kv Line snapped at Poultry farm near Peddagudem village	-
5		Arror	Arror Agl	11KV	Choutuppal	04.05	09.00	04.55	E/L	11 kv Line snapped at CN Reddy farm house near Arror village	-
6		Arror	Lingarajupally	11KV	Choutuppal	11.15	13.35	02.20	E/L	11 kv Line snapped near Muddapur village	-
1	SDP	MD SHAPUR	LINGAIPALLY THANDA	11KV	Gajwel	19.50	20.40	00.50		25KVA DTR FAILED	-
2		DOULTHABAD	LINGARAJPALLY	11KV	Gajwel	18.05	18.26	00.21		1-Ph RUNNING (3-Ph BREAKDOWN)	-
3		JAGADEVPUR	DAWALAPUR	11KV	Siddipet	12.50	13.50	01.00		TREE THUCING 11KVA LINE	-
4		Narmetta	Thimmaipally	11KV	Husnabad	07.50	08.55	01.05		LC For 11 kv jumper cut LCNO.23693	-
5		Shanigaram	Gundareddypally	11KV	Husnabad	13.10	15.15	02.05		Insulator failure, same rectified	-
6		Cherial Town	Cherial-Town			12.40	13.20	00.40		Line snapped, same rectified	-
1	RR N	Aliabad	Majeedpur	11KV	Medchal	07.10	08.00	00.50	BD	No Fault	-
1	RR E	Janapriya	Green Park	11KV	Sainikpuri	04.15	05.40	01.25		11Kv Cable Shot on Box Pole at Kalpa Harsha Apt. Naya Kranthi Nagar (Artisan/Panthulu)	-
1	HYD N	Chinna Thokatta	Dubai Gate	11KV	VI	23.33	00.59	01.26	EL,OL-Rph	Arranged B/F on 11KV Mahatma Nagar feeder	-
1	HYD C	Vittalwadi	Gandhi Kuteer	11KV	II	03.48	05.45	01.57	EL,OL-Rph	2No. RMUs fault at Airbus Apts	-