

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	5	46	5	46	5	46			
7	RR(E)	168	403		11		11		11			
8	Hyd	194	1044		121		121		121			
	Total	606	3055	5	178	5	178	5	178	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	15	42	15	42	15	42			
2	NLG	144	988	2	21	2	21	2	21			
3	MDK	107	933	28	30	28	30	28	30			
4	SDPT			6	29	6	29	6	29			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133		13		13		13			
	Total	476	3413	51	135	51	135	51	135	0	0	
	Grand Total	1082	6468	56	313	56	313	56	313	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 14.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Nawabpet	33KV	Mahabubnagar	05.30	06.50	01.20	EL&OL	Pin Binding Failed at Boyapally SS		NO
2		Mahabubnagar	Machanpally	33KV	Mahabubnagar	05.35	06.45	01.10	EL	Tree Branches Fallen on the Line		NO
3		220/132KV SS Palkonda	Kodur	33KV	Mahabubnagar	05.05	07.28	02.23	EL	AB Switch Open at Bandamidapally		NO
4		220/132KV SS Palkonda	Janampet	33KV	Mahabubnagar	04.15	09.10	04.55	EL	Disc Failed at Potulamadugu		NO
5		Makthal	Utkoor	33KV	Narayanapet	07.20	11.40	04.20	EL	Tree Branches Removing on the Line		NO
6		Makthal	Maganoor	33KV	Narayanapet	05.20	08.50	03.30	EL	Jumper Connecting Purpose		NO
7		Makthal	Krishna	33KV	Narayanapet	05.20	06.10	00.50	EL	Tree Branches Fallen on the Line		Alternate Supply Taken to 33KV Gudeballore Feeder at 6:10Hrs
8		Marikal	Devarkadra	33KV	Narayanapet	06.10	09.55	03.45	EL	Disc Replacement Purpose		Alternate Supply Given From 33KV Koukuntla at 9:55Hrs.
9		Midjil	Madaram	33KV	Jadcherla	03.00	12.35	09.35	EL	Flash Over Directed		NO
10		Wanaparthy	Revally	33KV	Wanaparthy	04.50	11.08	06.18	EL	Tree Fallen on the Line at Yedutla & Disc Failure		NO
11		Thirumalaipally	Willamkonda	33KV	Wanaparthy	05.30	14.10	08.40	EL	Insulators Replacement		NO
12		Thirumalaipally	Veltoor	33KV	Wanaparthy	04.20	14.10	09.50	EL	Insulators Replacement		NO
13		Amarchintha	Atmakur	33KV	Wanaparthy	04.50	07.58	03.08	EL	No Visible Fault		NO
14		Kalwakurthy	Rachoor	33KV	Nagarkurnool	06.24	08.50	02.26	EL	Y Phase LA Blost and Jumper direct & Isolator open		NO
15		Alampur	Shanthinagar -1	33KV	Gadwal	08.24	08.53	00.29	EL	Due to 33KV Line Fault		Alternate Supply Given From 33KV Shanthinagar 2 at 8:53Hrs.
1	NLG	Nalgonda	Gudapur	33KV	Nalgonda	06.46	10.16	03.30	E/L	Tree branches fallen on 33KV line near Munugode Bypass		-
2		Miryalaguda	Reddys Lab	33KV	Miryalaguda	09.50	12.00	02.10	E/L	Bird fallen on the 33 KV line		-
1	MDK	Kandi	Sangareddy - II	33KV	Sangareddy	05.55	08.35	02.40		BD due to Tree fallen on line		-
2		Kandi	BDL	33KV	Sangareddy	07.05	10.20	03.15		BD due to Tree fallen on line		
3		Kandi	HFC I	33KV	Sangareddy	05.10	09.15	04.05		BD due to Tree fallen on line		
4		Kandi	IIT Kandi	33KV	Sangareddy	06.05	09.45	03.40		BD due to Jumper cut		
5		Narayankhed	Wasar	33KV	Jogipet	04.40	09.10	04.30		B/D Tree branches fallen on the line (13.4.21 to 14.4.21)		
6		Narayankhed	Poosalpad	33KV	Jogipet	02.10	03.20	01.10		B/D Insulator failure (13.4.21 to 14.4.21)		
7		Narayankhed	Sirgapur	33KV	Jogipet	03.55	07.35	03.40		B/D due to Conductor snapped		
8		Borapatla	Chandapur	33KV	Jogipet	04.05	09.35	05.30		B/D due to Tree branches fallen on the line		
9		Jogipet	Gadipeddapur	33KV	Jogipet	04.05	07.20	03.15		B/D due to Tree branches fallen on the line		
10		Sadasivpet	Koheer	33KV	Sangareddy	02.10	09.35	07.25		B/D Alternate supply given 33kv Jharasangam to 33kv Koheer feeder		

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effectuated	Alternate Supply Arranged
11	MDK	Sadasivpet	Manjeera	33KV	Sangareddy	04.20	08.30	04.10		B/D due Jumper cut		
12		Sadasivpet	Sadasivpet	33KV	Sangareddy	04.45	07.20	02.35		B/D due Jumper cut & lightning arrester failure.		
13		Gummadidala	GPSS-I	33KV	Patancheru	04.25	07.35	03.10		B/D due to Jumper cut		
14		Gummadidala	GPSS-II	33KV	Patancheru	GPSS-II	04.16	09.10		B/D Insulator failure		
15		Gummadidala	AFA	33KV	Patancheru	AFA	05.20	08.20		B/D due to No fault found		
16		Gummadidala	Jinnaram	33KV	Patancheru	Jinnaram	05.55	08.35		B/D due to Kite fallen on the line		
17		Gummadidala	Gummadidala	33KV	Patancheru	Gummadidala	07.05	10.20		B/D due to Kite fallen on the line		
18		R.C.puram	Ambjua	33KV	Patancheru	Ambjua	05.10	09.15		B/D due to Kite fallen on the line		
19		R.C.puram	Manjeera	33KV	Patancheru	Manjeera	06.05	09.45		B/D due to No fault found		
20		R.C.puram	J.K Fennar	33KV	Patancheru	J.K Fennar	04.40	09.10		B/D due to Disk failure		
21		Pashamailaram	EPIP-II EPIP	33KV	Sangareddy	EPIP-II EPIP	02.10	03.20		B/D due to Jumper cut		
22		Pashamailaram	APL4	33KV	Sangareddy	APL4	03.55	07.35		B/D due to Tree branches fallen on the line		
23		Pashamailaram	SOL	33KV	Sangareddy	SOL	04.05	09.35		B/D due to Jumper cut		
24		Pashamailaram	GTN	33KV	Sangareddy	GTN	04.05	07.20		B/D due to No fault found		
25		Pashamailaram	Manjeera	33KV	Sangareddy	Manjeera	02.10	09.35		B/D due to Jumper cut		
26		Pashamailaram	BPL	33KV	Sangareddy	BPL	04.20	08.30		B/D due to Tree branches fallen on the line		-
27		Pashamailaram	Nactor	33KV	Sangareddy	Nactor	04.45	07.20		B/D due to No fault found		-
28		Pashamailaram	EPIP	33KV	Sangareddy	EPIP	04.25	07.35		B/D due to No fault found		-
1	SDPT	Siddipet	Narsapur	33KV	Siddipet	00.45	01.30	00.45		B/D-Heavy wind and Gale-Now Rectified		-
2		Siddipet	Narayanraopet	33KV	Siddipet	01.15	06.30	05.15		B/D-Heavy wind and Gale-Now Rectified		-
3		Thukkapur	Mettu	33KV	Gajwel	01.00	06.40	05.40		B/D-Heavy wind and Gale-Now Rectified		-
4		Husnabad	Thotapally	33KV	Husnabad	00.30	00.55	00.25		BD (Disk Failed)		-
5		Husnabad	Water Gird	33KV	Husnabad	23.30	12.50	13.20		BD (Disk Failed)		-
6		Husnabad	Katkur	33KV	Husnabad	00.05	11.05	11.00		BD (Disk Failed)		-
1	RR N	132KV Chintal	33KV Subhash Nagar	33KV	Medchal	04.55	07.09	02.14	BD	33KV PinInsulator failed at Vennalagadda		-
2		132KV LGM Pet	33KV MN Park	33KV	Medchal	05.27	08.08	02.41	BD	No Fault		-
3		132KV LGM Pet	33KV LGM Pet	33KV	Medchal	05.27	06.45	01.18	BD	Line AB Switch opened at Monsanto Company		-
4		132KV Medchal	33KV Shantha Biotech	33KV	Medchal	01.40	09.30	07.50	BD	No Fault		-
5		132KV Medchal	33KV Medchal-I	33KV	Medchal	01.20	09.30	08.10	BD	No Fault		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Sampally	11KV	Narayanpet	09.00	10.10	01.10		Break Down due to 11KV jumper cut at Sampally Agl	-
2		Gundumal	Amlikunta	11KV	Narayanpet	06.50	10.15	03.25		Break Down due to 11Kv line cut at Amlikunta vg	-
3		Maddur	Maddur	11KV	Narayanpet	05.20	07.05	01.45		Break Down due to 11KV Jumper cut at Kosgi Road	-
4		Maddur	Khajipur	11KV	Narayanpet	03.35	09.44	06.09		Break Down due to Heavy gale and wind	-
5		Pallerla	Parsapur	11KV	Narayanpet	09.42	10.45	01.03		Break Down due to 11Kv Insulator damaged at Chandria Naik tanda	-
6		Gokulnagar	Nandigama	11KV	Narayanpet	00.00	02.00	02.00		Break Down due to jumper cut & Heavy gale and wind	-
7		Salkarpet SS	Pagdiyal	11KV	Narayanpet	07.45	08.00	00.15		Break Down due to 11Kv jumper cut at Kondapur vg	-
8		Vennached	Lingaipally	11KV	Narayanpet	06.00	09.11	03.11		Break Down duw to replacement of 11KV Insulator at Baispally vg	-
9		Mohammadabad	Mohammadabad	11KV	Narayanpet	03.00	08.30	05.30		Break Down due to Heavy gale and wind	-
10		Venkatredddydpally	Shaikpally	11KV	Narayanpet	03.00	03.50	00.50		Break Down due to Heavy gale and wind	-
11		APPAKPALLY	JAJAPUR	11KV	Narayanpet	07.00	12.00	05.00		breakdown due to 11kv jumper cut and fallen on DTR at Jajapur vlg	-
12		APPAKPALLY	APPIREDDYPALLY	11KV	Narayanpet	07.00	12.00	05.00		breakdown due to insulator failed at Appireddipally vlg	-
13		KOTAKONDA	BOMMANPAD	11KV	Narayanpet	03.53	09.30	05.37		breakdown due to insulator failed at bomanpad vlg	-
14		KYATHANPALLY	WATTUGUNDLA	11KV	Narayanpet	03.23	10.28	07.05		breakdown due to 11kv line cut and fallen on channel kamsanpally vlg	-
15		MOGALMADKA	MOGALMADKA RURAL	11KV	Narayanpet	11.44	12.43	00.59		breakdown due to insulator failed	-
16		KANUKURTHY	DAMARGIDDA	11KV	Narayanpet	07.54	10.11	02.17		breakdown due to insulator failed	-
17		DHANWADA	MANDIPALLY	11KV	Narayanpet	03.30	10.21	06.51		breakdown due to insulator failed	-
18		MARIKAL	MARIKAL TOWN	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
19		MARIKAL	APPAMPALLY	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
20		MARIKAL	ELIGANDLA	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
21		MARIKAL	P.C.KUNTA	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
22		MARIKAL	INDL FEEDER	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
23		MARIKAL	TILERU	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
24		MARIKAL	MADWAR	11KV	Narayanpet	04.00	08.00	04.00		breakdown due to insulator failed	-
25		EKLASPUR	CHITTANUR	11KV	Narayanpet	05.30	14.10	08.40		breakdown due to insulator failed	-
26		EKLASPUR	KANMANUR	11KV	Narayanpet	10.00	12.30	02.30		breakdown due to disk fail	-
27		Midjil	Veijal	11KV	Jadcherla	03.00	10.00	07.00		B.D. Ht/Lt Near Ushodaya Company Side	-
28		Peddarevelly	Chinnarevelly	11KV	Jadcherla	05.25	09.19	03.54		B.D. 11Kv Disc Fail Near Pochamma Gadda Tanda Side.	-
29		Peddarevelly	Thirumalagiri	11KV	Jadcherla	05.30	11.20	05.50		b.d.11kv Disc Failure Near Jai Function Hall Side.	-
30		Peddarevelly	Chinnarevelly	11KV	Jadcherla	12.17	13.16	00.59		B.D.11Kv jumper Cut Near Pochamma Gadda Tanda side.	-
31		Malleboinpally	Malleboinpally	11KV	Jadcherla	03.28	13.38	10.10		B.D.25KVA Dtr Fail Near Kunta Tanda Side.	-
32		Malleboinpally	Bureddypally	11KV	Jadcherla	02.36	13.48	11.12		B.D.11Kv jumper Cut Near Bureddypally(Vi)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
33	MBNR	Thirumalapur	Khanapur	11KV	Jadcherla	05.40	08.53	03.13		B.D.11Kv jumper Cut Near Khanapur(Vi)	-
34		Nawabpet	Gurukunta	11KV	Jadcherla	08.48	11.37	02.49		B.D.11Kv Disc Fai Near Nawabpet (Vi)	-
35		Rajapur	Chennavelly	11KV	Jadcherla	06.00	09.30	03.30		B.D.11Kv Jumper Cut Near Kucharkal (Vi)	-
36		Rajapur	Muddireddypally	11KV	Jadcherla	06.00	11.00	05.00		B.D,11Kv Disc Fail Near Mudireddypally (Vi)	-
37		Badepally	Nagasala	11KV	Jadcherla	04.35	09.40	05.05		B.D.11Kv Jumper Cut Near Nagasala(vi)	-
38		Badepally	Gangapur	11KV	Jadcherla	06.30	12.00	05.30		B.D.11Kv Jumper Cut Near Mallappa Thota Side	-
39		Kothamolgara	Maddigatla	11KV	Jadcherla	04.00	12.00	08.00		B.D.11Kv Disc Fail Near Kothamolgara (Vi)	-
40		Udithyal	Udithyal	11KV	Jadcherla	03.30	08.00	04.30		B.D.Tree Follen On The On 11Kv Line Near Veerannapally Tanda Side.	-
41		Udithyal	Udithyal	11KV	Jadcherla	10.50	14.52	04.02		B.D. 11Kv insulator Failure Near Adavibavulu Side.	-
42		Udithyal	Macharam	11KV	Jadcherla	11.48	14.50	03.02		B.D.HT/LT Near Jalugadda Tanda Cut Point Side.	-
1	NLG	Nakkalapally	Pallepahad	11KV	Nalgonda	08.40	11.30	02.50	E/L	100KVA DTR failed under SS-1	-
2		Aitipamula	Ch.Annaram	11KV	Nalgonda	10.20	13.15	02.55	E/L	Tree branch fallen on line	-
3		Pamanagundla	Yerasanigudem	11KV	Nalgonda	15.56	16.55	00.59	E/L	AB switch open at Ravi Seeds	-
4		Yacharam	Annaram	11KV	Miryalguda	03.30	06.45	03.15	E/L	11 KV disk failure	-
5		Settipalem	Annapureddygudem	11KV	Miryalguda	05.20	07.55	02.35	E/L	Tree fallen on the 11KV line	-
6		Annaram	Annaram	11KV	Suryapet	02.50	07.30	04.40	E/L	11Kv Conductor snapped	-
7		Bollepally	Bollepally	11KV	Bhongir	04.40	09.30	04.50	EL/OL	11 kv Disc failed at Akula mallareddy well near Bollepally (V)	-
8		Bollepally	Jampally	11KV	Bhongir	04.40	08.30	03.50	EL/OL	11 kv Insulator failed near Jampally (V)	-
9		Chandupatla	Cheemalakondur	11KV	Bhongir	03.40	06.00	02.20	EL/OL	Musthyalapally village AB Switch open line stand. 11 kv Insulator failede near Musthyalapally (V)	-
10		MR.Gudem	Gangasanipally	11KV	Bhongir	07.30	08.50	01.20	EL/OL	11 kv Insulator failed near Gangasanipally (V)	-
11		B.Ramaram	Hajipur	11KV	Bhongir	08.30	09.40	01.10	EL/OL	11 kv Disc failed near Naginenipally (V)	-
12		Sharajipet	Saigudem	11KV	Bhongir	04.00	07.30	03.30	E/L	11 kv Disc Failed at SS-2 near Mandanapally (V)	-
13		Peddakandukur	Masaipet	11KV	Bhongir	05.30	11.20	05.50	EL/OL	11 kv Insulator failed near Masaipet (V)	-
14		Chamapur	Chandepally	11KV	Bhongir	04.05	10.15	06.10	EL/OL	11 kv Insulator failed at Enugu .Venkat reddy well near Chandepally (V)	-
15		Kapraipally	Kapraipally	11KV	Bhongir	05.00	09.05	04.05	E/L	11 kv Insulator failed near Kapraipally (V)	-
16		Suddala	Anantharam	11KV	Bhongir	07.50	12.30	04.40	E/L	11 kv Insulator failed at Thegala. Sathaiah well near Anantharam (V)	-
17		Choutuppal	Town 1	11KV	Choutuppal	05.30	10.00	04.30	EL/OL	11 kv Insulator failed at Shankara chary well near Choutuppal town	-
18		D.Nagaram	Pipalpahad Agl	11KV	Choutuppal	02.35	09.48	07.13	EL/OL	11 kv Line snapped near Pipal pahad (V)	-
19		Malkapur	Malkapur Agl	11KV	Choutuppal	09.50	10.40	00.50	EL/OL	11 kv Disc failed near malkapur (V)	-
20		Jublakpally	Jublakpally	11KV	Choutuppal	06.05	11.20	05.15	EL/OL	11 kv Disc failed near Anthammagudem (V)	-
21		Aror	Appareddypally	11KV	Choutuppal	04.00	10.00	06.00	EL/OL	11 KV Disc failed near Appareddypally (V)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Sadasivpet	Town III	11KV	Sangareddy	03.07	10.34	07.27		BD due to Tree fallen on line	-
2		EPIP-II	Export	11KV	Sangareddy	04.00	09.20	05.20		BD due to Tree fallen on line	-
3		EPIP-III	Sai Deepak	11KV	Sangareddy	03.40	08.30	04.50		BD due to Tree fallen on line	-
4		Pati	Pati	11KV	Patancheru	11.20	12.20	01.00		BD due Jumper cut	-
5		Patancheru Town	Shanthinagar	11KV	Patancheru	04.30	10.20	05.50		BD due to Insulator failed	-
6		Patancheru Town	Town	11KV	Patancheru	12.40	14.10	01.30		BD du to Disk failed	-
7		Patancheru Town	MIA-II	11KV	Patancheru	05.10	10.40	05.30		BD due to Tree branches fallen on line	-
8		MIG	HUDA	11KV	Patancheru	04.30	08.30	04.00		BD due to Tree branches fallen on line	-
9		Bollaram - I	Sulaxshana-I	11KV	Patancheru	15.38	17.10	01.32		BD due to Jumper cut	-
10		Bollaram - II	Rupa	11KV	Patancheru	05.18	08.18	03.00		BD due to Tree branches fallen on line	-
11		Gummadidala	Agrobell	11KV	Patancheru	01.00	11.30	10.30		BD due to Tree fallen on line	-
12		Gummadidala	Bell Remedies	11KV	Patancheru	01.20	10.20	09.00		BD due to Tree fallen on line	-
13		Dundigal	Jinnaram	11KV	Patancheru	05.00	08.10	03.10		Bd due to Disk failed	-
14		Bonthapally	Veerabadra	11KV	Patancheru	05.00	07.00	02.00		BD due to Tree fallen on line	-
15		Gundla Machnoor	Industrial	11KV	Patancheru	00.10	11.00	10.50		BD due to Tree fallen on line	-
16		Kistareddypet	Patelguda	11KV	Patancheru	04.50	08.42	03.52		Bd due to Disk failed	-
17		Inole	Peddakanjarla	11KV	Patancheru	02.40	13.00	10.20		BD due to Insulator failed	-
18		Sangareddy Town-II	SRD III	11KV	Sangareddy	04.45	09.30	04.45		BD du eo Conducoc snapped	-
19		Sangareddy Rural	Balaji Feeder	11KV	Sangareddy	11.40	12.58	01.18		BD due to Disk failed	-
20		Sadasivpet Town	Town III	11KV	Sangareddy	03.07	10.34	07.27		BD due to Tree fallen on line	-
21		Sangareddy	Allipur	11KV	Sangareddy	04.00	06.40	02.40		BD due to Conductor snapped	-
22		Patancheru Town	Shanthinagar	11KV	Patancheru	04.30	10.20	05.50		BD due to Insulator failed	-
23			Town	11KV	Patancheru	12.40	14.10	01.30		BD du to Disk failed	-
24		MIG	HUDA	11KV	Patancheru	04.30	08.30	04.00		BD due to Tree branches fallen on line	-
25		Ameenpur	Vediri	11KV	Patancheru	05.43	08.21	02.38		BD due to Tree branches fallen on line	-
26		Ameenpur	Bandam Kommu	11KV	Patancheru	05.43	08.21	02.38		BD due to Tree branches fallen on line	-
27		Kistareddypet	Patelguda	11KV	Patancheru	04.50	08.42	03.52		Bd due to Disk failed	-
28		RC Puram	RC Puram	11KV	Patancheru	06.20	08.40	02.20		BD due to Insulator failed	-
29		RC Puram	RC Puram	11KV	Patancheru	08.15	10.15	02.00		BD due to no fault at found	-
30		Jogipet	Town	11KV	Jogipet	02.30	04.00	01.30		BD due to tree fallen on line	-
1	SDPT	Mustabad X-Road	Raghavendranagar	11KV	Siddipet	01.05	02.30	01.25		B/D- Wire cut-Now Rectified	-
2		Mustabad X-Road	Hanuman Nagar	11KV	Siddipet	01.00	01.30	00.30		B/D- Disk fail-Now rectified	-
3		Habshipur	Dharmaram	11KV	Siddipet	06.46	09.50	03.04		B/D-Tree bunches fallen on line-Now rectified	-
4		Chellapur	Rajakkapet	11KV	Siddipet	00.51	07.23	06.32		B/D- HT/LT lines-Now Rectified	-
5		Peddagundavelly	Dumpalapally	11KV	Siddipet	10.00	13.00	03.00		B/D-Jumper out-Now Rectified	-
6		Peddachikode	Kammarpally	11KV	Siddipet	00.30	05.05	04.35		B/D- 11KV Insulator fail-Now Rectified	-
7		Peddachepyal	Peddachepyal	11KV	Siddipet	02.30	14.44	12.14		B/D-Insulators & disk fail-Now Rectified	-
8		Ponnala	Ponnala	11KV	Siddipet	05.35	11.40	06.05		B/D-Disk fail-Now Rectified	-
9		Narmetta	Venkatapur	11KV	Siddipet	00.48	11.30	10.42		B/D-Tree bunches fallen on line-Now rectified	-
10		Lingareddypally	Imambad	11KV	Siddipet	12.30	12.40	00.10		B/D-Tree bunches fallen on line-Now rectified	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
11	SDPT	BEGAMPET	YELKAL (LC NO: 12658/ASHOK Artisan	11KV	Gajwel	16.20	18.18	01.58		220KVA LINE CUTTED AND FELL DOWN ON THE 11KVA LINE	-
12		DOMMATA	DOMMATA (LC NO: 7816/ SRINIVAS. CL	11KV	Gajwel	08.10	09.12	01.02		11KVA LINE INTRAPTION	-
13		DOULTHABAD	LINGARAJPALLY (LC NO: 1008/ SRNIVAS. LM	11KV	Gajwel	09.01	09.58	00.57		BREAKDOWN NOT FOUND	-
14		MD SHAPUR	LINGAIPALLY THANDA (LC NO: NO LC NO/ NARSIMULU. CL	11KV	Gajwel	01.20	09.14	07.54		11KVA INSULATOR FAILED	-
15		KARKAPATLA	GLOBIN (LC NO: 664/ HANUMANTHU. LM	11KV	Gajwel	07.30	08.37	01.07		JUMPER BURN & CUT	-
16		JAGADEVPUR	ITIYALA (LC NO: 5764/ NARSIMULU. CL	11KV	Gajwel	06.29	07.41	01.12		JUMPER CUT	-
17		JAGADEVPUR	DAVALAPUR (LC NO: 5765/ KUMAR. LM	11KV	Gajwel	07.16	09.02	01.46		11KVA INSULATOR FAILED	-
18		CHATLAPALLY	CHATLAPALLY AGL (LC NO: 5081/ PRAKASH. CL	11KV	Gajwel	01.02	06.40	05.38		11KVA COUNDUCTOR CUT	-
19		GOWRARAM	GOWRARAM AGL (LC NO: 11435/ SRIDHAR. CL	11KV	Gajwel	02.25	09.15	06.50		THE TREES BROKE & FELL DOWN	-
20		NEMTOOR	JABBAPUR (LC NO: NO LC BOOK/ DAMODHER. CL	11KV	Gajwel	01.20	03.10	01.50		11KVA LINE CUT	-
21		GAJWEL & PRAGNAPUR	TOWN-2 (LC NO: 6310/ JAYASIMHARAO. LI	11KV	Gajwel	01.19	02.30	01.11		BREAKDOWN NOT FOUND	-
22		BV PUR	BV PUR (LC NO: 9976/ RAJESH. JLM	11KV	Gajwel	06.20	07.00	00.40		BREADOWN	-
23		MULUGU	NAGIREDDYPALLY (LC NO: 11066/ DHANPalreddy. alm	11KV	Gajwel	15.40	17.00	01.20		11KVA LINE CUT	-
24		VATIMAMIDI	R & R COLONY (LC NO: /	11KV	Gajwel	01.05	06.05	05.00		DAIRECT RECTIFYED	-
25		BANDAMAILARAM	BANDAMAIALARAM AGL (LC NO: 36578/ PRABAKER. Artisan	11KV	Gajwel	07.10	07.55	00.45		11KVA LINE PHASE TO PHASE	-
26		KOKKONDA	KOTOOR (LC NO: 36769/ YADAGIRI. CL	11KV	Gajwel	01.00	07.50	06.50		THE TREES BROKE & FELL DOWN	-
27		CHILASAGAR	CHLASAGAR VILLAGE (LC NO: 34657/ SRNIVASREDDY. CL	11KV	Gajwel	06.00	10.30	04.30		11KVA INSULATOR FAILED	-
28		CHILASAGAR	CHILASAGAR AGL (LC NOI 34658/ SRINIVASREDDY. CL	11KV	Gajwel	06.00	12.50	06.50		11KVA & LT LINE PHASE TO PHASE & INDUSTRIAL FEDEER MANUAL TRIPED	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
29		MULUGU	BAIALAMPUR (LC NO: 11065/ RAJESHAM. LM	11KV	Gajwel	11.45	13.30	01.45		11KVA INSULATOR FAILED	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Nizampet	Rajadhani school	11KV	Kukatpally	05.45	07.00	01.15	EL/OL	Due to rain	-
2		Nizampet	Nizampet	11KV	Kukatpally	05.50	07.20	01.30	EL	Due to rain	-
3		Vijayanagar colony	Jayanagar	11KV	Kukatpally	04.50	06.25	01.35	EL/OL	CTPT failure at Jayanagar	-
4		Vijayanagar colony	Shanthinagar	11KV	Kukatpally	04.55	06.35	01.40	EL/OL	Pin insulator failure at Complex road	-
5		Vijayanagar colony	Venkateshwara nagar	11KV	Kukatpally	04.55	08.10	03.15	EL/OL	Pin insulator failure at Bharathamma T/F road no 20	-
6		KPHB	Gowtham nagar	11KV	Kukatpally	04.32	06.30	01.58	EL	Due to rain,given back feeding from 11kv Allapur society feeder (no visible falt)	-
7		Madeenaguda	JP Nagar	11KV	Kukatpally	06.27	08.00	01.33	EL/OL	11KV AB Switch end kit failure,tree branch fall inon the line at JP Nagar	-
8		Dulapally	Prashanth Nagar	11KV	Medchal	04.50	07.50	03.00	BD	Tree fallen on the 11KV Line	-
9		Dulapally	IDA-II	11KV	Medchal	05.30	07.35	02.05	BD	11KV Pin Insulator failed at Water Tank Company	-
10		Dulapally	Dulapally Village	11KV	Medchal	04.48	06.28	01.40	BD	Line AB Switch opened (11KV Disc failed at SBH Bank)	-
11		Dulapally	KK Society	11KV	Medchal	05.40	08.35	02.55	BD	11KV Pin Insulator failed at MNT Industry	-
12		Petbasheerabad	Vaishnavi Enclave	11KV	Medchal	05.40	07.00	01.20	BD	No Fault	-
13		Jagathgirigutta	IDA	11KV	Medchal	05.25	07.40	02.15	BD	11KV Pin Insulator failed at Devamma Basti	-
14		Jagathgirigutta	Maqdoom Nagar	11KV	Medchal	06.10	08.10	02.00	BD	11KV Jumper cut and replaced at Polala Basti	-
15		Jagathgirigutta	Shirdi Hills	11KV	Medchal	06.35	08.30	01.55	BD	11KV Line Phase to Phase Touched at RGK	-
16		UMCC	Gajularamaram	11KV	Medchal	05.26	06.36	01.10	BD	11KV Cable endkit failed at Seetaramma Temple	-
17		Subhash Nagar	Gayatri Nagar	11KV	Medchal	07.15	08.40	01.25	BD	Tripped on EL Indication(Due to Rain)	-
18		Kompally	Vensai Enclave	11KV	Medchal	05.00	08.23	03.23	BD	11KV Line cut and replaced at Vensai Apartment	-
19		Chintal	Dwaraka Nagar	11KV	Medchal	07.15	08.20	01.05	BD	Kite fallen on the 11KV at Shivalayam Temple	-
20		Jagathgirigutta	Jagathgirigutta	11KV	Medchal	05.25	09.45	04.20	BD	11KV Cable Kit failed at Anjaiah Nagar	-
21		HMT	Ganesh Nagar	11KV	Medchal	06.20	10.55	04.35	BD	Breaker Mechanical Problem in SS	-
22		Kompally	Kompally	11KV	Medchal	04.45	06.36	01.51	BD	11KV PinInsulator failed at Kompally Main road	-
23		Kompally	NCL	11KV	Medchal	05.10	06.16	01.06	BD	11KV Line Melted at Vensai Aparment	-
24		Jeedimetla SS 3	Rama Reddy Nagar	11KV	Jeedimetla	04.50	06.45	01.55	EL	Due To Heavy Rain	-
25		Jeedimetla SS 3	Andhra Polymers	11KV	Jeedimetla	04.50	09.30	04.40	EL	Due To Heavy Rain	-
26		Jeedimetla SS 3	VSP Organics	11KV	Jeedimetla	04.50	11.50	07.00	EL	Due To Heavy Rain	-
27		Jeedimetla SS 3	Pipe Line	11KV	Jeedimetla	04.50	09.50	05.00	EL	Bird Fallen on the 11KV line at Gampala Basthi	-
28		Jeedimetla SS 3	Fox Sagar	11KV	Jeedimetla	04.50	06.50	02.00	EL	Due To Heavy Rain	-
29		Jeedimetla SS 3	Vinayak Nagar	11KV	Jeedimetla	06.15	11.15	05.00	EL	11KV AB Cable failiure at Vinayak Nagar	-
30		Jeedimetla SS 3	Vinayak Nagar	11KV	Jeedimetla	13.25	16.20	02.55	EL	11KV AB Cable failiure at Vijayasri Cemical Company	-
31		Jeedimetla SS 4	I matha	11KV	Jeedimetla	05.55	13.00	07.05	EL/OL	11KV Jummper Cut Opp: I Matha	-
32		Jeedimetla SS 4	Tagore	11KV	Jeedimetla	05.15	08.30	03.15	EL	11KV Insulator failure at Sub Station	-
33		Jeedimetla SS 4	Axis	11KV	Jeedimetla	04.05	06.35	02.30	EL/OL	11KV AB Cable end Kit Failure, Jummper Cut at Axis Colony	-
34		Jeedimetla SS 2	Apurupa Colony	11KV	Jeedimetla	04.50	05.55	01.05	EL/OL	11KV Pin Insulator Failure at SRC Nagar	-
35		Jeedimetla SS 2	NRSA	11KV	Jeedimetla	05.05	08.00	02.55	OL	AB Cale Failure at 220KV Shapur Back Side	-
36		Jeedimetla SS 2	Phase 3	11KV	Jeedimetla	05.17	08.50	03.33	EL/OL	11KV AB Cable failure at Phase 3	-
37		Jeedimetla SS 2	Kompalli Phrma	11KV	Jeedimetla	06.16	09.30	03.14	EL	11KV AB Cable failure at Phase 3	-
38		Aleep	Doctors colony cable	11KV	Jeedimetla	07.30	08.30	01.00	EL/OL	11kv end kit failure at plat no 610	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
39		Bowrampet	Junnurum	11KV	Jeedimetla	06.05	07.40	01.35	EL	Tree Branch fallen on the 11KV Line, AB Switch Spark at PGNR Common	-
40	RR N	Suraram	Martix	11KV	Jeedimetla	05.55	07.24	01.29	EL/OL	Due To Heavy Rain	-
41		Kandlakoya	Kandlakoya	11KV	Medchal	06.00	07.25	01.25	BD	Line AB Switch opened at Cheruvukatta (20% no supply)	-
42		Thumkunta	Thumkunta	11KV	Medchal	06.30	08.10	01.40	BD	Line AB Switch opened (No fault)	-
43		Aliabad	Majeedpur	11KV	Medchal	07.45	10.00	02.15	BD	100KVA DTR Cable failed at Shameerper Cheruvukatta	-
44		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	05.45	09.45	04.00	BD	11KV Jumper opened at Somanya Seeds (No fault)	-
45		Aliabad	Bommarajepet	11KV	Medchal	07.00	08.45	01.45	BD	No Fault	-
46		Aliabad	LGM Pet	11KV	Medchal	08.30	10.00	01.30	BD	No Fault	-
1		RR E	NGRI	Scientist colony	11KV	Habsiguda	05.45	06.40	00.55		Net cable fallen on 11kv at IDBA bank nagendra nagar
2	Uppal Kalsa		Venkateshwar temple	11KV	Habsiguda	05.59	08.40	02.41		Kites fallen on 11KV line at Bharath nagar	-
3	Idauppal		Srikrishna	11KV	Habsiguda	01.13	03.43	02.30		11KV jumper cut at Hyderabad security & Jumper open AFC hotel	-
4	Idauppal		Ramreddy nagar	11KV	Habsiguda	05.38	06.58	01.20		Kite stick fall on 11kvline at Sri ram colony	-
5	Uppal		Navbharath	11KV	Habsiguda	01.20	04.50	03.30		11KV jumper cut at Morden & tree branches fallen on 11kv line at X road	-
6	Uppal		Adarsh nagar	11KV	Habsiguda	03.30	05.20	01.50		2 nos jumper cut near Ss yard	-
7	Nacharam Indore		Mallikarjuna nagar	11KV	Habsiguda	05.44	10.12	04.28		11KV Insulator failed at Krishnaveni School	-
8	Uppal Bhagath		Saraswathi nagar	11KV	Habsiguda	01.28	06.40	05.12		Tree branches fallen on 11kv line at Nagole metro station	-
9	Boduppal		Surya Hills	11KV	Habsiguda	00.00	09.30	09.30		11KV Pin Insulator failed at Surya Hills Marrichettu (70% of Load B/F from 11KV Adarsha Nagar feeder at 3:00 to 9:30)	-
10	Moula-Ali		Mirzalguda	11KV	Sainikpuri	06.25	07.55	01.30		HG fuse Insulator failed Upperguda (L.Insp Venkateshwarulu)	-
11	NN Colony		Jai Jawan	11KV	Sainikpuri	06.15	10.00	03.45		33Kv Earth line fall on 11Kv line at Jiyareddy Nagar (AE/OP)	-
12	Ghatkesar		Yamannumpet	11KV	Keesara	04.30	06.30	02.00		11KV Disc failed at Sreenidhi College Opposite & PT failed at SS Yard	-
13	Aushapur		Ankushapur	11KV	Keesara	02.20	03.30	01.10		11KV line cut at Ruchi Daba	-
14	Aushapur		Edulabad AGL	11KV	Keesara	01.00	09.30	08.30		11KV Disc failed at Edulabad Village	-
15	Aushapur		Madharam	11KV	Keesara	06.00	08.30	02.30		Line Patrolling but no visible fault	-
16	Aushapur		Sandupatlaguda	11KV	Keesara	08.00	09.30	01.30		11KV Disc failed at Indian Petrol Bunk	-
17	Narapally		Prathap Singaram	11KV	Keesara	06.25	07.25	01.00		Tree branches fallen on 11kv line at Balaji Nagar	-
18	P&T Colony		Budda Nagar	11KV	Keesara	06.00	07.05	01.05		Banner Fallen on 11KV line at RTC Depot	-
19	P&T Colony		Canara Nagar	11KV	Keesara	06.05	07.10	01.05		Tree fallen on 11KV line at Budda Nagar Road No.08	-
20	P&T Colony		NIN	11KV	Keesara	06.15	07.30	01.15		Cable wire touched to 11KV line at P&T Colony	-
21	P&T Colony		Medipally	11KV	Keesara	06.50	10.00	03.10		11KV Insulator failed at Srinivasa Nagar Colony	-
22	Balaji Nagar		Dental College	11KV	Keesara	06.45	07.45	01.00		11KV Insulator failed at Gabbilalpet	-
23	Chengicherla		My Villas	11KV	Keesara	06.15	07.00	00.45		Tree branches fallen on 11KV line at Chinna Kranthi Colony	-
24	Chengicherla		Chengicherla	11KV	Keesara	06.30	07.15	00.45		11KV Insulator failed at Venkata Sai Nagar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Chilalguda	Pragatools	11KV	V	01.44	03.10	01.26	EL,OL-Rph	HT Jumper cut at Mekala Mandi	-
2		I.I.C.T	Deccan	11KV	V	01.52	03.04	01.12	EL,OL	Tree branches fallen on lines at Andal Mixture Shop	-
3		K.I.M.S	H.D.F.C	11KV	V	05.48	07.05	01.17	EL,OL-Y&Bph	No Visible Fault (due to Rain)	-
4		Bansilalpet	Naganna Kunta	11KV	V	06.15	07.28	01.13	EL,OL-Rph	Kite stick fault at Naganna Kunta	-
5		Vasanthapuri	Sripuri Colony	11KV	V	05.53	09.17	03.24	EL,OL	Pin Insulator flash over at Satya Colony	-
6		Seethaphalmandi	Namalagundu	11KV	V	05.30	08.32	03.02	EL,OL-Rph	No Visible Fault (due to Rain)	-
7		Bowenpally	Gowtham Nagar	11KV	VI	05.40	06.58	01.18	EL,OL-Y&Bph	No Visible Fault (due to Rain)	-
8		Bowenpally	I.A.F	11KV	VI	05.58	07.20	01.22	EL	No Visible Fault (due to Rain)	-
9		Tirumalgiri	Khanajiguda	11KV	VI	06.02	08.20	02.18	EL,OL-Bph	Brass Patti cut at Ambedkar Statue	-
10		Bowenpally	Gowtham Nagar	11KV	VI	07.23	08.35	01.12	EL,OL-R&Yph	No Visible Fault (due to Rain)	-
11		Bowenpally	Jaya Nagar	11KV	VI	07.28	09.35	02.07	EL,OL-Rph	No Visible Fault (due to Rain)	-
12		Bowenpally	I.A.F	11KV	VI	07.22	08.50	01.28	EL,OL-Rph	No Visible Fault (due to Rain)	-
13		New Bowenpally	Raju Colony	11KV	VI	05.07	06.43	01.36	EL	No Visible Fault (due to Rain)	-
14		I.D.P.L	SIFCO	11KV	VI	04.50	06.35	01.45	EL,OL-Bph	No Visible Fault (due to Rain)	-
15		I.D.P.L	Shivalayam	11KV	VI	04.50	06.35	01.45	EL	No Visible Fault (due to Rain)	-
16		I.D.P.L	I.E	11KV	VI	04.50	06.35	01.45	EL	Disc Insulator flash over at Kakatiya Ice Cream	-
17		New Bowenpally	Ali Complex	11KV	VI	06.00	07.18	01.18	EL,OL-Bph	No Visible Fault (due to Rain)	-
18		Marredpally	Ramsar Café	11KV	C-VI	02.00	03.15	01.15	EL,OL-Bph	No Visible Fault (due to Rain)	-
19		Gymkhana	Balaji Enclave	11KV	C-VI	01.35	04.30	02.55	EL,OL-Yph	Faulty loads of 11KV Bowenpally fdr	-
20		Gymkhana	Balamrai	11KV	C-VI	01.45	04.00	02.15	EL	No Visible Fault (due to Rain)	Partial fdr charged
21		Gunrock	Bowenpally	11KV	C-VI	01.30	04.50	03.20	EL	No Visible Fault (due to Rain)	-
22		Macha Bollaram	Madhura Enclave	11KV	C-VI	05.20	08.20	03.00	EL,OL-Bph	Tree branches fallen on lines at Madhura Enclave	-
23		Macha Bollaram	Chinthal Bazar	11KV	C-VI	05.30	07.25	01.55	EL,OL-Bph	DTR Fault at Chinthal Bazar	-
24		Macha Bollaram	Sai Reddy Nagar	11KV	C-VI	05.45	08.05	02.20	EL,OL-Rph	No Visible Fault (due to Rain)	-
25		Macha Bollaram	Ayyappa Nagar	11KV	C-VI	07.10	08.40	01.30	EL,OL-Bph	No Visible Fault (due to Rain)	-
26		Marredpally	Railway Colony	11KV	C-VI	07.00	08.50	01.50	EL,OL-Rph	No Visible Fault (due to Rain)	-
27		Marredpally	Military Hospital	11KV	C-VI	07.10	09.00	01.50	All Indication	No Visible Fault (due to Rain)	-
28		Alwal	Chandrapuram	11KV	C-VI	06.06	09.20	03.14	EL,OL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Mangapuram feeder
29		Addagutta	Addagutta	11KV	C-VI	05.50	07.50	02.00	EL	Auto Reclouser problem at Addagutta Petrol Bunk	-
30		Addagutta	Ambedkar Nagar	11KV	C-VI	06.10	08.30	02.20	EL	Tree branches on lines at Teachers Colony	-
31		Lodha	Hanuman Temple	11KV	IV	06.42	07.58	01.16	EL,OL-Bph	No Visible Fault (due to Rain)	-
32		Kundan Bagh	B.S.Maktha	11KV	IV	06.19	07.43	01.24	EL,OL-R&Yph	No Visible Fault (due to Rain)	-
33		Borabanda	SRT Nagar Market	11KV	IV	07.20	09.10	01.50	EL	AB Cable End Kit failed at Bharath Nagar Community Hall	-
34		Lodha	Hanuman Temple	11KV	IV	04.56	05.58	01.02	EL	No Visible Fault (due to Rain)	-
35		Borabanda	Kalyan Nagar Park	11KV	IV	04.45	08.55	04.10	EL	Pin Insulator flash over at Kalyan Nagar Park	-
36		Kalyan Nagar	Sri Ram Nagar	11KV	IV	05.54	08.36	02.42	EL,OL-Rph	No Visible Fault (due to Rain)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
37		Srinagar Colony	Srinagar Colony	11KV	X	04.50	08.30	03.40	EL,OL-Bph	No Visible Fault (due to Rain)	Arranged B/F on 11KV Eye Drusti fdr
38		MLA Colony	V.L.C.C	11KV	X	04.48	05.55	01.07	EL	No Visible Fault (due to Rain)	-
39	HYD N	Madhapur	Shilparamam	11KV	X	04.45	05.55	01.10	EL,OL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Value Lab fdr
40		Muffakamza College	Amrutha	11KV	X	06.18	08.12	01.54	EL	No Visible Fault (due to Rain)	-
41		Ravindra Society	Ayyanna Pride	11KV	X	05.40	06.55	01.15	EL,OL	No Visible Fault (due to Rain)	-
42		Muffakamza College	Nandi Nagar	11KV	X	07.30	09.20	01.50	EL	I/C Cable Jumper cut at Nandi Nagar	-
43		Road No.13	Gowri Shankar Nagar	11KV	X	05.55	07.18	01.23	EL,OL	No Visible Fault (due to Rain)	-
44		Kalyan Nagar	Jawahar Nagar	11KV	X	04.44	07.30	02.46	EL,OL-Rph	Conductor snapped at Jawahar Nagar	-
1		HYD S	Ch' Baradari	Ramnapura	11KV	III	04.46	06.35	01.49	EL,OL-Rph	Twisted HT lines at Chand Bai Meat Shop
2	Ch' Baradari		Bilal Nagar	11KV	III	04.48	07.00	02.12	EL	No Visible Fault (due to Rain)	-
3	Salarjung		Q.Q.Stadium	11KV	III	04.45	06.00	01.15	EL	No Visible Fault (due to Rain)	-
4	Panjasha		Gowlipura	11KV	III	04.54	07.34	02.40	EL	Disc Insulator flash over at Hanuman Temple	-
5	Panjasha		Gulzar House	11KV	III	07.32	09.35	02.03	EL	No Visible Fault (due to Rain)	-
6	Aliyabad		Shamsheer Gunj	11KV	III	04.53	09.19	04.26	EL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Sattar Bagh fdr
7	Aliyabad		Boys Town	11KV	III	04.55	08.30	03.35	EL	No Visible Fault (due to Rain)	-
8	Aliyabad		Sharada College	11KV	III	04.55	07.52	02.57	EL	No Visible Fault (due to Rain)	-
9	C.R.P.F		Baba Nagar	11KV	III	04.45	07.45	03.00	EL,OL-Rph	No Visible Fault (due to Rain)	Arranged B/F on 11KV C-Block fdr
10	Arundhathi Colony		Uppuguda	11KV	III	05.23	07.45	02.22	EL	Jumper Cut at Mahankali Temple	-
11	Falaknuma		Chatrinaka	11KV	III	05.05	08.50	03.45	EL,OL-Rph	Disc Insulator flash over at Sri Ram Nagar Colony	-
12	Panjasha		Sulthan Shai	11KV	III	21.20	23.03	01.43	EL	DTR Cable End Kit fault & 2no Insulator flash over at Bella	-
13	Chanchalguda		Chowni	11KV	VIII	05.03	06.45	01.42	EL,OL	Jumper Cut at Chowni	-
14	Arundhathi Colony		Habeeb Nagar	11KV	VIII	07.20	08.50	01.30	EL,OL	No Visible Fault (due to Rain)	-
15	Malakpet		Dabeerpura	11KV	VIII	06.12	09.26	03.14	OL-Rph	No Visible Fault (due to Rain)	Arranged B/F on 11KV Chanchalguda fdr
16	Malakpet		Azampura	11KV	VIII	05.09	06.45	01.36	EL,OL-Rph	No Visible Fault (due to Rain)	-
17	Teegalaguda		Shivalayam	11KV	VIII	05.14	08.05	02.51	EL	No Visible Fault (due to Rain)	-
18	Moosaram Bagh		Moosaram Bagh	11KV	VIII	05.20	09.20	04.00	EL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Shalivahan Nagar fdr & 11KV Sripuram Colony fdr
19	Arundhathi Colony		Fathesha Nagar	11KV	VIII	05.26	09.30	04.04	EL	No Visible Fault (due to Rain)	-
20	Teegalaguda		RTA Saleem Nagar	11KV	VIII	05.24	08.25	03.01	EL,OL-Bph	Disc Insulator flash over at RTA Office	-
21	Moosaram Bagh		A.B Colony	11KV	VIII	10.58	12.28	01.30	EL	Cable jumper cut at A.B Colony	-
22	Womens College		Victoriya Play Ground	11KV	IX	05.09	06.45	01.36	EL,OL	HT Line snapped at Puthli Bowli Junction	-
23	Osm.Hospital		Puthli Bowli	11KV	IX	07.35	08.50	01.15	EL,OL	No Visible Fault (due to Rain)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
24		Osm.Hospital	Osman Gunj	11KV	IX	05.25	07.54	02.29	All Indication	Jumper Cut at Osman Gunj	Arranged B/F on 11KV Feelkhana fdr
25		Jiyaguda	Samastha Narayana	11KV	IX	04.53	09.00	04.07	EL	Jumper cut & Kite stick fallen on lines at Samatha Narayana	-
26		Kulshumpura	Gandi Hanuman	11KV	IX	04.58	09.11	04.13	EL	Jumper cut at Gandi Hanuman	-
27		Karwan	Tappa Chabutra	11KV	IX	05.35	07.45	02.10	EL,OL-Rph	Tree branches fallen on lines at Pakeera Hotel	-
28	HYD S	Karwan	Tallagadda AB Cable	11KV	IX	05.15	07.50	02.35	EL,OL	Pin Insulator flash over at Annapurna Temple	-
1	HYD C	Narayanaguda	City Central Library	11KV	I	06.05	08.55	02.50	OL-Bph	Lines Twisted at Tyagaraya Sabha	-
2		Nizam College	Nizam College	11KV	I	07.01	08.28	01.27	EL,OL-Bph	No Visible Fault (due to Rain)	-
3		Hussain Sagar	Sadan College	11KV	I	06.01	07.30	01.29	All Indication	No Visible Fault (due to Rain)	-
4		Hussain Sagar	NTR Marg	11KV	I	07.25	08.50	01.25	All Indication	No Visible Fault (due to Rain)	-
5		Z.P.Office	Z.P.Office	11KV	I	05.24	07.45	02.21	EL	AB cable End Kit failed at Symphony Complex	-
6		Z.P.Office	Ramleela Maidan	11KV	I	05.27	07.47	02.20	EL	Pin Insulator flash over at Chitti Basti	-
7		Vittalwadi	Taj Mahal Hotel	11KV	I	07.55	09.40	01.45	EL	Tree branches fallen on line at King Koti	-
8		Lakeview	Lake View Guest House	11KV	I	08.02	11.25	03.23	EL	Cable End Kit failed at Lake View	-
9		Indirapark	Vivek Nagar	11KV	I	06.15	07.35	01.20	EL,OL	No Visible Fault (due to Rain)	-
10		Lakeview	Vijaya Hospital	11KV	I	07.20	09.43	02.23	EL,OL	Cable fault at Raj Bhavan Quarters	-
11		Jawahar Nagar	Jawahar Nagar	11KV	I	11.06	13.15	02.09	EL	Cabel fault	Arranged B/F on 11KV Post Office feeder
12		Industrial Area	Azamabad Key SS Cable	11KV	II	05.38	07.15	01.37	EL,OL-R&Bph	No Visible Fault (due to Rain)	-
13		Industrial Area	Azamabad Key SS OH	11KV	II	05.38	11.50	06.12	EL,OL-R&Bph	Jumper cut at Sandya Takies	-
14		Industrial Area	Ram Nagar	11KV	II	05.55	08.00	02.05	EL,OL-Bph	Removed loads of 11KV Vidya Nagar feeder	-
15		Industrial Area	Adikmett	11KV	II	06.00	10.30	04.30	EL,OL-Bph	Pin Insulator falsh over & Tree branches fallen on lines at Vidya Nagar	-
16		Fever Hospital	C.C.Sharaf Hospital	11KV	II	06.50	08.25	01.35	EL	No Visible Fault (due to Rain)	-
17		Golnaka	Harazpenta	11KV	II	01.45	03.19	01.34	All Indication	Faulty loads of 11KV Prabath fdr	-
18		Narayanaguda	Narayanaguda	11KV	II	04.55	06.45	01.50	EL	HT Jumper cut at No.6 DTR	-
19		Chilkaiguda	Parsigutta	11KV	II	05.52	08.55	03.03	EL	No Visible Fault (due to Rain)	-
20		Bathkamma Kunta	Indira Nagar	11KV	II	05.45	08.26	02.41	EL	No Visible Fault (due to Rain)	-
21		Fever Hospital	Kacheguda Railway Station	11KV	II	05.15	08.30	03.15	All Indication	No Visible Fault (due to Rain)	-
22		Fever Hospital	BKP Bus Depot	11KV	II	04.45	08.40	03.55	EL	No Visible Fault (due to Rain)	-
23		Chilkaiguda	Golconda X Road	11KV	II	05.40	09.35	03.55	EL,OL-Rph	No Visible Fault (due to Rain)	-
24		Amberpet	Patel Nagar	11KV	II	05.20	07.40	02.20	EL	O/G AB Switch Jumper cut at SS	-
25		Vittalwadi	Gandhi Kuteer	11KV	II	05.43	07.10	01.27	EL	No Visible Fault (due to Rain)	-
26		Narayanaguda	Preventive Medicine	11KV	II	07.35	09.20	01.45	EL,OL	Tree branches fallen on lines at Sundriya Park	-
27		Asif Nagar	Hakimpet	11KV	VII	04.44	09.58	05.14	EL,OL-Rph	Pin Insulator flash over at Allavath Colony	-
28		Asif Nagar	N.S.F Colony	11KV	VII	04.45	07.06	02.21	EL,OL-Bph	Tree branches fallen on lines at Akberpura	-
29		Asif Nagar	Market Yard	11KV	VII	04.50	06.07	01.17	EL	No Visible Fault (due to Rain)	-
30		Asif Nagar	Avalon	11KV	VII	06.17	07.18	01.01	EL	No Visible Fault (due to Rain)	-
31		Nampally	Red Hills	11KV	VII	06.09	09.15	03.06	EL,OL	Jumper cut at Nice Hospital	-
32		A.S.R.Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	05.56	08.10	02.14	EL,OL	No Visible Fault (due to Rain)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
33	HYD C	S.D.Hospital	Police Mess	11KV	VII	07.23	14.06	06.43	EL,OL	RMU fault & Jumper cut at Jubilee High School	09:56 Hrs Partial charged OK
34		Mothimahal	Risala Bazar	11KV	VII	06.17	07.34	01.17	EL,OL	No Visible Fault (due to Rain)	-
35		Mothimahal	Zinsi Bazar	11KV	VII	06.17	07.20	01.03	EL,OL	No Visible Fault (due to Rain)	-
36		Aditya Towers	Surya Nagar	11KV	VII	04.45	09.20	04.35	EL	No Visible Fault (due to Rain)	-
37		Mothimahal	Saleh Nagar	11KV	VII	06.02	11.30	05.28	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Fathe Darwaja fdr
38		ITI Mallepally	Afzal Sagar	11KV	VII	05.07	08.49	03.42	EL	No Visible Fault (due to Rain)	-
39		Mothimahal	Company Bagh	11KV	VII	04.53	05.56	01.03	EL,OL-Rph	No Visible Fault (due to Rain)	-
40		Mothimahal	Risala Bazar	11KV	VII	04.50	05.56	01.06	EL,OL-Yph	No Visible Fault (due to Rain)	-
41		Aditya Towers	Sabza Colony	11KV	VII	05.20	07.37	02.17	EL	No Visible Fault (due to Rain)	-
42		S.D.Hospital	Police Mess	11KV	VII	05.35	07.15	01.40	EL,OL-Bph	Tree branches fallen on lines at Maqsood PT	-
43		Golconda	Mothi Mahal	11KV	VII	04.50	08.40	03.50	EL	No Visible Fault (due to Rain)	-
44		Golconda	Narayanamma College	11KV	VII	05.10	07.08	01.58	EL,OL	No Visible Fault (due to Rain)	-
45		Nampally	Yousufin Darga	11KV	VII	06.10	08.45	02.35	EL,OL	No Visible Fault (due to Rain)	-
46		Asif Nagar	Military	11KV	VII	04.45	10.39	05.54	EL,OL-R&Yph	Tree branches fallen on lines at Military Area	-
47		Asif Nagar	Mehdipatnam OH	11KV	VII	06.31	08.14	01.43	EL	Cable fault at Moghal Apartment	-
48		Asif Nagar	Avalon	11KV	VII	07.31	08.34	01.03	EL,OL-Bph	Tree branches fallen on lines	-
49		ITI Mallepally	Zahara Masjid	11KV	VII	17.17	18.35	01.18	EL,OL	Cabel fault	Arranged B/F on 11KV Cresent Hospital fdr