

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	9	31	9	31	9	31			
2	NLG	144	988	1	18	1	18	1	18			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	10	52	10	52	10	52	0	0	
	Grand Total	1082	6468	10	55	10	55	10	55	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 15.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Hanwada	33KV	Mahabubnagar	05.35	10.00	04.25	E/L&O/L	Insulators Failed at Boyapally(V)	Hanwada	-
2		220/132KV SS Palkonda	Janampet	33KV	Mahabubnagar	04.20	07.36	03.16	E/L&O/L	Isolator Opened at Pothulamadugu	Janampet	-
3		Makthal	Utkoor	33KV	Narayanapet	03.55	07.55	04.00	E/L	Due to Rain No Visible Fault	Utkoor	-
4		Maddur	Vepoor	33KV	Narayanapet	03.55	05.00	01.05	E/L	Due to Rain No Visible Fault	Vepoor	-
5		Marikal	Devarkadra	33KV	Narayanapet	06.00	07.15	01.15	E/L	Due to Rain	Devarkadra	Alternate Supply Arranged From 33KV Koukuntla SS at 7:15Hrs
6		Puttapad	Salkarpet	33KV	Narayanapet	02.35	09.56	07.21	E/L&O/L	Line Petrolling Done & Tree Branches Removing on the Line Near Salkarpet SS	Salkarpet	-
7		Balanagar	Rajapur	33KV	Jadcherla	03.05	06.00	02.55	E/L	Pomal AB Switch Opened at Rajapur Supply Stood OK	Rajapur	-
8		Balanagar	G.R Cable	33KV	Jadcherla	16.30	17.30	01.00	E/L&O/L	Tree Branch Fallen on the line near Rangareddy gudem	G.R Cable	-
9		Thirumalaipally	Veltoor	33KV	Wanaparthy	06.25	06.43	00.18	E/L	Due to Rain	Veltoor	Alternate Supply Arranged From 33KV Peddamandadi at 6:43Hrs
1	NLG	Nalgonda	Rayanguda	33KV	Nalgonda	05.57	10.16	04.19	EL	Pin insulator failed	Rayanguda	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 15.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Machanpally	Manikonda	11KV	Mahabubnagar	09.00	12.30	03.30		11KV LC Phase to Phase Near Manikonda(vi)	-
2		Koukuntla	Muchinthalla	11KV	Mahabubnagar	05.30	08.35	03.05		11KV Phase to Phase at Muchinthalla	-
3		Kodur	Zamistapur	11KV	Mahabubnagar	07.00	08.15	01.15		11KV Tree Fallen Conductor Near Zamistapur	-
4		Narwa	Raicode	11KV	Mahabubnagar	07.00	09.50	02.50		11KV Conductor cut Rajpally(vi)	-
5		Bijwar	MAQDUMPUR	11KV	Narayanapet	03.00	11.00	08.00		11kv disk failed at sab sation yard	-
6		Utkoor	PAGIDIMARRY	11KV	Narayanapet	07.39	08.18	00.39		11KV Jumper cut at ameenpur vlg	-
7		Jaklair	JAKLAIR	11KV	Narayanapet	03.35	06.30	02.55		Break down due to rain fall	-
8		Jaklair	JAKLAIR	11KV	Narayanapet	04.00	06.00	02.00		Break down due to rain fall	-
9		Maganoor	MAGANOR	11KV	Narayanapet	03.48	04.15	00.27		Break down due to rain fall	-
10		Gudeballore	SATAYASAI & LIFT	11KV	Narayanapet	03.40	09.10	05.30		11KV Conductor cut and tree cutting at nalla gattu	-
11		PERAPALLA	SHASHANPALLY	11KV	Narayanapet	03.30	08.50	05.20		11kv jumper cut and fallen on DTR at kothapally vlg	-
12		KYATHANPALLY	WATTUGUNDLA	11KV	Narayanapet	02.22	07.38	05.16		Break down due to pole damage	-
13		MOGALMADKA	MOGALMADKA RURAL	11KV	Narayanapet	08.37	09.25	00.48		Break down due to line testing	-
14		DHANWADA	DHANWADA RURAL	11KV	Narayanapet	04.36	10.30	05.54		11kv line cut at dhanwada rural	-
15		DHANWADA	KAMSANPALLY	11KV	Narayanapet	04.50	08.45	03.55		11kv line cut at kamsanpally	-
16		Mohammadabad	Annareddypally	11KV	Narayanapet	06.30	08.30	02.00		11kv line cut at Annareddypally vg	-
17		Kosgi	Sampally	11KV	Narayanapet	04.00	06.30	02.30		11KV Conductor damaged at Nagasanpally & 11KV Insulator faile at Thimmaipally vg	-
18		Kosgi	Nacharam	11KV	Narayanapet	04.25	07.00	02.35		Break Down due to AB Switch Burnt at Nacharam vg	-
19		Kosgi	Bhakthimalla	11KV	Narayanapet	04.00	06.00	02.00		11KV Insulator failed Near Kosgi Agl	-
20		K V Pet	Bandameedipally	11KV	Jadcherla	07.10	11.02	03.52		11Kv Jumper Cut Near Bandameedipally (Vi)	-
21		Bhoothpur	Amistapur Agl	11KV	Jadcherla	03.10	12.35	09.25		Braker Limb Fail Near SS	-
22		Bhoothpur	Rural	11KV	Jadcherla	03.30	05.05	01.35		11Kv Jumper Cut Near Bhoothpur (Vi)	-
23		Kodgal	Kodgal Agl	11KV	Jadcherla	03.00	08.45	05.45		HT/LT Near Laxmi Nagar Tanda side.	-
24		Rajapur	Chennavelly	11KV	Jadcherla	04.00	10.00	06.00		11Kv Pin Insulator Failure Near Gundom Bavi Kucharkal (Vi)	-
25		Rajapur	Mallepally	11KV	Jadcherla	05.00	10.00	05.00		11Kv Jumper Cut Near Mallepally (Vi)	-
26		Kothamolgara	Kothamolgara	11KV	Jadcherla	06.30	12.00	05.30		11Kv Insulator Failure Near Chinna Kappeta(Vi)	-
27		Kothamolgara	Elikicherla	11KV	Jadcherla	10.00	13.00	03.00		11Kv Disc Fai Near Elikicherla(Vi)	-
28		Nawabpet	Nawabpet	11KV	Jadcherla	06.45	12.10	05.25		11Kv Jumper Cut Near Kucharkal (Vi)	-
29		Nawabpet	KOLLUR	11KV	Jadcherla	06.45	12.10	05.25		11Kv Jumper Cut Near Kucharkal (Vi)	-
30		Marikal	Malkapur	11KV	Jadcherla	02.30	09.30	07.00		11Kv jumper cut Near Agraharam(Vi)	-
31		Marikal	Chakalpally	11KV	Jadcherla	02.30	11.45	09.15		11KV Insulator Failure Near Chakalpally(Vi)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mukundapuram	Mukundapuram	11KV	Huzurnagar	06.30	08.45	02.15	EL	11 KV LINE SNAPPED	-
2		Gondiryala	Gondiryala-1	11KV	Huzurnagar	04.45	07.15	02.30	EL	11 KV JUMPER CUT	-
3		Chandur	Gundrapally	11KV	Nalgonda	04.38	08.00	03.22	EL	11KV Jumper cut	-
4		Katangur	Bollepally	11KV	Nalgonda	06.15	08.30	02.15	EL	Tree branch fallen on line	-
5		Katangur	Mallaram	11KV	Nalgonda	05.30	09.50	04.20	EL	11KV line cut at Perindevigudem(V)	-
6		Aitipamula	Dugunelly	11KV	Nalgonda	06.15	07.00	00.45	EL	Tree branch fallen on line	-
7		Aitipamula	Rasoolgudem	11KV	Nalgonda	03.16	10.00	06.44	EL	Tree branch fallen on line	-
8		Kanagal	Kanagal AGL	11KV	Nalgonda	03.50	10.00	06.10	EL	11KV Jumper cut	-
9		Kanagal	Lachugudem	11KV	Nalgonda	03.50	10.00	06.10	EL	11KV Jumper cut	-
10		Turkapally	Hydalapur	11KV	Nalgonda	05.45	14.40	08.55	EL	Tree fallen on line near Boddu Anjaiah well	-
11		Turkapally	Turkapally AGL	11KV	Nalgonda	07.30	09.50	02.20	EL	11KV Insulator failed	-
12		Palem	Bopparam	11KV	Nalgonda	06.55	10.15	03.20	EL	11KV Disc failed	-
13		Baironibanda	N.G.Kothapally	11KV	Nalgonda	08.50	10.10	01.20	EL	11KV Jumper cut	-
14		Kethepally	Cheekatigudem	11KV	Nalgonda	08.20	09.15	00.55	EL	11KV Jumper cut	-
15		Mushampally	Mushampally AGL	11KV	Nalgonda	09.00	11.30	02.30	EL	11KV Jumper cut	-
16		AD Pally	Ulsaipalem	11KV	Miryalagudem	06.30	10.55	04.25	EL	Coductor Snaped at Ulsaipalem	-
17		Utlapally	Yadgarpally	11KV	Miryalagudem	06.35	10.35	04.00	EL	Tree Branches fallen near yadgarpally	-
18		Buggabaigudem	Thimmareddygudem Old	11KV	Miryalagudem	10.40	12.45	02.05	EL	Coductor Snaped at Buggabaigudem Agl	-
1	SDP	KOKKONDA	KOTTUR	11KV	Gajwel	10:05	15:10	05:05		11KV JUMPER CUT	-
2		DUDEEDA	DUDEEDA RAMPALLY	11KV	Gajwel	08:50	09:36	0:56		TREE BRANCH FALL OVER 11 KV	-
3		Cherial Town	Gattu thota	11KV	Husnabad	10.10	10.55	00.45		HT/LT Line fault	-
1	RR N	Aliabad	Majeedpur	11KV	Medchal	16.07	19.50	03.43		11KV Line AB Switch opened at Ratnalayam Temple (11KV Pole damaged by Car at Majeedpur)	-
2		Jeedimetla-I	APIIC Colony	11KV	Jeedimetla	12.20	14.20	02.00		AB Cale Bunt out at BalajiApt, APIIC Colony	-
1	HYD C	Bathkammakunta	D.D.Colony	11KV	II	02.48	05.18	02.30	EL	Rat fallen on DTR at Kasturi Apts	-