

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	9	4	9	4	9			
2	NLG	144	988	2	2	2	2	2	2			
3	MDK	107	933		1		1		1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>6</b>	<b>15</b>	<b>6</b>	<b>15</b>	<b>6</b>	<b>15</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>6</b>	<b>25</b>	<b>6</b>	<b>25</b>	<b>6</b>	<b>25</b>	<b>0</b>	<b>0</b>	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koukuntla	33KV	Mahabubnagar	00.30	04.25	03.55	E/L	Tree Branches fallen on the Line	Koukuntla	No
2		Makthal	Jaklair	33KV	Narayanapet	12.30	12.40	00.10	E/L	Pin Binding Replaced	Jaklair	Alternate Supply Arranged From Bijwar at 12:40Hrs
3		Chinnamaroor	Velgonda	33KV	Wanaparthi	00.35	00.45	00.10	E/L&O/L	Tree Branches fallen on the Line	Velgonda	Alternate Supply Arranged From 33KV Chinnamaroor at 00:45Hrs
4		Nagarkurnool	Manthathi	33KV	Nagarkurnool	8:10	9:45	1:35	O/L	Due to Crane Fallen on the Line Removed	Manthathi	No
1	NLG	S.Gouraram	Akkenapally	33KV	Nalgonda	2:20	11:00	8:40	EL	Tree Branches and Grass Fallen on the Line	Akkenapally	No
2		132 KV SS Wadapally	Damarcherla	33KV	Miryalaguda	00.50	05.15	04.25	EL	Pole damage due to hit by bus near lorry yard Wadapally	Damarcherla	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Sarjakhapet	Hakeempet	11KV	Narayanapet	09.17	11.00	01.43		11KV wire cut at pollepally vg	No
2		Jaklair	JAKLAIR	11KV	Narayanapet	00.35	06.00	05.25		Break down due to rain fall	No
3		Paspula	SATYARAM	11KV	Narayanapet	03.20	06.00	02.40		Break down due to rain fall	No
4		Mustipally	MUSTIPALLY	11KV	Narayanapet	1:20	2:50	1:30		Break down due to rain fall	No
5		Mustipally	SATYARAM	11KV	Narayanapet	2:23	5:15	2:52		Break down due to rain fall	No
6		Manthangoud	KATHWAR	11KV	Narayanapet	1:00	6:00	5:00		Break down due to rain fall	No
7		Manthangoud	KATROPALLY	11KV	Narayanapet	1:00	6:00	5:00		Break down due to rain fall	No
8		NARAYANPET	JALALPUR	11KV	Narayanapet	8:33	11:47	3:14		Break down due to 11kv line cut at byram konda road	No
9		Donur	Crussar	11KV	Jadcherla	00.00	07.00	07.00		BD Tree Follon the line near donur	No
1	NLG	Aitipamula	Rasulgudem	11KV	Nalgonda	5:20	9:00	3:40	EL	Tree Fallen on the 11 KV Line	No
2		Eduloor	Parada	11KV	Nalgonda	13.45	17.30	03.45	EL	11 KV Jumper Cut Under SS-45	No
1	MDK	SOL	Markwell	11KV	Sangareddy	17:05	18:20	1:15		Jumper Cut	No
1	SDPT	Akkannapet	Pakilnayak Thanda	11KV	Husnabad	12:33	13:17	0:44		Bross Patty cut	No
2		PREGNAPUR	PREGNAPUR TOWN	11KV	Gajwel	06.40	07.34	00.54		CONDUCTOR SNAPPED	No
3		MULUGU	MULUGU AGL	11KV	Gajwel	14:02	18:10	04.08		INSULATOR FAILED	No
1	RR N	Jeedimetla-I	Nitco	11KV	Jeedimetla	19:20	20:35	1:15	OL	Tree Branchesh fallen the 11kv line at Globle technical, Back side Ranga theater	No
2		Thumkunta	Thumkunta	11KV	Medchal	07.40	08.52	01.12		Tree Fallen on 11KV Line at Mandaipally Road	No
3		Bommarajpet	Karkamma	11KV	Medchal	10.20	11.15	00.55		Tree Fallen on 11KV Line at Subramanya Thota,Bommarajpet	No
4		Ravalkole	IDA Ravalkole	11KV	Medchal	16.30	17.00	00.30		11KV Pin Insulator failed at Kashimbhai thanda	No
1	RR E	Uppal	Navabharath	11KV	Habsiguda	16:05	16:50	0:45		11KV UG Cable failed due to JCB Work at Golkonda Printing Press	No
2		P&T Colony	NIN	11KV	Keesara	08.05	09.50	01.45		11KV Cable kit lug cut at SS Yard	No
1	HYD S	Gosha Mahal	M.J.Market	11KV	IX	06.32	08.15	01.43	EL,OL-Rph	Cable fault at M.J.Market	No
2		Gosha Mahal	Hindi Nagar	11KV	IX	6:32	8:18	1:46	EL,OL-Rph	Jumper cut at Chaknawadi	No
3		Malakpet	Komatiwadi	11KV	VIII	15:05	16:30	1:25	EL,OL-R&Yph	UG Cable End Kit at Balsetty Keth	No
4		Kulsumpura	Gandi Hanuman	11KV	IX	15:23	16:55	1:32	EL	Cable burntout at Hari Darga DTR	No