

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		18		18		18			
8	Hyd	194	1044	1	20	1	20	1	20			
	Total	606	3055	1	43	1	43	1	43	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		5		5		5			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	2	50	2	50	2	50	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Shathavahana	33KV	Patancheru	15:05	18:05	3:00		B/D Due Conductor Snapped	Shathavahana	No
1	HYD S	220KV Ch.Gutta	Madannapet	33KV	Malakpet	02.01	02.08	00.07		Tripped on EL, OL R-Phase	Madannapet	Alternate supply arranged.

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	PERAPALLA	PERAPALLA	11KV	Narayanapet	12.31	13.18	00.47		break down due to fire blown to DTR at perapalla vlg	No
2		MOGALMADKA	MOGALMADKA(T)	11KV	Narayanapet	11.00	11.59	00.59		break down due to 11kv conductor cut at mogalmadka vlg	No
1	NLG	Endugula	Kothagudam	11KV	Nalgonda	12:40	13:40	1:00	EL	11KV Jumper Cut	No
2		K.M.Pally	K.M.Pally Town	11KV	Devarakonda	16.20	17.20	01.00	EL	Insulotor Failed	No
3		K.M.Pally	Chennaram	11KV	Devarakonda	16.20	17.20	01.00	EL	Melt on the Line	No
4		Gondiryala	Chimiryala	11KV	Huzurnagar	07.20	09.00	01.40	EL	11 KV LINE SNAPPED	No
5		Choutuppal	Chinnakondur	11KV	Choutuppal	8:00	10:51	2:51	EL/OL	11 kv Line snapped & 11 KV Jumper snapped near Chinnakondur village	No
1	RR N	Dulapally	Karthika Vanam	11KV	Medchal	7:24	9:08	1:44		2 No 11KV Pin Insulators failed and Lizard fallen on 11KV Line at Azent industry backside	No
2		Subhash Nagar	Pragha Tools	11KV	Medchal	15.28	16.43	01.15		11KV Line AB Switch opened at Mayuri Bar	No
3		Subhash Nagar	Gayatri Nagar	11KV	Medchal	15.28	16.18	00.50		Tree fallen on the 11KV Line at Gayathri Nagar	No
4		Subhash Nagar	Gayatri Nagar	11KV	Medchal	17.56	19.27	01.31		Lizard fallen on the 11KV Line at Parivar Apartments	No
5		UMCC	Mahadevpuram	11KV	Medchal	18:30	18:50	0:20		Line AB Switch opened at Jacinka Garden(11KV Cable endkit failed)	No
1		Sainikpui	Defence Colony	11KV	Sainikpuri	13:54	14:32	0:38		11KV Jumper cut at Defence Colony	No
2		Vayuprui	Vayuprui	11KV	Sainikpuri	15.25	16.37	01.12		Ground Patrolling Done But No Fault Done Due to Heavy Rain and wind	No
3		Moula ali	Mirzalguda	11KV	Sainikpuri	15.36	16.59	01.23		Tree fallen on 11KV line at Upperguda	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
4	RR E	Vinyak Nagar	RK Nagar	11KV	Sainikpuri	15.36	16.50	01.14		Tree branches fallen on 11Kv line at Madhuri Diagotic Centre	No	
5		Malkajgiri	Hanumapet	11KV	Sainikpuri	15.38	17.13	01.35		11KV Jumper cut at MK Nagar Railway Station Due to Heavy Rain and wind	No	
6		Sainikpuri	Defence Colony	11KV	Sainikpuri	16.10	17.21	01.11		Coconut branches fallen on 11KV line at Defence Colony	No	
7		Janapriya	Shalivahana	11KV	Sainikpuri	16.50	17.44	00.54		Tree fallen on 11KV line and line Twisting at Hitech Colony	No	
8		Anand Bagh	Kalyan Nagar	11KV	Sainikpuri	15.32	17.23	01.51		Tree branches fallen on 11KV line at Klayan Nagar	No	
9		Yapral	Yapral	11KV	Sainikpuri	15.20	16.40	01.20		Tree branches fallen on 11Kv line at Yapral and Due to Heavy Rain and wind	No	
10		Anand Bagh	Kruppaand	11KV	Sainikpuri	15.35	17.44	02.09		Bird fallen 11Kv line Cross aram and line Twisting and coconut branches fallen on 11Kv line at lakshmi nagar and Anand Bagh	No	
11		Anand Bagh	Shivapuri	11KV	Sainikpuri	15.33	17.40	02.07		Tree fallen on 11KV line and line Twisting at Shivapuri	No	
12		Yapral	Pradhampuri	11KV	Sainikpuri	15.40	17.30	01.50		Tree branches fallen on 11KV line at Pradhampuri	No	
13		Yapral	Govt School	11KV	Sainikpuri	15.40	18.00	02.20		Tree fallen on 11Kv line and Due to Heavy Rain at Govt School	No	
14		Mallapur-2	Narsimha Nagar	11KV	Habsiguda	15.40	16.39	00.59		Tree fallen on Pole & Pole damaged at Sai Garden	No	
15		Nacharam Indore	Ram Reddy Nagar	11KV	Habsiguda	15.57	16.48	00.51		11KV line twisted at Chandraiah Hotel (30% Load charged at 16:23)	No	
16		Keesara	Vardhana	11KV	Keesara	17.30	18.10	00.40		11KV Disc failed at Godumakunta ORR	No	
17		Aushapur	Ankushapur	11KV	Keesara	17.40	19.10	01.30		11KV Line cut at Princeton College	No	
18		Nagaram	S.N Colony	11KV	Keesara	15:50	16:26	0:36		Line Patrolling but no visible fault	No	
1		HYD N	Macha Bollaram	Madhura Enclave	11KV	C-VI	15.22	16.40	01.18	EL	Tree branches fallen on lines at Bharathi Nagar	No
2			Macha Bollaram	Ayyappa Nagar	11KV	C-VI	15:28	17:05	1:37	A/R Tripped	No Visible Fault	No
3			R.P.Nilayam	Naga Devatha	11KV	C-VI	15:30	17:45	2:15	EL,OL	No Visible Fault (due to Rain)	No
4	Gunrock		Lal Bazar	11KV	C-VI	15:45	17:10	1:25	EL	Tree branches fallen on lines at Lal Bazar	No	
5	R.P.Nilayam		Vaishnavi Matha	11KV	C-VI	15:56	17:26	1:30	EL	Tree branches fallen on lines at Vaisnavi Matha Temple	No	
6	Gunrock		A.W.H.O Colony	11KV	C-VI	16:05	18:10	2:05	EL,OL	Tree branches fallen on lines at AWHO Colony	No	
7	Bhudevi Nagar		Adarsh Nagar	11KV	C-VI	16:20	17:30	1:10	EL,OL	Tree branches fallen on lines at Venkatapuram	No	
8	Sanjeevaiah Park		Police Line	11KV	C-VI	17:45	18:59	1:14	A/R Tripped	No Visible Fault (due to Rain)	No	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
9		Jana Priya	Bharath Nagar	11KV	IV	17.55	19.05	01.10	EL	Tree branches fallen on lines at Bharath Nagar Ground	No
1	HYD S	Malakpet	Chaderghat	11KV	VIII	01.05	02.40	01.35	EL,OL-Yph	DTR Cable fault at Kamala Nagar & faulty loads of 11KV Noorkhan Bazar fdr (1No. DTR kept Off)	Arranged B/F on 11KV Abid Ali Eye Hospital fdr
2		Gunj	Judges Colony	11KV	VIII	18:04	19:58	1:54	OL-Rph	Post type Insulator flash over at Indo American Hospital	No
3		Salarjung	Purani Haveli	11KV	III	23:30	1:40	2:10	EL,OL	Cable fault at Chetta Bazar	Arranged partial B/F on 11KV Salarjung Museum fdr
1	HYD C	Golconda	Narayanamma College	11KV	VII	10.25	11.27	01.02	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Brindavana Colony fdr
2		Indira Park	Domalguda	11KV	I	17.51	20.00	02.09	EL	Tree branches fallen on lines at Lezend Apts	No
3		Chilkaiguda	Golconda X Road	11KV	II	17.54	19.10	01.16	EL,OL-Rph	Pin Insulator flash over at J.J.Motors	No
4		Vittalwadi	Y.M.C.A	11KV	II	17.55	19.18	01.23	EL	Pin Insulator flash over at HDFC Bank	No
5		Indira Park	Datta Nagar	11KV	I	17.55	19.35	01.40	EL	Tree branches fallen on lines at Datta Nagar	No
6		I.T.I Mallepally	Afzal Sagar	11KV	VII	18.04	19.22	01.18	EL	No Visible Fault (due to Rain)	Arranged B/F on 11KV Nampally Hospital fdr
7		Vittalwadi	APCO	11KV	II	18:50	20:10	1:20	EL,OL	Tree branches fallen on lines (4No DTR's kept off)	No
8		Vittalwadi	APCO	11KV	II	21.00	23.30	02.30	EL,OL-Rph	Tree branches & Kite Sticks fallen on lines (3No DTR's kept off)	No