

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	2	15	2	15	2	15			
3	MDK	107	933									
4	SDPT			1	6	1	6	1	6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	22	3	22	3	22	0	0	
	Grand Total	1082	6468	3	24	3	24	3	24	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 21.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	KMPally	SLBC	33KV	Devarakonda	16.40	18.44	02.04		Due to Heavy Wind & Rain	SLBC	-
2		KMPally	Neredugomma	33KV	Devarakonda	17.15	20.50	03.35		Due to Heavy Wind & Rain	Neredugomma	-
1	SDPT	Husnabad	Katkur	33KV	Husnabad	19.30	21.30	02.00		Jumper cut	Katkur	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 21.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Salkarpet SS	Thalapump	11KV	Narayanapet	11.10	11.35	00.25		Break down Due to 11KV pin insulator damaged at Thalapump Agl	-
1	NLG	Gundepuri	Gundepuri	11KV	Suryapet	04.00	07.50	03.50	EL	Insulator failed	-
2		Choutuppall Ipds	Damera Agl	11KV	Choutuppall	06.05	07.44	01.39	EL	11 KV Pole damage near Thangedipally village	-
3		K.M.Pally	C.A.Pally	11KV	Devarakonda	16.40	18.10	01.30	EL	Due to Heavy Wind & Rain pin insulator	-
4		Kopple	Bollaram	11KV	Devarakonda	16.40	17.20	00.40	EL	Due to Heavy Wind & Rain pin insulator	-
5		Jununthala	Makkapally	11KV	Devarakonda	17.15	18.10	00.55	EL	Due to Heavy Wind & Rain pin insulator	
6		Marriguda	Tammadapally	11KV	Devarakonda	16.40	18.05	01.25	EL	Due to Heavy Wind & Rain pin insulator	
7		Sivanagudem	K.B.Pally	11KV	Devarakonda	16.40	18.22	01.42	EL	Due to Heavy Wind & Rain AAA Conductor Snnaped	
8		Vaddipatla	Vaddipatla	11KV	Devarakonda	17.15	18.10	00.55	EL	Due to Heavy Wind & Rain AAA Conductor Snnaped	
9		Angadipeta	Angadipeta	11KV	Devarakonda	16.40	18.10	01.30	EL	Due to Heavy Wind & Rain pin Conductor Joined	
10		Kothapally	Peddamunigal	11KV	Devarakonda	16.40	18.00	01.20	EL	Due to Heavy Wind & Rain pin insulator	
11		Kothapally	Kasurajpally	11KV	Devarakonda	17.15	18.10	00.55	EL	Due to Heavy Wind & Rain pin insulator	
12		Teldevarapally	Teldevarapally	11KV	Devarakonda	16.40	18.21	01.41	EL	Due to Heavy Wind & Rain pin insulator	
13		Cherukupally	Dindi Rural	11KV	Devarakonda	16.40	18.10	01.30	EL	Due to Heavy Wind & Rain pin insulator	-
14		Chinthapally	vinjamoor	11KV	Devarakonda	17.15	17.48	00.33	EL	Due to Heavy Wind & Rain pin insulator	-
15		V.K.Palem	Srinivasnagar	11KV	Miryalaguda	02.40	08.00	05.20	EL	11KV conductor snapped	-
1	SDPT	Dubbak	Lachapet	11KV	Siddipet	06.20	08.29	02.09		B/D 11 KV Wire cut LC No.15631	-
2		Dubbak	Lachapet	11KV	Siddipet	16.53	17.25	00.32		B/D Tree branches folldown LC No.15632	-
3		PREGNAPUR SS	AKKARAM FEEDER	11KV	Gajwel	10.20	11.50	01.30		CONDUCTOR CUT	-
4		Husnabad	Husnabad Town-1	11KV	Husnabad	18.20	18.30	00.10		Jumper open	-
5		Husnabad	Husnabad Town-2	11KV	Husnabad	00.45	01.15	00.30		Jumper open	-
6		Potharam	Nagaram	11KV	Husnabad	20.20	21.15	00.55		Phase problem, same rectified	-
1	RR E	Mallapur	Standed tiles	11KV	Habsiguda	07.45	09.50	02.05		CT/PT Smoke at Mangal Chand & Jumper cut at Apollo Pharamache	-
1	HYD N	Gunrock	Subhash Nagar	11KV	C-VI	04.20	05.50	01.30	EL,OL-Rph	Disc Insulator flash over at Ravi Colony	