

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	11	1	11	1	11	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 25.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Achampet	33KV	Nagarkurnool	15.55	16.20	00.25	O/L	Tree Branch Fallen on the line near Maduranagar Colony	Achampet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 25.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Singarajpally	Singarajpally	11KV	Devarakonda	04.30	09.50	05.20	EL	Conductor Snapped & Pin insulator failed	-
2		Mudigonda	Gottimukkala	11KV	Devarakonda	14.50	19.10	04.20	EL	Conductor Snapped	-
3		Palvai	M.K.Gudem	11KV	Devarakonda	11.50	13.10	01.20	EL	pin insulator failed	-
4		MT.Pally	Mogilipka	11KV	Choutuppall	08.00	10.28	02.28	EL	11 kv Line snapped near Mogilipaka village	-
1	MDK	Zaheerabad	CH. Hyderabad	11KV	Zaheerabad	09.25	10.50	01.25		BD due to Jumper cut	-
1	RR N	Jagathgirigutta	IDA Jagathgirigutta	11KV	Medchal	17.25	18.02	00.37	EL	11KV Cable failed at Sanjaypuri Colony	-
2		Aliabad	HBL	11KV	Medchal	07.25	11.10	03.45	EL	11KV Conductor and replaced at BC Hostel, Aliabad	-
1	RR E	Moula-Ali	Mirzalguda	11KV	Sainikpuri	12.30	14.30	02.00		Stick fallen on 11Kv line at Opposite HMT Company Gate (Artisan Raju/Mallesh)	-
1	HYD N	Patigadda	KIMS Road	11KV	V	11.30	13.20	01.50	EL	I/C Cable fault at KIMS Nursing Hostel	12:12Hrs Arranged partial loads B/F on 11KV D.V.Colony fdr
1	HYD S	Kandikal Gate	Saibaba Nagar	11KV	III	16.25	18.05	01.40	EL,OL-R&Bph	Cable fault (1No. DTR kept off)	Arranged B/F on 11KV Saibaba Nagar fdr
1	HYD C	Industrial Area	RTC X Road	11KV	II	18.55	20.50	01.55	EL,OL-Rph	Standby Cable fault at Bawarchi Hotel	-----