

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	6	1	6	1	6	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 26.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Zaheerabad	Old Allana	33KV	Zaheerabad	00.45	16.45	16.00		BD due to Pin binding work		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 26.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jaklair	Bondalkunta	11KV	Narayanpet	01.00	08.00	07.00		Due to Eagle Fallen on 11KV line at Edavelly(V)	-
1	NLG	D Nagaram	W Kota	11KV	Suryapet	10.45	11.45	01.00	E/L	11Kv Insulator failed	-
1	MDK	MIG	HUDA	11KV	Patancheru	11.50	12.35	00.45		BD Due to Insulator Failure	-
1	SDPT	Mulugu	Mulugu AGL	11KV	Gajwel	16.30	19.00	02.30		Tree fallen	-
2		Mulugu	Bailampur	11KV	Gajwel	15.20	16.20	01.00		Tractor touch to LT line	-
3		Chilasagar	Shutdown	11KV	Gajwel	11.30	12.10	00.40		LIMBS Cheaking	-
1	HYD S	Kandikal Gate	Rakshapuram	11KV	Charminar	22.45	01.05	02.20	EL,OL	Cable fault damaged by GHMC wing	23:43Hrs Partial fdr loads added on 11KV Balapur fdr & remaining loads added on 11KV Neelam Center fdr