

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		9		9		9			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	15	0	15	0	15	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	4	1	4	1	4			
2	NLG	144	988									
3	MDK	107	933	15	6	15	6	15	6			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	16	17	16	17	16	17	0	0	
	Grand Total	1082	6468	16	32	16	32	16	32	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 27.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Amith Cotton Mill	33KV	Jadcherla	05.05	06.45	01.40	OL	Tree Branches Touched to the Line	Amith Cotton Mill	-
1	MDK	Kandi	HFC I	33KV	Sangareddy	18.35	22.35	04.00		BD due to Tree branches fallen on line	HFC I	-
2		Kandi	ITW Signode	33KV	Sangareddy	18.50	23.55	05.05		BD due to Tree branches fallen on line	ITW Signode	-
3		Kandi	ACE Tyres	33KV	Sangareddy	18.35	23.35	05.00		BD due to Conductor snapped	ACE Tyres	-
4		Pashamailaram	Isnapur	33KV	Sangareddy	20.15	21.20	01.05		BD due to Conductor snapped	Isnapur	-
5		Pashamailaram	EPIP	33KV	Sangareddy	19.35	21.25	01.50		BD due to Jumper cut	EPIP	-
6		Pashamailaram	EPIP II	33KV	Sangareddy	18.35	21.25	02.50		BD due to Jumper cut	EPIP II	-
7		Pashamailaram	SOL	33KV	Sangareddy	18.40	21.20	02.40		BD due to Conductor snapped	SOL	-
8		Pashamailaram	BPL	33KV	Sangareddy	18.45	21.25	02.40		BD due to Jumper cut	BPL	-
9		Pashamailaram	Manjeera	33KV	Sangareddy	17.45	21.20	03.35		BD due to Conductor snapped	Manjeera	-
10		Pashamailaram	GTN	33KV	Sangareddy	18.18	21.20	03.02		BD due to Conductor snapped	GTN	-
11		Pashamailaram	BOC	33KV	Sangareddy	18.35	21.45	03.10		BD due to Tree fallen on line	BOC	-
12		Pashamailaram	APL5	33KV	Sangareddy	18.45	22.55	04.10		BD due to Tree fallen on line	APL5	-
13		Pashamailaram	APL IV	33KV	Sangareddy	18.35	21.55	03.20		BD due to Tree fallen on line	APL IV	-
14		Pashamailaram	Nandigama	33KV	Sangareddy	18.35	21.25	02.50		BD due to Jumper cut	Nandigama	-
15		Borpatla	Covalent	33KV	Jogipet	18.46	20.30	01.44		BD due to Heavy Rain & Wind	Covalent	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 27.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	DHANWADA	DHANWADA RURAL	11KV	Narayanapet	07.00	10.00	03.00		Breakdown due to jumper cut and fallen on DTR at dhanwada rural	-
2		EKLASPUR	JINNARAM	11KV	Narayanapet	03.45	06.00	02.15		Breakdown due to heavy gale and wind	-
3		EKLASPUR	KANMANUR	11KV	Narayanapet	09.20	12.40	03.20		Breakdown due to jumper cut and fallen on DTR at buddegani thanda	-
4		CHINNAJATRAM	CHINNAJATARAM	11KV	Narayanapet	15.55	17.04	01.09		Breakdown due to 25KVA DTR fail at S.C.wada	-
1	MDK	Patancheru Town	Allwyn	11KV	Patancheru	17.15	20.20	03.05		BD due to heavy rain & wind	-
2		Kistareddypet	Kistareddypet	11KV	Patancheru	20.20	20.50	00.30		BD due to Jumper cut	-
3		EPIP-I	kirby	11KV	Sangareddy	20.35	22.30	01.55		BD due to Tree fallen on line	-
4		Patancheru Town	High power	11KV	Patancheru	21.10	21.35	00.25		BD due to Jumper cut	-
5		Bollaram - I	NCL	11KV	Patancheru	18.20	20.18	01.58		BD due to Disk failed	-
6		Bollaram - I	Pavan	11KV	Patancheru	19.50	20.55	01.05		BD due to Insulator failed	-
1	SDP	Chinnagundavelly	Chinnagundavelly	11KV	Siddipet	12.58	15.45	02.47		B/D Due to Bird	-
2		Chowdaram	Yellammajalu	11KV	Siddipet	13.33	17.30	03.57		B/D Insulater fail	-
3		PREGNAPUR	PREGNAPUR TOWN	11KV	Gajwel	16.25	17.04	00.39		CONDUCTOR SNAPPED	-
4			PREGNAPUR TOWN	11KV	Gajwel	17.39	18.20	00.41		INSULAOR FAILED	-
5		MARPADGA	NAGIREDDYPALLI	11KV	Gajwel	15:20	16:50	01:30		CONDUCTOR SNAPPED	-
6			MARPADGA AGL- II	11KV	Gajwel	16:15	16:45	0:30		INSULATOR FAILED	-
7		Komuravelli	Kadaverugu	11KV	Husnabad	15.10	17.10	02.00		Cable burnt	-
1	RR N	Jeedimetla-III	V S P organic	11KV	Jeedimetla	19.27	21.00	01.33	EL/OL	11kv Conductor snapped At Myline company	-
2		Jeedimetla-I	Phase-II	11KV	Jeedimetla	19.25	20.55	01.30	EL/OL	11kv Endy Kit failure At Phase-IV	-
3		Jeedimetla-I	Nitco	11KV	Jeedimetla	19.30	20.35	01.05	EL/OL	No Foutl due To rain	-
4		UMCC	Mini Industry	11KV	Medchal	18.00	18.40	00.40	BD	11KV AB Cable failed at Vivekananda Nagar	-
5		Kolthur	Anantharam	11KV	Medchal	11.28	12.08	00.40	BD	Bird fallen on the 11KV Line at Saikrupa Garden	-
6		Keshavaram	Keshavaram	11KV	Medchal	12.02	13.20	01.18	BD	Tree Branches touched on the 11KV Line at Keshavaram Thanda	-
7		Keshavaram	Dairy	11KV	Medchal	12.02	13.20	01.18	BD	Tree Branches touched on the 11KV Line at Keshavaram Thanda	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
8		Kistapur	IDA Hanuman	11KV	Medchal	14.10	14.50	00.40	BD	Linghtening Arrester failed at Ravalkole Chowrasta	-
9		GP Pally	GP Pally	11KV	Medchal	19.20	20.30	01.10	BD	Tree fallen on the 11KV Line at Ayodya X Roads	-
1	RR E	Techpark	Haryanasteel	11KV	Habsiguda	02.15	03.45	01.30		11KV Pole damaged due to Car dashed at GVK Company & Half load Back feeding supply taken from 11KV AP Food feeder	-
2		Techpark	Ap food	11KV	Habsiguda	14.38	15.40	01.02		Ht/LT line cut at Ap food	-
1	HYD N	I.D.P.L.	Tipcon	11KV	VI	17.20	18.35	01.15	EL,OL	HT line snapped at Fan Company	-----
2		Lodha	I.E	11KV	IV	17.37	19.22	01.45	OL	Cable fault at Fathe Nagar (3Nos. DTRs kept off)	-----
3		Jana Priya	Erragadda	11KV	IV	18.20	19.30	01.10	EL	Tree branches fallen on lines at Darga	Arranged B/F on 11KV Rajiv Nagar feeder
4		Jana Priya	Shastry Nagar	11KV	IV	23.05	00.42	01.37	EL	Cable fault at Janapriya Gate	Arranged B/F on 11KV P.R Nagar feeder