

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		3		3		3			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>11</b>	<b>1</b>	<b>11</b>	<b>1</b>	<b>11</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 29.04.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Singoor	Muddaipet	33KV	Jogipet	17.30	19.05	01.35		BD due to Conductor snapped	Muddaipet	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 29.04.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gudeballore	KOTHAPALLY	11kv	Narayanapet	07.00	09.00	02.00		Due to 11kv line cut at checkpost	-
2		Gudeballore	SATAYASAI & LIFT	11kv	Narayanapet	10.00	11.25	01.25		Due to Pin Binding cut and fallen on DTR at nallagattu	-
3		PALLERLA	NADIPAD	11kv	Narayanapet	00.45	11.00	10.15		Due to 100kva DTR fail at nandipad vlg	-
4		MARIKAL	ELIGANDLA	11kv	Narayanapet	09.04	11.23	02.19		Due to 11kv line cut at eligendla vlg	-
1	NLG	Kalmlacheruvu	Kalmlacheruvu	11kv	Huzurnagar	00.00	06.50	06.50	E/L	11Kv Line Snapped	-
2		Alair	lkkurthy	11kv	Bhongir	09.10	10.10	01.00	E/L	25kva DTR failed near dilwarpur (V)	-
3		Padatapally	Thuruppally	11kv	Devarakonda	08.00	11.55	03.55	E/L	11Kv Line Snapped	-
1	MDK	Cheryal	Turbovent	11kv	Sangareddy	18.40	19.30	00.50		BD due to Jumper cut	-
2		EPIP-II	Marigold	11kv	Sangareddy	17.03	17.40	00.37		BD due to Tree branches fallen on the line	-
1	RR N	Prashanth Hills	Prashanth Hills	11kv	Kukatpally	14.21	15.21	01.00	EL	GHMC Road Work , Public T/F Feldown at Madhuranagar	-
1	HYD N	Clock Tower	Anjali	11kv	V	09.05	10.30	01.25	EL,OL-Bph	I/C Cable fault	Arranged B/F on 11KV R.P.Road fdr