

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	0	2	0	2	0	2			
6	RR(N)	54	550	0	1	0	1	0	1			
7	RR(E)	168	403	0	1	0	1	0	1			
8	Hyd	194	1044	0	3	0	3	0	3			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	1	0	1	0	1			
2	NLG	144	988	0	3	0	3	0	3			
3	MDK	107	933	0	3	0	3	0	3			
4	SDPT			0	3	0	3	0	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	10	0	10	0	10	0	0	
	Grand Total	1082	6468	0	17	0	17	0	17	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown
1	Mahabubnagar	Polepally	MNR	11KV	Jadcherla	07.30	10.51	03.21		11 KV wire cut near Tharma cable.
2	Nalgonda		Munukuntla	11KV	Nalgonda	10.00	13.00	03.00		11KV Jumper Cut
3	Sangareddy	Cheryal	Turbovent	11KV	Sangareddy	16.40	19.30	02.50		B/D Due to Insulator Failure
4		Patancheru Town	Town	11KV	Patancheru	17.10	18.40	01.30		B/D Due to tree branch fallen on the line
5		Patancheru Town	Kanjarla	11KV	Patancheru	11.55	13.40	01.45		B/D Due to Conductor Snapped
6	Siddipet	Habshipur	Dharmaram	11KV	Siddipet	16.25	17.23	00.58		B/D LT Line Touch
7		Mirdoddi	Mirdoddi	11KV	Siddipet	10.20	14.00	03.40		B/D Insulator Fail Lcno 5606
8		Thukkapur SS	Thukkapur Industrial Feeder LC.No.7754	11KV	Gajwel	12.12	13.52	01.40		Pin insulator fail
9	Suryapet	Annaram	Annaram	11KV	SURYAPET	07.10	11.30	04.20		Insulator failed
10	Yadadri Circle	Addagudur	Ch.Ramaram	11KV	Bhongir	08.05	10.20	02.15		11kv Insulator Failed at Ch.Ramaram Village
11	Hyd Central	Golnaka	Nehru Nagar	11KV	Azamabad	02.21	04.23	02.02	EL,OL	Cable fault at Oil Depot
12	Hyd North	MLA Colony	V.L.C.C	11KV	Banjara Hills	16.45	17.50	01.05	EL	Tree branches fallen on lines Ex Minister Chenna Reddy House
13		S.P.R Hills	Mahathama Nagar	11KV	Green Lands	17.23	18.40	01.17	EL,OL-Bph	AB Switch I/C side Cable End Kit fault at H.F Nagar
14	CYBER CITY	Kothaguda	Botanical garden	11KV	KONDAPUR	04.10	05.50	01.40	EL	AB Cable fault at Akruthi apartment,Sriram nagar
15	SAROOR NAGAR	Mother dairy	Ganesh nagar	11KV	SAROOR NAGAR	06.15	08.00	01.45	EL	Jumper cut at Narayana College
16	MEDCHAL	Miyapur X Road	ASR Statue	11KV	KUKATPALLY	18.35	19.45	01.10	OL	11KV Pin Insulator failed at Neelima Heights
17	RAJENDRA NAGAR	Mdpally	Bandlaguda	11KV	RAJENDRA NAGAR	23.03	00.15	01.12	EI/OL	Line patrolling done fault not found

