

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	0	0	0	0	0	0			
6	RR(N)	54	550	2	7	2	7	2	7			
7	RR(E)	168	403	0	12	0	12	0	12			
8	Hyd	194	1044	0	3	0	3	0	3			
	Total	606	3055	2	22	2	22	2	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	6	1	6	1	6			
2	NLG	144	988	0	19	0	19	0	19			
3	MDK	107	933	2	23	2	23	2	23			
4	SDPT			0	0	0	0	0	0			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	48	3	48	3	48	0	0	
	Grand Total	1082	6468	5	70	5	70	5	70	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.08.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanpet	07.45	10.50	03.05	E/L	33KV Jumper Cut Near 132KV SS Maddur		NO
2	RR N	132KV LGM Pet	33KV MN Park	33KV	MEDCHAL	04.48	07.12	02.24		No Fault (Idle Charged)		
3		132KV LGM Pet	33KV MN Park	33KV	MEDCHAL	07.45	09.15	01.30		Tree Branch fallen on the 33KV Line at Vimta Labs		
4	SRD	Zaheerabad	Chota Hyderabad	33KV	Zaheerabad	03.15	06.25	03.10		BD due to after petrolling no fault at found		
5				33KV		09.02	10.57	01.55		BD due to Isolator brust		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.08.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	IDA Uppal	Ram Reddy Nagar	11KV	Habsiguda	05.35	07.05	01.30		replaced at Ambedkar statue at KCR	
2		Techpark	Balaji	11KV	Habsiguda	07.00	07.50	00.50		Tripped on EL(Balaji Braker Fault at SS Yard)	
3		Uppal Kalsa	Sri Sri Nagar	11KV	Habsiguda	23.40	01.05	01.25		Tripped on EL/OL (Due to 11KV Pin Insulator failed at SBI Bank Beside Gully)	
4		Uppal Kalsa	Vegitable Market	11KV	Habsiguda	23.55	01.20	01.25		Tripped On OL(Due to Tree Branches fallen on 11KV line at Vegitable market Boddurai)	
5		Mallapur	Sai Nagar	11KV	Habsiguda	23.50	01.30	01.40		Tripped on EL/OL(Due to 11KV Pin Insulator failed at Methal Industries)	
6		Kushaguda	Rukminipuri	11KV	Sainikpuri	05.45	06.37	00.52		11Kv Pin Insuletor fail at Krishna Sai Apt	
7		Janapriya	Vampuguda	11KV	Sainikpuri	06.02	07.05	01.03		Vampuguda Community Hall (LM	
8		Sainikpuri	Eshwaripuri	11KV	Sainikpuri	07.05	08.40	01.35		11KV polymer disk failed at Bhaskar Rao Colony Bus Stop (AF)	
9		Janapriya	High Tension	11KV	Sainikpuri	11.35	12.50	01.15		Bird fallen on 11Kv line at Kattamaisamma Temple (LM Narshima)	
10		Nagaram	S N Colony	11KV	Keesara	00.43	02.33	01.50		11KV Line Cut at Near Surya Bai Function Hall	
11		Ghatkesar	Ghatkesar	11KV	Keesara	23.54	00.32	00.38		11KV Pin Insulator failed at Sahanthi Nagar	
12		Peerazadiguda	Peerazadiguda	11KV	Keesara	11.25	12.30	01.05		11KV Disk Failed at Wood Company	
13	MBNR	Marikal	Kanmankalva	11KV	Jadcherla	00.00	07.56	07.56		11 KV Pole Damaged Near Lingampally(V)	
14		Annasagar	Annasagar Agl	11KV	Jadcherla	06.50	10.13	03.23		11KV Jumper Cut Near Annasagar (V)	
15		Bhoothpur	Amistapur Agl	11KV	Jadcherla	08.42	09.26	00.44		Bird Died On The 11KV Line Near Amistapur(V)	
16		Gudeballore	Khandoddi	11KV	Narayanpet	07.40	09.00	01.20		11KV Line cut at Khandoddi Agl	
17		Paspula	Satyaram	11KV	Narayanpet	00.20	07.00	06.40		Due to Gale and Wind	
18		Paspula	Paspula Bheema Lift	11KV	Narayanpet	00.20	07.00	06.40		Due to Gale and Wind	
19	RRN	Miyapur X road	Lotus Colony	11KV	kukatpally	03.50	05.25	01.35	EL/OL	11kv Post Of Insultor Failure At Uday Bhanu House	Insultor Failure At Uday Bhanu
20		Geonome Valley	Nectar	11KV	MEDCHAL	07.00	07.40	00.40		11KV HG Fuse replaced at Rodennta Pharma	
21		Gowdavelly	IDA Gowdavelly	11KV	MEDCHAL	03.20	04.20	01.00		11KV Line AB Switch Opened at Church(Tree Fallen on 11KV Line at saketh Vencher)	
22		Kandlakoya	IDA Godrej	11KV	MEDCHAL	08.00	08.45	00.45		11KV Jumper cut and replaced at kandlakoya X Road	
23		Keshavaram	Uddamarry	11KV	MEDCHAL	03.15	09.37	06.22		11KV Jumper Cut & Replaced at Venkateswara Swamy Temple	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
24		Medchal	Check Post	11KV	MEDCHAL	17.45	18.25	00.40		11KV Conductor Snapped and Replaced at near by SS	
25		Thumkunta	Thumkunta	11KV	MEDCHAL	06.05	07.40	01.35		Tree fallen on 11KV Line at Domas	
26	NALGONDA	Kothapally	Peddamunigal	11KV	Devarakonda	10.15	12.10	01.55	EL	Conductor Snapped	
27		Ghanpur	Polkampally	11KV	Devarakonda	06.10	08.30	02.20	EL	Pin insulator failed	
28		Akaram	Vallala	11KV	Nalgonda	04.30	05.45	01.15	EL	11KV Jumper Cutt	
29		Nakerikal	Chandhampally	11KV	Nalgonda	06.30	09.40	03.10	EL	Tree Flowen	
30		Eduloor	Parada	11KV	Nalgonda	04.00	09.00	05.00	EL	11KV Jumper Cutt	
31		Nangunoor	Nagarajupally	11KV		11.43	14.23	02.40		B/D for Tripping	
32	Rampur	JP Thanda	11KV		06.15	09.10	02.55		B/D for Pole damage		
33	Naremtta	Naremtta	11KV		06.10	13.00	06.50		B/D for Tree branches fall on 11KV Line LC No.12242		
34	Venkatapur	Bussapur	11KV		14.45	17.10	02.25		B/D for 11KV Conductor cut		
35	Ponnal	Kistasagar	11KV		02.10	08.10	06.00		B/D for Insulator fail LC No.33854		
36	Ensanpally	Ensanpally	11KV	Siddipet	02.10	02.54	00.44		B/D for Pin binding fail		
37	Gonepally	Chinnakodur	11KV		11.05	13.40	02.35		B/D for Disc fail LC No.8367		
38	Dubbak	Lachapet	11KV		02.20	08.25	06.05		B/D for 11KV Line phase to phase		
39	Ragothampally	Akaram	11KV		02.18	10.15	07.57		B/D for Tree branches fall on 11KV Line		
40	Ragothampally	Gosanpally	11KV		02.30	09.20	06.50		B/D for Insulator fail LC No.1329		
41	Kokkonda SS	Nujiveedu LC;	11KV		22.20	05.45	07.25		Tripping EL		
42	Chillasagar Ss	Industrial LC :	11KV		02.00	06.00	04.00		EL		
43	Marpadaga SS	Sirsinagandla	11KV		06.46	10.48	03.58		Disk Fail		
44	Marpadaga SS	Sirsinagandla	11KV	Gajwel	12.32	18.00	05.28		DTR Fail		
45	Kondaipaka SS	Vishvanathapally	11KV		07.20	11.35	04.15		Disk Fail		
46	Bandaram SS	Bandaram	11KV		02.50	06.00	03.10		Tripping due to Rain		
47	Anajipur SS	Manthur	11KV		4:00	9:00	5:00		Disk Failure		
48	Thukkapur SS	Industrial	11KV		09.20	13.40	04.20		Bird Fallen On Line		
49	Ismailkhan Pet	Industrial	11KV	Sangareddy	06.50	09.40	02.50		BD due to Insulator failed		
50	Ismailkhan Pet	Erdhanoor	11KV	Sangareddy	03.10	08.40	05.30		BD due to Insulator failed		
51	Bollaram - I	Sulaxshana-I	11KV	Patancheru	07.00	09.00	02.00		BD due to Conductor snapped		
52	Bollaram - I	NCL	11KV	Patancheru	04.40	05.40	01.00		BD due to heavy rain		
53	Collectorate	Collector Feeder	11KV	Sangareddy	01.36	07.32	05.56		BD due to Tree branches fallen on line		
54	T.Singaram	Mood thanda	11KV	SURYAPET	06.40	08.50	02.10		Jumper cut		
55	D.Nagaram	W.Kota	11KV	SURYAPET	03.30	06.50	03.20		Insulator failed		
56	Y Singaram	Magdunagar	11KV	Huzurnagar	07.05	08.30	01.25				
57	Dirsincherla	Yallapuram	11KV	Huzurnagar	06.30	07.20	00.50				
58	Palakeedu	Nagireddy gudem	11KV	Huzurnagar	04.00	04.59	00.59				
59	Nandanam	Telephone exchange	11KV	Bhongir	04.05	06.45	02.40			11 kv insulator failed at Poultry farm near Anajipur village	
60	MR.Gudem	Baswapur	11KV	Bhongir	12.00	15.00	03.00			11kv Insulator Failed near Baswapur Village	
61	Chamapur	Chandepally	11KV	Bhongir	02.45	11.15	08.30			11 kv Disc failed at SS-03 near Chandepally village	
62	Suddala	Bramahanapally	11KV	Bhongir	06.00	09.50	03.50			11kv DTR failed at SS-9 near Bramhanapally village	
63	Laxmapuram	Nidanpally	11KV	Choutuppal	23.40	08.30	08.50			11 kv Insulator failed near nidanpally village	
64	BP.Pally	Bheemanapally	11KV	Choutuppal	14.00	15.30	01.30			11kv Insulator Failed near Bheemanpally Village	
65	Voligonda	Dasireddygudem Indl	11KV	Choutuppal	01.30	10.00	08.30			11 kv Insulator failed near Voligonda	
66	Sangem	Sangem	11KV	Choutuppal	04.04	09.25	05.21			11 kv insulator failed at Gadagottam well near Sangem village	
67	Vemulakonda	Gopirajpally	11KV	Choutuppal	13.20	15.10	01.50			11kv Insulator Failed near Gopirajpally Village	
68	Hyd Central	Golnaka	Shivalayam	11KV	Azamabad	05.22	10.45	05.23	OL	flash over at Shivalayam DTR & Disc Insulator	
69	Hyd South	Karwan	Jiyaguda Cable	11KV	Begumbazar	07.55	09.05	01.10	EL	Cable fault at Opp: SS	
70	Secunderabad	Osm. University	Osm. University	11KV	Paradise	10.40	12.30	01.50	EL	Pin Insulator flash over at Osmania University	