

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                           | 107         | 0                                  | 0        | 0                       | 0        | 0                                   | 0        |                                |          |                   |
| 2    | NLG          | 22                           | 358         | 0                                  | 0        | 0                       | 0        | 0                                   | 0        |                                |          |                   |
| 3    | MDK          | 97                           | 359         | 0                                  | 0        | 0                       | 0        | 0                                   | 0        |                                |          |                   |
| 4    | SDPT         |                              |             | 0                                  | 0        | 0                       | 0        | 0                                   | 0        |                                |          |                   |
| 5    | RR(S)        | 53                           | 234         | 0                                  | 1        | 0                       | 1        | 0                                   | 1        |                                |          |                   |
| 6    | RR(N)        | 54                           | 550         | 0                                  | 0        | 0                       | 0        | 0                                   | 0        |                                |          |                   |
| 7    | RR(E)        | 168                          | 403         | 0                                  | 1        | 0                       | 1        | 0                                   | 1        |                                |          |                   |
| 8    | Hyd          | 194                          | 1044        | 0                                  | 1        | 0                       | 1        | 0                                   | 1        |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                   | <b>3055</b> | <b>0</b>                           | <b>3</b> | <b>0</b>                | <b>3</b> | <b>0</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                           | 849         | 1                                  | 1         | 1                       | 1         | 1                                   | 1         |                                |          |                   |
| 2    | NLG                | 144                           | 988         | 0                                  | 4         | 0                       | 4         | 0                                   | 4         |                                |          |                   |
| 3    | MDK                | 107                           | 933         | 0                                  | 0         | 0                       | 0         | 0                                   | 0         |                                |          |                   |
| 4    | SDPT               |                               |             | 0                                  | 2         | 0                       | 2         | 0                                   | 2         |                                |          |                   |
| 5    | RR(S)              | 58                            | 396         | 0                                  | 0         | 0                       | 0         | 0                                   | 0         |                                |          |                   |
| 6    | RR(N)              | 38                            | 114         | 0                                  | 0         | 0                       | 0         | 0                                   | 0         |                                |          |                   |
| 7    | RR(E)              | 22                            | 133         | 0                                  | 0         | 0                       | 0         | 0                                   | 0         |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                    | <b>3413</b> | <b>1</b>                           | <b>7</b>  | <b>1</b>                | <b>7</b>  | <b>1</b>                            | <b>7</b>  | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                   | <b>6468</b> | <b>1</b>                           | <b>10</b> | <b>1</b>                | <b>10</b> | <b>1</b>                            | <b>10</b> | <b>0</b>                       | <b>0</b> |                   |

TSSPDCL - LMRC / Corporate office

Date: 20.08.2021

Circle-wise 33KV Breakdowns

| S.No | Circle        | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                              | Sub Stations Effected | Alternate Supply Arranged |
|------|---------------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1    | Mahaboobnagar | Polepally           | Jadcherla            | 33KV | Jadcherla            | 22.17 | 00.18 | 02.01    | E/L&O/L          | 33KV Jumper Connecting Purpose at Polepally Sez |                       |                           |

**TSSPDCL - LMRC / Corporate office**

**Circle-wise 11KV Breakdowns**

**Date: 20.08.2021**

| S.No | Circle       | Name of 33/11KV SS | Name of 11 KV Feeder                       | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged |
|------|--------------|--------------------|--|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1    | CYBER CITY   | Vattinagulapally   | Aparna                                     | 11KV | IBRAHIMBAGH          | 17:08 | 19:20 | 2:12     | OL               | 2 Pole damaged & 11Kv line snapped and rectified at Movie tower gutta |                           |
| 2    | SARoor NAGAR | Fruit market       | Ganga Hospital                             | 11KV | SARoor NAGAR         | 23.25 | 01.20 | 01.55    | EL/OL            | 11KV Line snapped at Fruit market back side gate                      |                           |
| 3    | Nagarkurnool | Hajipur            | Hajipur Indl Feeder                        | 11KV | Nagarkurnool         | 23.00 | 23.10 | 00.10    | O/L              | Tripped on O/L  |                           |
| 4    | Nalgonda     | Mellavai SS        | Devathpaly                                 | 11KV | Devarakonda          | 08.10 | 09.16 | 01.06    | E/L              | Pin insulator Failed  |                           |
| 5    |              | Chinthpally        | Vinjamoor                                  | 11KV | Devarakonda          | 08.10 | 10.00 | 01.50    | E/L              | Pin insulator Failed  |                           |
| 6    |              | K.M.Pally          | C.A.Pally                                  | 11KV | Devarakonda          | 11.00 | 12.30 | 01.30    | E/L              | Jumper Cut  |                           |
| 7    | Siddipet     | MARKOOK            | SNEHA INDUSTRIAL (LC.NO:21919) DHARSHAN.LM | 11KV | Gajwel               | 01.00 | 10.00 | 09.00    |                  | POLE BROKEN   |                           |
| 8    |              | ERRAVALLY          | NARSANNAPET (LC.NO:25827) LAXMAN.LM        | 11KV | Gajwel               | 09.10 | 13.20 | 04.10    |                  | BIRD FALLEN ON 11 KV LINE   |                           |
| 9    | Yadadri      | Golnepally         | Nemalikaluva                               | 11KV | Choutuppall          | 07.45 | 08.30 | 00.45    |                  | 11 KV Insulator failed near Nemalikaluva village                      |                           |
| 10   | Hyd Central  | Narayanaguda       | Narayanaguda                               | 11KV | Azamabad             | 19.22 | 20.35 | 01.13    | EL,OL            | HG fuse blown at Amrutha Bar  |                           |