

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		4		4		4			
3	MDK	107	933		1		1		1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	9	0	9	0	9	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
										Nil		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 01.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mothiganapur	Mothiganapur	11KV	Jadcherla	13.15	14.20	01.05		11KV Jumper cut near Mothiganapur	-
1	NLG	R.C Puram	Rama Chandrapuram	11KV	Suryapet	09.30	12.00	02.30	E/L	Bird fallen on the line	-
2		Ch.Annaram	Chervuannaram	11KV	Nalgonda	06.30	10.40	04.10	E/L	11KV Jumper cut	-
3		Eduloor	Parada	11KV	Nalgonda	10.10	12.00	01.50	E/L	11KV Insulator cut	-
4		Ch.Annaram	Garlabaigudem	11KV	Nalgonda	14.10	15.40	01.30	E/L	11KV Jumper cut	-
1	MDK	Pati	My Home	11KV	Patancheru	16.00	21.50	05.50		BD due to Jumper cut	-
2	SDPT	Chittapur	Chowdarpally	11KV	Siddipet	15.32	16.34	01.02		B/D - Tree branches fallen on the line, LC No. 25688	-
3		DUDEEDA	DUDEEDA TOWN	11KV	Gajwel	08.15	09.15	01.00		THE TREE BRANCH BROKE & FELL ON THE 11KVA LINE	-
4		DUDEEDA	DUDEEDA TOWN	11KV	Gajwel	11.05	11.44	00.39		THE TREE BRANCH BROKE & FELL ON THE 11KVA LINE	-
1	HYD N	Gymkhana	Rani Bagh	11KV	C-VI	13.00	14.17	01.17	All Indication	Cable fault at SS	Arranged B/F on 11KV Pared Ground fdr
1	HYD S	Hyderguda	Jana Priya OH	11KV	III	10.59	14.23	03.24	EL	O/G Cable fault at Jana Priya Apts	-